

測定月報

測定日: 2018/02

(1/7)

日	モニタ											
	A001 正門警備所 (DM71)			A002 正門警備所 (DM72)			A003 免震重要棟(DM-45)			A004 免震重要棟(DM-52)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.67E-06	1.5	100	4.54E-06	1.1	100	4.70E-06	7.0	100	4.27E-06	6.6	100
2	3.95E-06	1.5	100	3.94E-06	1.1	100	3.97E-06	7.0	100	3.70E-06	6.6	100
3	5.85E-06	1.5	100	5.74E-06	1.1	100	5.79E-06	7.0	100	5.58E-06	6.6	100
4	3.11E-06	1.5	100	3.04E-06	1.1	100	3.36E-06	7.0	100	3.10E-06	6.6	100
5	5.29E-06	1.5	100	5.18E-06	1.1	100	5.34E-06	7.0	100	4.94E-06	6.6	100
6	5.77E-06	1.5	100	5.64E-06	1.1	100	5.84E-06	7.0	100	5.44E-06	6.6	100
7	2.27E-06	1.5	100	*1 2.26E-06	1.2	100	2.60E-06	7.0	100	2.29E-06	6.6	100
8	2.58E-06	1.5	100	2.39E-06	1.5	100	2.75E-06	7.0	100	2.46E-06	6.6	100
9	4.38E-06	1.5	100	4.01E-06	1.5	100	4.44E-06	7.2	100	4.11E-06	6.6	100
10	5.87E-06	1.5	100	5.50E-06	1.5	100	5.38E-06	7.7	100	5.30E-06	6.6	100
11	3.12E-06	1.5	100	3.00E-06	1.5	100	3.04E-06	7.7	100	3.16E-06	6.6	100
12	2.58E-06	1.5	100	2.45E-06	1.5	100	2.47E-06	7.7	100	2.53E-06	6.6	100
13	4.78E-06	1.5	100	4.52E-06	1.5	100	4.43E-06	7.7	100	4.55E-06	6.6	100
14	*1 3.42E-06	1.5	100	3.24E-06	1.5	100	3.08E-06	7.7	100	*1 3.29E-06	6.6	100
15	3.26E-06	1.4	100	3.07E-06	1.5	100	3.12E-06	7.7	100	3.28E-06	6.6	100
16	3.77E-06	1.4	100	3.54E-06	1.5	100	3.15E-06	7.7	100	3.35E-06	6.6	100
17	6.02E-06	1.4	100	5.66E-06	1.5	100	5.52E-06	7.7	100	5.63E-06	6.6	100
18	3.03E-06	1.4	100	2.67E-06	1.5	100	2.60E-06	7.7	100	2.83E-06	6.6	100
19	4.80E-06	1.4	100	4.33E-06	1.5	100	3.89E-06	7.7	100	4.05E-06	6.6	100
20	4.96E-06	1.4	100	4.58E-06	1.5	100	*1 4.39E-06	7.6	100	4.52E-06	6.6	100
21	4.16E-06	1.4	100	3.77E-06	1.5	100	3.81E-06	7.3	100	3.83E-06	6.6	100
22	4.62E-06	1.4	100	4.34E-06	1.5	100	4.28E-06	7.3	100	4.21E-06	6.6	100
23	4.27E-06	1.4	100	3.99E-06	1.5	100	4.05E-06	7.3	100	4.03E-06	6.6	100
24	4.44E-06	1.4	100	4.14E-06	1.5	100	4.28E-06	7.3	100	4.17E-06	6.6	100
25	5.57E-06	1.4	100	5.03E-06	1.5	100	5.03E-06	7.3	100	5.07E-06	6.6	100
26	6.06E-06	1.4	100	5.73E-06	1.5	100	5.63E-06	7.3	100	5.74E-06	6.6	100
27	7.67E-06	1.4	100	7.29E-06	1.5	100	7.16E-06	7.3	100	7.02E-06	6.6	100
28	6.96E-06	1.4	100	6.65E-06	1.5	100	6.25E-06	7.3	100	6.15E-06	6.6	100
29												
30												
31												
1ヶ月値	4.55E-06	1.4	100	4.30E-06	1.4	100	4.30E-06	7.4	100	4.24E-06	6.6	100
*2 最大値	1.49E-05	1.5	102	1.37E-05	1.5	103	1.57E-05	7.7	101	1.27E-05	6.6	102
最大値日時	02/27 23:55	02/01 00:01	02/01 23:07	02/28 00:01	02/07 15:59	02/28 19:42	02/20 16:15	02/09 17:20	02/01 00:10	02/27 23:08	02/01 00:01	02/02 01:56
*2 最小値	0.00E+00	1.4	98	0.00E+00	1.1	98	0.00E+00	7.0	98	0.00E+00	6.6	98
最小値日時	02/08 16:24	02/14 14:43	02/01 00:41	02/07 15:59	02/01 00:01	02/01 04:53	02/09 17:20	02/01 00:01	02/09 16:42	02/14 14:09	02/01 00:01	02/01 20:35

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(2/7)

日	モニタ											
	A005			A006			A007			A008		
	5/6号警備所前(DM49)			5/6号警備所前(DM54)			1号北側法面上(旧厚生棟)(DM-67)			1号北側法面上(旧厚生棟)(DM-76)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.34E-06	1.4	100	4.65E-06	1.9	100	4.84E-06	8.9	100	5.04E-06	7.9	100
2	3.67E-06	1.4	100	3.94E-06	1.9	100	4.14E-06	8.9	100	4.23E-06	7.9	100
3	5.54E-06	1.4	100	5.91E-06	1.9	100	6.14E-06	8.9	100	6.25E-06	7.9	100
4	3.08E-06	1.4	100	3.27E-06	1.9	100	3.46E-06	8.9	100	3.58E-06	7.9	100
5	4.97E-06	1.4	100	5.34E-06	1.9	100	5.58E-06	8.9	100	5.66E-06	7.9	100
6	5.43E-06	1.4	100	5.77E-06	1.9	100	6.31E-06	8.9	100	6.27E-06	7.9	100
7	2.27E-06	1.4	100	2.37E-06	1.9	100	2.55E-06	8.9	100	*1 2.51E-06	8.2	100
8	2.43E-06	1.4	100	*1 2.63E-06	1.9	100	2.77E-06	8.9	100	2.40E-06	8.7	100
9	4.29E-06	1.4	100	4.88E-06	1.8	100	4.69E-06	8.9	100	4.08E-06	8.7	100
10	5.58E-06	1.4	100	6.45E-06	1.8	100	6.11E-06	8.9	100	5.37E-06	8.7	100
11	3.22E-06	1.4	100	3.73E-06	1.8	100	3.55E-06	8.9	100	3.18E-06	8.7	100
12	2.57E-06	1.4	100	2.91E-06	1.8	100	2.95E-06	8.9	100	2.50E-06	8.7	100
13	4.60E-06	1.4	100	5.21E-06	1.8	100	5.07E-06	8.9	100	4.39E-06	8.7	100
14	3.15E-06	1.4	100	3.65E-06	1.8	100	3.60E-06	8.9	100	3.12E-06	8.7	100
15	3.16E-06	1.4	100	3.66E-06	1.8	100	3.68E-06	8.9	100	3.13E-06	8.7	100
16	3.32E-06	1.4	100	3.74E-06	1.8	100	3.70E-06	8.9	100	3.23E-06	8.7	100
17	5.27E-06	1.4	100	5.96E-06	1.8	100	6.27E-06	8.9	100	5.39E-06	8.7	100
18	2.75E-06	1.4	100	3.06E-06	1.8	100	3.18E-06	8.9	100	2.69E-06	8.7	100
19	*1 4.12E-06	1.4	100	4.55E-06	1.8	100	*1 4.59E-06	9.0	100	4.02E-06	8.7	100
20	4.37E-06	1.5	100	4.99E-06	1.8	100	4.59E-06	9.2	100	4.29E-06	8.7	100
21	3.89E-06	1.5	100	4.29E-06	1.8	100	3.88E-06	9.2	100	3.68E-06	8.7	100
22	4.39E-06	1.5	100	4.75E-06	1.8	100	4.38E-06	9.2	100	4.10E-06	8.7	100
23	3.94E-06	1.5	100	4.40E-06	1.8	100	4.21E-06	9.2	100	3.92E-06	8.7	100
24	4.36E-06	1.5	100	4.92E-06	1.8	100	4.51E-06	9.2	100	4.08E-06	8.7	100
25	5.18E-06	1.5	100	5.75E-06	1.8	100	5.29E-06	9.2	100	4.89E-06	8.7	100
26	5.80E-06	1.5	100	6.43E-06	1.8	100	5.90E-06	9.2	100	5.42E-06	8.7	100
27	7.32E-06	1.5	100	8.07E-06	1.8	100	7.37E-06	9.2	100	6.74E-06	8.7	100
28	6.34E-06	1.5	100	7.10E-06	1.8	100	6.50E-06	9.2	100	5.94E-06	8.7	100
29												
30												
31												
1ヶ月値	4.26E-06	1.4	100	4.73E-06	1.8	100	4.64E-06	9.0	100	4.29E-06	8.5	100
*2 最大値	1.38E-05	1.5	103	1.47E-05	1.9	102	2.45E-05	9.2	102	1.35E-05	8.7	102
最大値日時	02/28 00:04	02/19 14:41	02/05 07:30	02/27 23:51	02/01 00:01	02/01 05:04	02/19 14:59	02/19 14:59	02/01 00:31	02/03 08:04	02/07 15:28	02/01 00:29
*2 最小値	0.00E+00	1.4	97	0.00E+00	1.8	98	0.00E+00	8.9	97	0.00E+00	7.9	97
最小値日時	02/08 15:23	02/01 00:01	02/14 04:37	02/08 16:01	02/08 16:01	02/02 04:23	02/13 15:57	02/01 00:01	02/07 22:06	02/07 15:28	02/01 00:01	02/05 05:35

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(3/7)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上 (DM59)			1/2号西側法面上 (DM65)			3/4号西側法面上 (DM64)			3/4号西側法面上 (DM48)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.32E-06	6.7	100	4.24E-06	7.1	100	4.33E-06	3.6	100	4.51E-06	4.2	100
2	3.72E-06	6.7	100	3.63E-06	7.1	100	3.81E-06	3.6	100	4.01E-06	4.2	100
3	5.42E-06	6.7	100	5.34E-06	7.1	100	5.71E-06	3.6	100	6.12E-06	4.2	100
4	3.09E-06	6.7	100	3.02E-06	7.1	100	3.11E-06	3.6	100	3.34E-06	4.2	100
5	5.01E-06	6.7	100	4.91E-06	7.1	100	5.14E-06	3.6	100	5.31E-06	4.2	100
6	5.48E-06	6.7	100	5.38E-06	7.1	100	5.66E-06	3.6	100	5.75E-06	4.2	100
7	2.24E-06	6.7	100	2.17E-06	7.1	100	2.29E-06	3.6	100	2.46E-06	4.2	100
8	2.45E-06	6.7	100	*1 2.45E-06	7.1	100	2.46E-06	3.6	100	2.59E-06	4.2	100
9	4.03E-06	6.7	100	4.20E-06	7.0	100	4.16E-06	3.6	100	4.33E-06	4.2	100
10	5.11E-06	6.7	100	5.29E-06	7.0	100	5.51E-06	3.6	100	5.64E-06	4.2	100
11	3.11E-06	6.7	100	3.26E-06	7.0	100	3.13E-06	3.6	100	3.48E-06	4.2	100
12	2.47E-06	6.7	100	2.52E-06	7.0	100	2.47E-06	3.6	100	2.73E-06	4.2	100
13	4.46E-06	6.7	100	4.54E-06	7.0	100	4.60E-06	3.6	100	4.79E-06	4.2	100
14	3.07E-06	6.7	100	3.12E-06	7.0	100	3.17E-06	3.6	100	3.39E-06	4.2	100
15	*1 3.10E-06	6.7	100	3.14E-06	7.0	100	*1 3.26E-06	3.6	100	3.52E-06	4.2	100
16	3.00E-06	6.8	100	3.22E-06	7.0	100	3.41E-06	3.5	100	3.52E-06	4.2	100
17	4.95E-06	6.8	100	5.56E-06	7.0	100	5.76E-06	3.5	100	5.81E-06	4.2	100
18	2.48E-06	6.8	100	2.66E-06	7.0	100	2.83E-06	3.5	100	2.82E-06	4.2	100
19	3.72E-06	6.8	100	3.92E-06	7.0	100	4.28E-06	3.5	100	4.33E-06	4.2	100
20	4.06E-06	6.8	100	4.33E-06	7.0	100	4.57E-06	3.5	100	*1 4.66E-06	4.3	100
21	3.35E-06	6.8	100	3.65E-06	7.0	100	3.79E-06	3.5	100	3.63E-06	4.5	100
22	3.67E-06	6.8	100	4.02E-06	7.0	100	4.23E-06	3.5	100	4.07E-06	4.5	100
23	3.54E-06	6.8	100	3.95E-06	7.0	100	4.00E-06	3.5	100	3.90E-06	4.5	100
24	3.77E-06	6.8	100	4.08E-06	7.0	100	4.33E-06	3.5	100	4.25E-06	4.5	100
25	4.45E-06	6.8	100	4.96E-06	7.0	100	5.21E-06	3.5	100	4.99E-06	4.5	100
26	4.85E-06	6.8	100	5.33E-06	7.0	100	5.71E-06	3.5	100	5.44E-06	4.5	100
27	6.26E-06	6.8	100	6.85E-06	7.0	100	7.34E-06	3.5	100	7.14E-06	4.5	100
28	5.52E-06	6.8	100	6.01E-06	7.0	100	6.52E-06	3.5	100	6.22E-06	4.5	100
29												
30												
31												
1ヶ月値	3.95E-06	6.7	100	4.13E-06	7.0	100	4.32E-06	3.6	100	4.38E-06	4.3	100
*2 最大値	1.97E-05	6.8	104	1.18E-05	7.1	102	1.31E-05	3.6	102	1.38E-05	4.5	102
最大値日時	02/15 14:40	02/15 14:40	02/23 23:56	02/03 07:57	02/01 00:01	02/01 04:15	02/03 06:28	02/01 00:01	02/01 06:50	02/03 06:45	02/20 15:43	02/01 07:55
*2 最小値	0.00E+00	6.7	96	0.00E+00	7.0	97	0.00E+00	3.5	98	0.00E+00	4.2	97
最小値日時	02/09 16:22	02/01 00:01	02/22 05:57	02/08 15:36	02/08 15:34	02/14 01:33	02/09 15:42	02/15 14:49	02/01 08:01	02/09 15:57	02/01 00:01	02/14 04:24

*1: ろ紙交換

*2: 最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(4/7)

日	モニタ											
	A013			A014			A015			A016		
	4号南側法面上[3号南側](DM58)			4号南側法面上[3号南側](DM51)			登録S休憩所 (DM46)			登録S休憩所 (DM62)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.42E-06	1.4	100	4.62E-06	1.2	100	5.09E-06	2.7	100	4.78E-06	2.2	100
2	3.68E-06	1.4	100	3.84E-06	1.2	100	4.71E-06	2.7	100	4.37E-06	2.2	100
3	5.49E-06	1.4	100	5.68E-06	1.2	100	6.77E-06	2.7	100	6.24E-06	2.2	100
4	3.07E-06	1.4	100	3.15E-06	1.2	100	3.54E-06	2.7	100	3.30E-06	2.2	100
5	4.98E-06	1.4	100	5.19E-06	1.2	100	6.04E-06	2.7	100	5.56E-06	2.2	100
6	5.57E-06	1.4	100	5.76E-06	1.2	100	6.24E-06	2.7	100	5.95E-06	2.2	100
7	2.24E-06	1.4	100	2.39E-06	1.2	100	2.65E-06	2.7	100	2.45E-06	2.2	100
8	2.46E-06	1.4	100	2.60E-06	1.2	100	2.90E-06	2.7	100	2.71E-06	2.2	100
9	4.06E-06	1.4	100	4.23E-06	1.2	100	4.93E-06	2.7	100	4.55E-06	2.2	100
10	5.40E-06	1.4	100	5.67E-06	1.2	100	6.87E-06	2.7	100	6.30E-06	2.2	100
11	3.09E-06	1.4	100	3.28E-06	1.2	100	3.62E-06	2.7	100	3.36E-06	2.2	100
12	2.45E-06	1.4	100	2.61E-06	1.2	100	2.87E-06	2.7	100	2.76E-06	2.2	100
13	4.42E-06	1.4	100	4.77E-06	1.2	100	5.59E-06	2.7	100	5.13E-06	2.2	100
14	3.05E-06	1.4	100	3.28E-06	1.2	100	3.83E-06	2.7	100	3.52E-06	2.2	100
15	3.17E-06	1.4	100	3.36E-06	1.2	100	3.62E-06	2.7	100	3.42E-06	2.2	100
16	3.28E-06	1.4	100	3.47E-06	1.2	100	4.27E-06	2.7	100	4.15E-06	2.2	100
17	5.66E-06	1.4	100	6.04E-06	1.2	100	6.96E-06	2.7	100	6.63E-06	2.2	100
18	2.72E-06	1.4	100	2.86E-06	1.2	100	3.17E-06	2.7	100	2.99E-06	2.2	100
19	*1 3.96E-06	1.4	100	*1 4.24E-06	1.1	100	5.29E-06	2.7	100	5.00E-06	2.2	100
20	4.29E-06	1.3	100	4.77E-06	1.0	100	*1 5.46E-06	2.7	100	*1 5.25E-06	2.2	100
21	3.54E-06	1.3	100	3.99E-06	1.0	100	4.22E-06	2.7	100	4.23E-06	2.3	100
22	4.02E-06	1.3	100	4.43E-06	1.0	100	4.83E-06	2.7	100	4.78E-06	2.3	100
23	3.95E-06	1.3	100	4.33E-06	1.0	100	4.50E-06	2.7	100	4.55E-06	2.3	100
24	4.05E-06	1.3	100	4.40E-06	1.0	100	4.62E-06	2.7	100	4.67E-06	2.3	100
25	4.86E-06	1.3	100	5.33E-06	1.0	100	5.62E-06	2.7	100	5.66E-06	2.3	100
26	5.39E-06	1.3	100	5.87E-06	1.0	100	6.20E-06	2.7	100	6.26E-06	2.3	100
27	6.70E-06	1.3	100	7.24E-06	1.0	100	8.13E-06	2.7	100	8.39E-06	2.3	100
28	6.09E-06	1.3	100	6.57E-06	1.0	100	7.42E-06	2.7	100	7.54E-06	2.3	100
29												
30												
31												
1ヶ月値	4.15E-06	1.4	100	4.43E-06	1.1	100	5.00E-06	2.7	100	4.80E-06	2.2	100
*2 最大値	1.29E-05	1.4	103	1.35E-05	1.2	102	1.71E-05	2.7	102	1.66E-05	2.3	102
最大値日時	02/27 23:38	02/01 00:01	02/11 20:33	02/27 23:51	02/01 00:01	02/01 23:45	02/03 06:29	02/01 00:01	02/15 18:36	02/27 23:59	02/20 15:40	02/01 05:07
*2 最小値	0.00E+00	1.3	97	0.00E+00	1.0	97	0.00E+00	2.7	98	0.00E+00	2.2	98
最小値日時	02/07 15:37	02/19 14:45	02/05 00:25	02/07 16:01	02/19 14:28	02/10 02:11	02/20 16:10	02/01 00:01	02/01 08:26	02/06 15:59	02/01 00:01	02/01 00:31

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(5/7)

日	モニタ											
	A017			A018			A019			A020		
	旧情報棟(DM-77)			旧情報棟(DM-57)			シールド中央制御室(DM-53)			シールド中央制御室(DM-50)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	3.88E-06	7.4	100	3.93E-06	5.9	100	4.47E-06	3.4	100	4.59E-06	3.2	100
2	3.48E-06	7.4	100	3.51E-06	5.9	100	3.64E-06	3.4	100	3.82E-06	3.2	100
3	4.97E-06	7.4	100	5.02E-06	5.9	100	5.47E-06	3.4	100	5.72E-06	3.2	100
4	2.81E-06	7.4	100	2.81E-06	5.9	100	3.07E-06	3.4	100	3.12E-06	3.2	100
5	4.61E-06	7.4	100	4.68E-06	5.9	100	4.95E-06	3.4	100	5.23E-06	3.2	100
6	5.07E-06	7.4	100	5.14E-06	5.9	100	5.46E-06	3.4	100	5.70E-06	3.2	100
7	2.11E-06	7.4	100	2.17E-06	5.9	100	2.16E-06	3.4	100	2.24E-06	3.2	100
8	2.25E-06	7.4	100	2.33E-06	5.9	100	2.41E-06	3.4	100	*1 2.52E-06	3.2	100
9	3.75E-06	7.4	100	3.88E-06	5.9	100	4.06E-06	3.4	100	4.41E-06	3.2	100
10	5.22E-06	7.4	100	5.37E-06	5.9	100	5.49E-06	3.4	100	5.94E-06	3.2	100
11	2.90E-06	7.4	100	2.95E-06	5.9	100	3.07E-06	3.4	100	3.34E-06	3.2	100
12	2.29E-06	7.4	100	2.36E-06	5.9	100	2.48E-06	3.4	100	2.66E-06	3.2	100
13	4.13E-06	7.4	100	4.19E-06	5.9	100	4.48E-06	3.4	100	5.02E-06	3.2	100
14	*1 3.01E-06	7.1	100	2.92E-06	5.9	100	*1 3.10E-06	3.4	100	3.34E-06	3.2	100
15	3.25E-06	6.6	100	2.92E-06	5.9	100	3.32E-06	3.3	100	3.49E-06	3.2	100
16	3.54E-06	6.6	100	3.11E-06	5.9	100	3.48E-06	3.3	100	3.55E-06	3.2	100
17	5.85E-06	6.6	100	5.23E-06	5.9	100	6.01E-06	3.3	100	6.11E-06	3.2	100
18	2.91E-06	6.6	100	2.53E-06	5.9	100	2.82E-06	3.3	100	2.93E-06	3.2	100
19	4.51E-06	6.6	100	3.97E-06	5.9	100	4.24E-06	3.3	100	4.52E-06	3.2	100
20	4.55E-06	6.6	100	4.03E-06	5.9	100	4.55E-06	3.3	100	4.86E-06	3.2	100
21	3.81E-06	6.6	100	*1 3.51E-06	5.8	100	3.83E-06	3.3	100	4.15E-06	3.2	100
22	4.33E-06	6.6	100	3.93E-06	5.7	100	4.36E-06	3.3	100	4.61E-06	3.2	100
23	4.14E-06	6.6	100	3.76E-06	5.7	100	4.26E-06	3.3	100	4.21E-06	3.2	100
24	4.36E-06	6.6	100	4.01E-06	5.7	100	4.26E-06	3.3	100	4.53E-06	3.2	100
25	5.08E-06	6.6	100	4.72E-06	5.7	100	5.03E-06	3.3	100	5.49E-06	3.2	100
26	5.52E-06	6.6	100	5.23E-06	5.7	100	5.57E-06	3.3	100	6.19E-06	3.2	100
27	7.05E-06	6.6	100	6.70E-06	5.7	100	7.33E-06	3.3	100	7.47E-06	3.2	100
28	6.44E-06	6.6	100	6.12E-06	5.7	100	6.46E-06	3.3	100	6.98E-06	3.2	100
29												
30												
31												
1ヶ月値	4.14E-06	7.0	100	3.97E-06	5.8	100	4.28E-06	3.3	100	4.53E-06	3.2	100
*2 最大値	1.30E-05	7.4	102	1.68E-05	5.9	102	1.39E-05	3.4	102	1.41E-05	3.2	102
最大値日時	02/27 23:57	02/01 00:01	02/01 01:33	02/21 14:49	02/01 00:01	02/01 00:10	02/27 23:41	02/01 00:01	02/01 00:14	02/27 23:26	02/01 00:01	02/01 00:06
*2 最小値	0.00E+00	6.6	98	0.00E+00	5.7	97	0.00E+00	3.3	97	0.00E+00	3.2	98
最小値日時	02/15 15:45	02/14 15:22	02/01 00:33	02/15 16:02	02/21 14:49	02/09 06:34	02/09 15:01	02/14 14:52	02/01 22:02	02/08 15:29	02/01 00:01	02/01 01:54

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(6/7)

日	モニタ											
	A021			A022			A027			A028		
	Hタンクエリア (DM60)			Hタンクエリア (DM55)			1号機海側4m盤(DM-68)			1号機海側4m盤(DM-70)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.94E-06	2.4	100	4.12E-06	2.9	100	5.11E-06	3.9	100	4.72E-06	5.1	100
2	4.32E-06	2.4	100	3.58E-06	2.9	100	4.29E-06	3.9	100	3.94E-06	5.1	100
3	6.18E-06	2.4	100	5.27E-06	2.9	100	6.30E-06	3.9	100	5.95E-06	5.1	100
4	3.40E-06	2.4	100	2.81E-06	2.9	100	3.71E-06	3.9	100	3.44E-06	5.1	100
5	5.66E-06	2.4	100	4.73E-06	2.9	100	5.70E-06	3.9	100	5.47E-06	5.1	100
6	6.03E-06	2.4	100	5.12E-06	2.9	100	6.50E-06	3.9	100	6.10E-06	5.1	100
7	2.59E-06	2.4	100	2.03E-06	2.9	100	2.88E-06	3.9	100	2.61E-06	5.1	100
8	2.77E-06	2.4	100	*1 2.36E-06	2.8	100	3.06E-06	3.9	100	2.81E-06	5.1	100
9	4.70E-06	2.4	100	4.26E-06	2.7	100	4.92E-06	3.9	100	4.66E-06	5.1	100
10	6.06E-06	2.4	100	5.74E-06	2.7	100	6.31E-06	3.9	100	5.83E-06	5.1	100
11	3.55E-06	2.4	100	3.27E-06	2.7	100	3.99E-06	3.9	100	3.64E-06	5.1	100
12	2.86E-06	2.4	100	2.63E-06	2.7	100	3.13E-06	3.9	100	2.87E-06	5.1	100
13	5.19E-06	2.4	100	4.82E-06	2.7	100	5.32E-06	3.9	100	5.00E-06	5.1	100
14	3.66E-06	2.4	100	3.38E-06	2.7	100	3.66E-06	3.9	100	3.31E-06	5.1	100
15	3.61E-06	2.4	100	3.36E-06	2.7	100	3.92E-06	3.9	100	3.65E-06	5.1	100
16	3.93E-06	2.4	100	3.62E-06	2.7	100	3.80E-06	3.9	100	3.53E-06	5.1	100
17	6.38E-06	2.4	100	6.00E-06	2.7	100	6.13E-06	3.9	100	5.88E-06	5.1	100
18	3.12E-06	2.4	100	2.88E-06	2.7	100	3.29E-06	3.9	100	3.08E-06	5.1	100
19	4.78E-06	2.4	100	4.50E-06	2.7	100	4.88E-06	3.9	100	4.55E-06	5.1	100
20	*1 5.07E-06	2.5	100	4.67E-06	2.7	100	*1 5.03E-06	4.0	100	4.79E-06	5.1	100
21	4.10E-06	2.6	100	3.95E-06	2.7	100	3.93E-06	4.3	100	*1 4.03E-06	5.2	100
22	4.63E-06	2.6	100	4.49E-06	2.7	100	4.19E-06	4.3	100	4.24E-06	5.5	100
23	4.36E-06	2.6	100	4.23E-06	2.7	100	4.08E-06	4.3	100	4.12E-06	5.5	100
24	4.61E-06	2.6	100	4.37E-06	2.7	100	4.46E-06	4.3	100	4.44E-06	5.5	100
25	5.43E-06	2.6	100	5.18E-06	2.7	100	5.12E-06	4.3	100	5.08E-06	5.5	100
26	6.02E-06	2.6	100	5.89E-06	2.7	100	5.98E-06	4.3	100	5.90E-06	5.5	100
27	7.80E-06	2.6	100	7.44E-06	2.7	100	7.16E-06	4.3	100	7.19E-06	5.5	100
28	6.86E-06	2.6	100	6.55E-06	2.7	100	6.21E-06	4.3	100	6.20E-06	5.5	100
29												
30												
31												
1ヶ月値	4.74E-06	2.5	100	4.33E-06	2.8	100	4.75E-06	4.0	100	4.54E-06	5.2	100
*2 最大値	1.40E-05	2.6	102	1.31E-05	2.9	120	1.35E-05	4.3	102	1.37E-05	5.5	102
最大値日時	02/27 23:43	02/20 15:47	02/02 12:45	02/27 23:44	02/01 00:01	02/07 16:44	02/03 08:08	02/20 15:56	02/01 05:50	02/03 08:19	02/21 15:16	02/03 04:05
*2 最小値	0.00E+00	2.4	98	0.00E+00	2.7	99	0.00E+00	3.9	97	0.00E+00	5.1	98
最小値日時	02/07 16:30	02/01 00:01	02/02 08:02	02/07 16:45	02/08 15:38	02/01 00:02	02/14 15:35	02/01 00:01	02/01 01:39	02/14 15:54	02/01 00:01	02/01 05:45

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする

測定月報

測定日: 2018/02

(7/7)

日	モニタ											
	A029 3号機海側4m盤(DM-61)			A030 3号機海側4m盤(DM-66)			A031 HTI南側(DM-69)			A032 HTI南側(DM-73)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	4.92E-06	5.4	100	4.68E-06	5.7	100	4.72E-06	10.1	100	4.66E-06	9.3	100
2	4.27E-06	5.4	100	3.94E-06	5.7	100	3.99E-06	10.1	100	3.92E-06	9.3	100
3	6.26E-06	5.4	100	5.91E-06	5.7	100	6.35E-06	10.1	100	6.00E-06	9.3	100
4	3.59E-06	5.4	100	3.30E-06	5.7	100	3.54E-06	10.1	100	3.17E-06	9.3	100
5	5.66E-06	5.4	100	5.37E-06	5.7	100	5.79E-06	10.1	100	5.39E-06	9.3	100
6	6.37E-06	5.4	100	6.00E-06	5.7	100	6.29E-06	10.1	100	5.99E-06	9.3	100
7	2.70E-06	5.4	100	2.37E-06	5.7	100	2.76E-06	10.1	100	2.50E-06	9.3	100
8	2.96E-06	5.4	100	2.63E-06	5.7	100	2.97E-06	10.1	100	2.75E-06	9.3	100
9	4.79E-06	5.4	100	4.47E-06	5.7	100	4.81E-06	10.1	100	4.59E-06	9.3	100
10	5.94E-06	5.4	100	5.65E-06	5.7	100	6.35E-06	10.1	100	6.09E-06	9.3	100
11	3.83E-06	5.4	100	3.50E-06	5.7	100	3.73E-06	10.1	100	3.40E-06	9.3	100
12	3.02E-06	5.4	100	2.73E-06	5.7	100	2.92E-06	10.1	100	2.58E-06	9.3	100
13	5.19E-06	5.4	100	4.80E-06	5.7	100	5.20E-06	10.1	100	4.74E-06	9.3	100
14	3.50E-06	5.4	100	*1 3.30E-06	5.6	100	3.62E-06	10.1	100	*1 3.36E-06	9.2	100
15	3.80E-06	5.4	100	3.52E-06	5.5	100	3.65E-06	10.1	100	3.35E-06	9.0	100
16	3.73E-06	5.4	100	3.55E-06	5.5	100	3.71E-06	10.1	100	3.51E-06	9.0	100
17	5.76E-06	5.4	100	5.54E-06	5.5	100	6.32E-06	10.1	100	5.94E-06	9.0	100
18	3.15E-06	5.4	100	3.03E-06	5.5	100	3.10E-06	10.1	100	3.02E-06	9.0	100
19	4.56E-06	5.4	100	4.53E-06	5.5	100	*1 4.62E-06	10.1	100	4.44E-06	9.0	100
20	4.84E-06	5.4	100	4.86E-06	5.5	100	4.80E-06	10.2	100	4.83E-06	9.0	100
21	*1 4.12E-06	5.5	100	4.09E-06	5.5	100	3.96E-06	10.2	100	3.98E-06	9.0	100
22	4.36E-06	5.6	100	4.56E-06	5.5	100	4.47E-06	10.2	100	4.51E-06	9.0	100
23	4.03E-06	5.6	100	4.34E-06	5.5	100	4.31E-06	10.2	100	4.28E-06	9.0	100
24	4.54E-06	5.6	100	4.70E-06	5.5	100	4.49E-06	10.2	100	4.42E-06	9.0	100
25	5.21E-06	5.6	100	5.48E-06	5.5	100	5.36E-06	10.2	100	5.31E-06	9.0	100
26	5.72E-06	5.6	100	6.06E-06	5.5	100	5.98E-06	10.2	100	5.83E-06	9.0	100
27	7.16E-06	5.6	100	7.63E-06	5.5	100	7.42E-06	10.2	100	7.38E-06	9.0	100
28	6.03E-06	5.6	100	6.35E-06	5.5	100	6.88E-06	10.2	100	6.64E-06	9.0	100
29												
30												
31												
1ヶ月値	4.64E-06	5.5	100	4.53E-06	5.6	100	4.72E-06	10.1	100	4.52E-06	9.1	100
*1 最大値	1.34E-05	5.6	103	1.34E-05	5.7	103	1.47E-05	10.2	102	1.74E-05	9.3	108
最大値日時	02/03 08:16	02/21 15:07	02/02 02:33	02/27 23:56	02/01 00:01	02/21 22:32	02/03 06:43	02/19 14:37	02/04 01:27	02/14 15:00	02/01 00:01	02/15 15:16
*1 最小値	0.00E+00	5.4	97	0.00E+00	5.5	97	0.00E+00	10.1	98	0.00E+00	9.0	98
最小値日時	02/14 16:14	02/01 00:01	02/02 02:21	02/14 15:07	02/14 15:07	02/01 17:51	02/15 14:50	02/01 00:01	02/02 05:48	02/14 15:01	02/14 15:00	02/01 20:52

*1:ろ紙交換

*2:最大・最小値に関しては、1日1回BG測定による、影響があるため、値に関しては、参考値扱いとする