

| 承認 | 審査 | 作成 |
|---------|---------|---------|
| | | |
| H30.4.4 | H30.4.4 | H30.4.4 |

各建屋滞留水移送ライン近傍線量率データ(月報)

2018年 3月分

各建屋滞留水移送ライン近傍線量率データ（2018年3月分）

| 月日 | 2号T／B出口 (mSv/h) | 3号T／B入口 (mSv/h) | 4号T／B出口 (mSv/h) | HTI建屋入口 (mSv/h) | プロセス主建屋入口 (mSv/h) | 焼却工作建屋出口 (mSv/h) | 備考 |
|------|--------------------|--------------------|--------------------|--------------------|----------------------|---------------------|----|
| 3/1 | 1.04E+02 | 2.05E+02 | 3.16E+01 | 1.00E+02 | 1.67E+01 | 4.54E+01 | |
| 3/2 | 1.07E+02 | 2.05E+02 | 3.32E+01 | 1.02E+02 | 1.73E+01 | 4.48E+01 | |
| 3/3 | 1.10E+02 | 2.33E+02 | 3.61E+01 | 1.03E+02 | 2.03E+01 | 4.53E+01 | |
| 3/4 | 1.30E+02 | 8.23E+02 | 3.79E+01 | 1.04E+02 | 1.90E+01 | 4.57E+01 | |
| 3/5 | 1.07E+02 | 1.75E+02 | 3.10E+01 | 1.04E+02 | 1.58E+01 | 4.50E+01 | |
| 3/6 | 1.16E+02 | 3.12E+02 | 3.20E+01 | 1.05E+02 | 1.60E+01 | 4.53E+01 | |
| 3/7 | 1.04E+02 | 2.48E+02 | 3.26E+01 | 1.04E+02 | 1.88E+01 | 4.56E+01 | |
| 3/8 | 1.03E+02 | 1.66E+02 | 2.22E+01 | 5.95E+01 | 1.39E+01 | 2.75E+01 | |
| 3/9 | 1.02E+02 | 1.55E+02 | 2.10E+01 | 5.28E+01 | 1.34E+01 | 2.64E+01 | |
| 3/10 | 1.08E+02 | 2.40E+02 | 2.60E+01 | 9.41E+01 | 1.79E+01 | 4.33E+01 | |
| 3/11 | 1.21E+02 | 6.22E+02 | 3.21E+01 | 6.42E+01 | 1.75E+01 | 3.42E+01 | |
| 3/12 | 1.04E+02 | 1.62E+02 | 2.41E+01 | 8.66E+01 | 1.68E+01 | 3.90E+01 | |
| 3/13 | 1.04E+02 | 1.79E+02 | 2.56E+01 | 9.70E+01 | 1.80E+01 | 4.40E+01 | |
| 3/14 | 1.09E+02 | 1.82E+02 | 2.65E+01 | 8.52E+01 | 1.72E+01 | 3.81E+01 | |
| 3/15 | 1.18E+02 | 4.61E+02 | 2.70E+01 | 9.74E+01 | 1.83E+01 | 4.63E+01 | |
| 3/16 | 1.15E+02 | 4.56E+02 | 2.43E+01 | 5.67E+01 | 1.48E+01 | 2.93E+01 | |
| 3/17 | 1.19E+02 | 4.57E+02 | 2.54E+01 | 6.86E+01 | 1.59E+01 | 3.36E+01 | |
| 3/18 | 1.14E+02 | 3.50E+02 | 3.07E+01 | 7.10E+01 | 1.80E+01 | 3.79E+01 | |
| 3/19 | 1.19E+02 | 4.78E+02 | 2.67E+01 | 9.14E+01 | 1.83E+01 | 4.31E+01 | |
| 3/20 | 1.19E+02 | 4.60E+02 | 2.50E+01 | 7.87E+01 | 1.67E+01 | 3.74E+01 | |
| 3/21 | 1.09E+02 | 2.32E+02 | 2.69E+01 | 8.36E+01 | 1.75E+01 | 4.13E+01 | |
| 3/22 | 1.04E+02 | 1.95E+02 | 2.58E+01 | 6.15E+01 | 1.61E+01 | 3.53E+01 | |
| 3/23 | 1.04E+02 | 1.59E+02 | 2.57E+01 | 7.43E+01 | 1.62E+01 | 3.85E+01 | |
| 3/24 | 1.12E+02 | 3.86E+02 | 2.74E+01 | 7.43E+01 | 1.68E+01 | 3.88E+01 | |
| 3/25 | 1.11E+02 | 2.97E+02 | 2.80E+01 | 6.84E+01 | 1.62E+01 | 3.46E+01 | |
| 3/26 | 1.08E+02 | 1.81E+02 | 2.67E+01 | 8.90E+01 | 1.76E+01 | 4.05E+01 | |
| 3/27 | 1.13E+02 | 2.80E+02 | 2.64E+01 | 7.93E+01 | 1.67E+01 | 3.85E+01 | |
| 3/28 | 1.18E+02 | 4.42E+02 | 2.59E+01 | 7.18E+01 | 1.58E+01 | 3.44E+01 | |
| 3/29 | 1.18E+02 | 4.35E+02 | 2.59E+01 | 7.96E+01 | 1.68E+01 | 3.82E+01 | |
| 3/30 | 1.10E+02 | 2.42E+02 | 2.67E+01 | 7.84E+01 | 1.67E+01 | 3.77E+01 | |
| 3/31 | 1.07E+02 | 3.04E+02 | 2.54E+01 | 6.91E+01 | 1.58E+01 | 3.33E+01 | |