

水処理運転管理部 水処理運営G

承認	審査	作成
H30.7.3	H30.7.3	H30.7.3

各建屋滞留水移送ライン近傍線量率データ(月報)

2018年 6月分

各建屋滞留水移送ライン近傍線量率データ（2018年6月分）

月日	2号T／B出口 (mSv／h)	3号T／B入口 (mSv／h)	4号T／B出口 (mSv／h)	HTI建屋入口 (mSv／h)	プロセス主建屋入口 (mSv／h)	焼却工作建屋出口 (mSv／h)	備考
6/1	1.15E+02	4.00E+02	2.65E+01	7.92E+01	1.44E+01	3.88E+01	
6/2	1.22E+02	4.67E+02	1.99E+01	4.82E+01	1.15E+01	2.47E+01	
6/3	1.16E+02	3.61E+02	2.83E+01	7.06E+01	1.75E+01	4.16E+01	
6/4	1.12E+02	2.14E+02	2.00E+01	4.95E+01	1.13E+01	2.49E+01	
6/5	1.08E+02	2.15E+02	1.96E+01	4.75E+01	1.11E+01	2.44E+01	
6/6	1.11E+02	2.10E+02	2.64E+01	4.50E+01	1.11E+01	2.38E+01	
6/7	1.10E+02	2.17E+02	2.00E+01	4.76E+01	1.12E+01	2.45E+01	
6/8	1.16E+02	4.05E+02	2.32E+01	5.73E+01	1.42E+01	3.08E+01	
6/9	1.13E+02	2.30E+02	2.12E+01	4.96E+01	1.19E+01	2.56E+01	
6/10	1.26E+02	8.13E+02	2.90E+01	4.46E+01	1.29E+01	2.51E+01	
6/11	1.15E+02	4.99E+02	6.17E+01	1.51E+02	3.22E+01	8.75E+01	
6/12	1.09E+02	2.83E+02	2.93E+01	9.86E+01	2.52E+01	4.90E+01	
6/13	1.08E+02	2.95E+02	2.97E+01	6.65E+01	1.76E+01	3.48E+01	
6/14	1.23E+02	5.99E+02	2.71E+01	5.78E+01	1.51E+01	3.01E+01	
6/15	1.11E+02	2.41E+02	1.29E+02	2.39E+02	5.93E+01	1.40E+02	
6/16	1.02E+02	2.23E+02	2.27E+01	5.27E+01	1.58E+01	2.96E+01	
6/17	1.07E+02	2.89E+02	2.31E+01	5.53E+01	1.45E+01	2.86E+01	
6/18	1.23E+02	7.70E+02	3.57E+01	5.95E+01	1.36E+01	3.54E+01	
6/19	1.10E+02	4.35E+02	3.96E+01	6.36E+01	2.03E+01	3.75E+01	
6/20	1.05E+02	3.48E+02	4.31E+01	6.18E+01	1.98E+01	3.72E+01	
6/21	1.25E+02	8.94E+02	5.18E+01	6.28E+01	2.53E+01	3.75E+01	
6/22	1.08E+02	2.75E+02	4.68E+01	6.37E+01	2.09E+01	3.78E+01	
6/23	1.08E+02	2.14E+02	3.56E+01	6.35E+01	1.76E+01	3.75E+01	
6/24	1.24E+02	6.34E+02	3.74E+01	6.38E+01	2.03E+01	3.77E+01	
6/25	1.12E+02	2.88E+02	3.75E+01	6.39E+01	1.85E+01	3.75E+01	
6/26	1.11E+02	2.86E+02	7.60E+01	6.37E+01	4.53E+01	3.73E+01	
6/27	1.16E+02	4.58E+02	8.24E+01	5.37E+01	6.34E+01	3.73E+01	
6/28	1.09E+02	2.20E+02	3.55E+01	6.29E+01	1.77E+01	3.74E+01	
6/29	1.24E+02	5.41E+02	3.85E+01	6.38E+01	1.96E+01	3.73E+01	
6/30	1.08E+02	2.59E+02	3.98E+01	6.36E+01	2.17E+01	3.74E+01	