

測定月報

測定日: 2019/04

(1/11)

日	モニタ									
	B001	B002	B003	B004	B005	B006	B007	B008	B009	B010
	入退域管理棟周辺 線量率 (μ Sv/h)	正門警備所周辺 線量率 (μ Sv/h)	環境管理棟周辺 線量率 (μ Sv/h)	車両スクリーニング場周辺 線量率 (μ Sv/h)	厚生棟休憩所周辺 線量率 (μ Sv/h)	登録センター休憩所周辺 線量率 (μ Sv/h)	5、6号機サービス建屋休憩所周辺 線量率 (μ Sv/h)	シールド中央制御室周辺 線量率 (μ Sv/h)	免震重要棟周辺 線量率 (μ Sv/h)	5、6号機防護本部周辺 線量率 (μ Sv/h)
1	0.201	0.476	1.685	0.457	0.571	1.379	※(2.169	5.689	1.360
2	0.200	0.484	1.676	0.456	0.568	1.378		2.174	5.790	1.364
3	0.198	0.476	1.675	0.456	0.567	1.388		2.171	5.797	1.374
4	0.204	0.488	1.686	0.462	0.574	1.393		2.219	5.758	1.399
5	0.208	0.506	1.701	0.467	0.582	1.402		2.255	5.802	1.428
6	0.210	0.505	1.697	0.465	0.581	1.403		2.240	5.780	1.426
7	0.207	0.507	1.694	0.466	0.581	1.408		2.242	5.760	1.421
8	0.205	0.498	1.694	0.465	0.580	1.394		2.221	5.720	1.415
9	0.205	0.499	1.689	0.464	0.577	1.390		2.216	5.719	1.414
10	0.199	0.475	1.645	0.452	0.561	1.360		2.162	5.590	1.363
11	0.194	0.456	1.601	0.437	0.529	1.337		2.087	5.466	1.297
12	0.201	0.478	1.674	0.455	0.563	1.373		2.181	5.707	1.362
13	0.203	0.484	1.683	0.458	0.568	1.393		2.200	5.795	1.376
14	0.205	0.495	1.690	0.461	0.571	1.399		2.214	5.830	1.397
15	0.202	0.488	1.680	0.461	0.572	1.391		2.196	5.765	1.380
16	0.203	0.496	1.694	0.458	0.573	1.388		2.210	5.720	1.393
17	0.207	0.498	1.692	0.459	0.580	1.393		2.232	5.717	1.403
18	0.204	0.501	1.695	0.461	0.580	1.403		2.261	5.764	1.413
19	0.209	0.504	1.701	0.465	0.578	1.394		2.273	5.812	1.426
20	0.207	0.489	1.691	0.460	0.576	1.398		2.242	5.713	1.416
21	0.207	0.483	1.696	0.461	0.578	1.395		2.255	5.741	1.418
22	0.207	0.492	1.699	0.464	0.582	1.398		2.268	5.776	1.432
23	0.204	0.503	1.694	0.463	0.579	1.398		2.274	5.750	1.430
24	0.205	0.503	1.702	0.464	0.581	1.396		2.284	5.792	1.440
25	0.207	0.498	1.687	0.466	0.580	1.440		2.272	5.809	1.416
26	0.203	0.488	1.653	0.454	0.563	1.418		2.197	5.644	1.339
27	0.202	0.478	1.658	0.446	0.562	1.373		2.186	5.638	1.340
28	0.203	0.462	1.678	0.453	0.566	1.387		2.221	5.696	1.367
29	0.203	0.464	1.683	0.457	0.572	1.392		2.243	5.740	1.390
30	0.203	0.457	1.662	0.452	0.563	1.379		2.210	5.699	1.354
31										
1ヶ月値	0.204	0.488	1.682	0.459	0.572	1.391		2.219	5.733	1.392
最大値	0.243	0.562	1.807	0.596	0.635	1.606		2.375	5.987	1.521
最大値日時	04/15 15:30	04/19 07:10	04/08 16:30	04/25 09:50	04/05 18:30	04/25 13:20		04/23 19:20	04/25 13:30	04/05 17:10
最小値	0.161	0.378	1.405	0.368	0.449	1.233		1.857	5.024	1.133
最小値日時	04/11 06:40	04/11 04:40	04/11 05:10	04/11 04:10	04/11 04:10	04/11 01:50		04/11 04:00	04/11 04:30	04/11 05:30

*1:線量表示器の故障に伴う欠測

測定月報

測定日: 2019/04

(2/11)

日	モニタ									
	B011	B012	B013	B014	B015	B016	B017	B018	B019	B020
	1号機北側法面上周辺	1、2号機西側法面上周辺	3、4号機西側法面上周辺	4号機南側法面上周辺	一般焼却炉周辺	車両整備場周辺	多核種除去施設周辺	キャスク仮保管施設周辺	野島の森五差路周辺	5、6号機西側周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	42.814	37.744	9.407	1.088	17.267	0.730	*	*	*	*
2	42.457	37.566	9.319	1.075	17.235	0.846	0.628	0.256	2.038	1.733
3	42.643	37.652	9.338	1.073	17.286	0.810	0.608	0.256	2.072	1.740
4	43.466	38.429	9.632	1.105	17.392	0.720	0.613	0.263	2.182	1.771
5	44.422	39.122	9.993	1.144	17.571	0.761	0.630	0.271	2.320	1.812
6	44.414	39.119	9.892	1.133	17.718	0.784	0.630	0.270	2.277	1.813
7	44.167	38.948	9.820	1.127	17.733	0.786	0.627	0.267	2.257	1.816
8	43.694	38.398	9.600	1.110	17.608	0.782	0.619	0.264	2.193	1.800
9	43.733	38.510	9.668	1.102	17.638	0.799	0.637	0.263	2.194	1.803
10	42.299	37.440	9.299	1.051	16.977	0.771	0.613	0.257	2.093	1.725
11	41.309	36.579	9.199	1.017	15.773	0.723	0.564	0.244	2.054	1.605
12	42.888	38.006	9.477	1.070	17.220	0.744	0.600	0.257	2.146	1.719
13	43.285	38.228	9.538	1.084	17.435	0.734	0.606	0.258	2.164	1.741
14	43.596	38.650	9.725	1.099	17.530	0.743	0.613	0.263	2.231	1.766
15	43.714	38.906	9.835	1.101	17.216	0.789	0.611	0.266	2.276	1.750
16	43.741	38.719	9.694	1.096	17.423	0.984	0.627	0.266	2.227	1.760
17	43.937	38.895	9.798	1.104	17.491	1.131	0.629	0.268	2.268	1.776
18	44.298	39.096	9.928	1.122	17.548	1.110	0.655	0.269	2.309	1.787
19	44.703	39.604	10.063	1.134	17.638	1.116	0.639	0.275	2.354	1.814
20	43.981	38.835	9.721	1.103	17.728	1.109	0.621	0.267	2.223	1.789
21	44.054	39.030	9.819	1.105	17.743	1.106	0.624	0.269	2.261	1.796
22	44.738	39.471	9.979	1.123	17.747	1.118	0.637	0.273	2.321	1.809
23	44.467	39.333	9.889	1.117	17.758	0.929	0.642	0.270	2.289	1.807
24	44.647	39.634	10.071	1.128	17.777	0.805	0.648	0.274	2.368	1.825
25	44.224	39.662	10.129	1.129	17.581	0.861	0.641	0.280	2.396	1.795
26	42.493	38.091	9.535	1.053	17.043	0.872	0.610	0.266	2.174	1.699
27	42.239	37.891	9.458	1.040	17.102	0.855	0.602	0.260	2.148	1.685
28	42.928	38.397	9.571	1.063	17.378	0.865	0.612	0.263	2.179	1.721
29	43.544	38.904	9.739	1.084	17.546	0.873	0.620	0.267	2.244	1.754
30	42.839	38.565	9.717	1.066	17.104	0.860	0.604	0.267	2.249	1.700
31										
1ヶ月値	43.525	38.581	9.695	1.095	17.407	0.871	0.621	0.265	2.228	1.763
最大値	46.385	40.720	10.527	1.221	18.144	1.273	0.712	0.410	2.543	1.901
最大値日時	04/22 15:40	04/25 15:30	04/19 12:10	04/05 17:50	04/24 15:00	04/17 09:30	04/18 15:50	04/02 12:10	04/25 15:10	04/19 17:30
最小値	38.142	33.225	8.531	0.898	13.656	0.550	0.475	0.195	1.860	1.378
最小値日時	04/11 03:40	04/11 04:20	04/11 03:40	04/11 04:10	04/11 04:40	04/16 10:40	04/11 04:10	04/11 05:20	04/11 04:10	04/11 04:10

*1:線量表示器の点検・校正に伴う欠測

測定月報

測定日: 2019/04

(3/11)

日	モニタ									
	B021 西門周辺	B022 さくら通り正門側	B023 増設多核種除去設備西側周辺 <small>11号シールド内(高圧ボイラールーム)</small>	B024 増設多核種除去設備東側周辺 <small>11号シールド内(高圧ボイラールーム)</small>	B025 1、2号機海側(4m盤)	B026 3、4号機海側(4m盤)	B027 固体廃棄物貯蔵庫管理棟周辺	B028 高性能多核種除去設備周辺	B029 サブドレン浄化設備周辺	B030 給油所周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	*1	*1	*1	*1	*2	*2	*1	*1	*1	*1
2										
3										
4										
5										
6										
7										
8										
9	1.322	0.849	0.398	4.877						
10	1.299	0.831	0.394	4.729						
11	1.254	0.805	0.385	4.512						
12	1.299	0.832	0.393	4.746						
13	1.304	0.834	0.396	4.785						
14	1.314	0.839	0.402	4.815						
15	1.310	0.839	0.409	4.790						
16	1.318	0.844	0.398	4.822						
17	1.324	0.847	0.407	4.851			1193.980	65.206		
18	1.323	0.856	0.410	4.876			1195.910	63.976		
19	1.330	0.859	0.415	4.901			1200.560	64.855		
20	1.327	0.852	0.399	4.879			1206.008	66.149		
21	1.328	0.855	0.404	4.891			1202.437	65.937		
22	1.332	0.863	0.412	4.919			1203.651	66.051		
23	1.327	0.868	0.407	4.921			1208.240	66.516		
24	1.348	0.876	0.420	4.934			1208.412	66.539	0.279	0.397
25	1.337	0.882	0.423	4.873			1210.448	66.769	0.287	0.400
26	1.285	0.858	0.403	4.751			1205.644	66.575	0.286	0.398
27	1.294	0.852	0.397	4.738			1189.507	64.927	0.283	0.378
28	1.307	0.862	0.400	4.789			1188.124	64.630	0.274	0.368
29	1.322	0.871	0.402	4.833			1197.349	65.465	0.275	0.370
30	1.263	0.855	0.407	4.756			1204.874	66.059	0.276	0.375
31							1193.720	64.698	0.273	0.368
1ヶ月値	1.312	0.851	0.404	4.816			1200.803	65.637	0.279	0.381
最大値	1.421	0.944	0.490	5.057			1219.307	68.251	0.478	0.488
最大値日時	04/25 02:10	04/25 10:50	04/19 11:10	04/24 10:40			04/22 16:20	04/25 16:20	04/24 14:10	04/23 11:20
最小値	0.737	0.708	0.336	4.016			978.774	39.742	0.241	0.326
最小値日時	04/09 10:40	04/11 04:30	04/11 05:20	04/11 03:50			04/16 11:20	04/18 07:20	04/25 15:40	04/30 11:50

*1:線量表示器の点検・校正に伴う欠測

*2:線量表示器の故障に伴う欠測

測定月報

測定日: 2019/04

(4/11)

日	モニタ									
	B031	B032	B033	B034	B035	B036	B037	B038	B039	B040
	HIC保管エリア周辺	H8タンクエリア周辺	H4タンクエリア周辺	H5タンクエリア周辺	J2タンクエリア周辺	1、2号機S/B周辺	タンク周辺	2号機R/B西側	1号機R/B西側	1号機R/B北側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.413	0.675	1.986	0.636	1.637	2.137	0.527	*4 1183.509	62.854	*2
2	0.409	0.648	1.984	0.632	1.581	2.133	0.524	1181.103	63.328	
3	*1	*1	*1	*1	1.549	2.144	0.528	1182.560	63.025	
4					1.545	2.171	0.541	1189.555	64.415	
5					1.550	2.209	0.559	1195.853	65.527	
6					1.528	2.220	0.557	1195.482	65.625	
7					1.517	2.217	0.552	1194.279	65.386	
8					1.496	2.207	0.541	1190.172	64.705	
9					1.492	2.203	0.542	1189.238	64.874	
10					*1	*1	*1	1179.328	63.330	
11					*3 0.246	*3 0.248	*3 0.283	1169.589	62.179	
12								1180.375	62.063	
13								1184.595	63.560	
14								1186.970	64.634	
15								1185.492	64.980	
16								1186.502	64.040	
17								*1	*1	
18								*3 0.232	*3 0.287	
19										
20										
21										
22										
23										
24										
25										
26										
27										
28										
29										
30										
31										
1ヶ月値	0.412	0.667	1.985	0.635	1.546	2.180	0.541	1185.360	64.004	
最大値	0.441	0.743	2.083	0.714	1.722	2.325	0.608	1205.650	70.038	
最大値日時	04/01 09:00	04/01 02:20	04/02 10:00	04/01 12:40	04/01 07:50	04/06 16:50	04/05 15:50	04/05 17:30	04/04 09:00	
最小値	0.368	0.613	1.885	0.594	0.246	0.248	0.283	0.232	0.287	
最小値日時	04/01 07:20	04/02 05:10	04/02 00:50	04/01 01:10	04/11 11:30	04/11 11:30	04/11 11:30	04/18 11:20	04/18 11:20	

*1:線量表示器の点検・校正に伴う欠測

*2:線量表示器の故障に伴う欠測

*3:線量表示器の点検・校正に伴う測定値

*4:2018年12月20日からB038をB087の代替機として配備

測定月報

測定日：2019/04

(5/11)

日	モニタ									
	B041	B042	B043	B044	B045	B046	B047	B048	B049	B050
	集中RW西側法面上	大型メンテナンス建屋 東側	大熊通り中央付近	1～4号機PPゲート前	1、2号機S/B周辺	3、4号機S/B周辺	集中RW東側	集中RW南側(PSFモニタ近傍)	共用プール西側	4号機R/B西側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	2.969	3.824	2.881	17.807	35.470	68.485	6.415	9.210	28.508	8.268
2	2.947	3.863	2.883	17.659	35.262	68.445	6.466	9.241	28.525	8.207
3	2.954	3.874	2.894	17.627	35.379	68.978	6.643	9.252	28.696	8.249
4	3.040	3.872	2.944	18.090	35.974	70.326	6.632	9.381	28.959	8.412
5	3.155	3.942	3.006	18.558	36.508	71.964	6.675	9.469	29.323	8.595
6	3.120	3.911	2.997	18.524	36.705	72.608	6.727	9.488	29.354	8.561
7	3.105	3.879	2.987	18.512	36.612	72.675	6.582	9.476	29.364	8.558
8	3.042	3.892	2.960	18.358	36.215	72.100	6.970	9.481	29.220	8.446
9	3.042	3.972	2.962	18.357	36.227	72.060	7.234	9.514	29.227	8.440
10	*1	3.972	2.872	17.631	35.210	69.734	7.120	9.087	27.990	8.162
11	*2 0.261	3.932	2.757	17.327	34.057	62.869	6.892	8.613	26.735	7.917
12		3.908	2.863	17.778	35.169	64.297	6.832	9.151	28.308	8.223
13		3.811	2.887	17.927	35.597	65.163	6.986	9.299	28.593	8.321
14		3.840	2.926	18.206	35.822	65.697	7.002	9.377	28.780	8.405
15		3.870	2.914	18.312	35.729	64.221	6.657	9.161	28.304	8.363
16		3.824	2.928	18.119	35.745	64.793	6.788	9.180	28.749	8.368
17		*1	2.945	18.189	35.809	65.045	6.498	8.879	28.858	8.427
18			2.971	18.362	35.995	65.311	6.524	9.151	29.042	8.531
19			2.997	18.612	36.291	65.881	6.687	9.437	29.207	8.588
20			2.952	18.195	36.041	66.142	6.516	9.411	29.043	8.455
21			2.968	18.306	36.085	66.504	6.480	9.415	29.107	8.478
22			2.998	18.615	36.468	66.727	6.467	9.486	29.246	8.568
23			2.989	18.695	36.445	67.199	6.258	9.427	29.215	8.549
24			3.008	18.813	36.536	67.348	6.194	9.306	29.267	8.604
25			2.988	18.402	36.032	66.438	6.287	9.195	28.749	8.552
26			2.850	17.580	34.725	62.971	6.395	8.864	27.414	8.190
27			2.831	17.432	34.487	61.536	6.141	9.007	27.475	8.151
28			2.860	17.689	35.141	62.681	6.291	9.261	28.189	8.304
29			2.910	17.988	35.593	63.457	6.291	9.390	28.580	8.406
30			2.868	17.756	34.871	61.045	6.310	8.985	27.549	8.264
31										
1ヶ月値	3.039	3.889	2.927	18.114	35.740	66.757	6.599	9.253	28.652	8.385
最大値	3.311	4.207	3.126	22.371	37.738	74.036	8.832	9.978	29.880	8.880
最大値日時	04/05 08:40	04/12 03:30	04/07 17:30	04/09 19:00	04/22 14:10	04/06 15:10	04/10 12:00	04/09 10:30	04/05 17:00	04/05 17:40
最小値	0.261	3.433	2.513	15.918	32.290	59.919	5.829	5.946	23.664	7.192
最小値日時	04/11 11:30	04/05 10:40	04/11 04:30	04/11 09:10	04/11 04:10	04/30 09:50	04/27 19:10	04/17 14:10	04/11 03:40	04/11 04:10

*1:線量表示器の点検・校正に伴う欠測

*2:線量表示器の点検・校正に伴う測定値

測定月報

測定日: 2019/04

(6/11)

日	モニタ									
	B051 3号機R/B西側	B052 2号機R/B西側	B053 1号機R/B西側	B054 1号機R/B北側	B055 物揚場周辺	B056 固体庫1, 2棟周辺	B057 旧事務本館北側	B058 固体庫第9棟建設地周辺	B059 危険物屋外貯蔵所周辺	B060 56号機
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	111.013	*1 49.405	64.005	49.016	4.978	4.310	9.398	0.414	1.814	1.973
2	110.362	49.510	66.013	49.098	5.003	4.290	9.339	0.411	1.817	1.995
3	106.866	49.884	65.837	49.473	5.070	4.319	9.358	0.415	1.830	2.012
4	108.324	50.732	66.883	50.295	5.207	4.416	9.558	0.420	1.853	2.041
5	109.383	46.314	67.676	46.895	5.253	4.536	9.783	0.429	1.881	2.076
6	109.685	42.226	67.781	43.594	5.161	4.508	9.735	0.426	1.886	2.077
7	109.584	42.072	67.501	43.347	5.119	4.497	9.675	0.431	1.882	2.079
8	108.412	40.072	66.744	41.033	5.011	4.441	9.529	0.426	1.877	2.072
9	108.576	38.757	67.074	39.411	5.016	4.445	9.519	0.425	1.880	2.079
10	105.945	37.369	65.451	37.967	4.880	4.251	9.135	0.415	1.799	1.935
11	103.014	36.140	64.297	36.947	4.656	3.995	8.828	0.387	1.623	1.747
12	105.614	36.458	63.863	37.357	4.870	4.259	9.267	0.408	1.790	1.959
13	107.063	36.175	65.050	37.212	4.904	4.306	9.367	0.416	1.811	1.988
14	108.275	36.421	66.686	37.419	5.014	4.374	9.475	0.418	1.832	2.016
15	107.082	36.334	67.004	37.408	5.030	4.370	9.472	0.414	1.808	1.909
16	106.839	36.355	66.605	37.396	4.991	4.373	9.431	0.417	1.830	1.991
17	107.761	36.618	65.232	37.663	5.046	4.409	9.523	0.420	1.843	2.012
18	108.106	36.983	65.963	38.075	5.106	4.449	9.578	0.422	1.857	2.036
19	108.703	37.302	67.097	38.500	5.173	4.500	9.679	0.423	1.870	2.050
20	108.165	36.647	67.012	37.842	5.033	4.403	9.444	0.422	1.864	2.050
21	108.358	36.772	66.935	37.980	5.073	4.437	9.520	0.425	1.868	2.059
22	108.514	37.203	67.134	38.428	5.134	4.492	9.577	0.428	1.880	2.080
23	108.453	37.035	67.329	38.258	5.085	4.463	9.505	0.427	1.887	2.078
24	108.896	37.208	67.485	38.429	5.179	4.502	9.623	0.428	1.888	2.085
25	108.031	36.944	67.114	38.203	5.128	4.465	9.618	0.427	1.859	1.998
26	105.616	35.393	65.526	36.592	4.807	4.195	9.111	0.410	1.766	1.801
27	105.429	35.210	65.202	36.398	4.793	4.162	9.087	0.402	1.753	1.854
28	106.622	35.729	65.988	36.917	4.874	4.248	9.244	0.410	1.787	1.954
29	107.551	36.213	66.624	37.454	4.991	4.325	9.401	0.417	1.817	1.996
30	106.234	35.671	65.340	36.920	4.893	4.237	9.254	0.409	1.764	1.820
31										
1ヶ月値	107.749	39.172	66.282	40.051	5.016	4.366	9.434	0.418	1.831	1.994
最大値	112.247	52.397	73.915	51.613	5.465	4.721	10.220	0.476	1.971	2.181
最大値日時	04/02 12:40	04/05 09:10	04/04 09:00	04/05 09:10	04/05 07:20	04/05 17:00	04/22 16:30	04/26 08:30	04/24 14:10	04/09 11:50
最小値	94.014	33.665	45.166	34.609	4.167	3.500	7.891	0.336	1.324	1.467
最小値日時	04/08 10:40	04/11 03:30	04/18 07:20	04/11 04:30	04/11 04:20	04/11 04:00	04/11 04:30	04/11 03:50	04/11 05:20	04/11 05:20

*1: 2019年2月8日からB052をB040の代替機として配備

測定月報

測定日: 2019/04

(7/11)

日	モニタ									
	B061	B062	B063	B064	B065	B066	B067	B068	B069	B070
	5、6号機放水口周辺	焼却設備建屋周辺	Fタンクエリア周辺	ヤード P1東側周辺	焼却設備建屋前道路カーブ側	資材置場	一時保管エリアC周辺	ALPS連ダ周辺	一時保管エリアH1周辺	土捨場資材置場
	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)
1	0.712	1.659	29.316	11.261	2.444	3.175	1.393	0.340	3.000	0.521
2	0.712	1.652	28.663	11.245	2.442	3.160	1.391	0.338	3.009	0.520
3	0.714	1.659	28.418	11.275	2.443	3.171	1.397	0.341	3.034	0.525
4	0.724	1.684	28.533	11.336	2.475	3.196	1.419	0.351	3.069	0.532
5	0.741	1.710	28.666	11.388	2.501	3.223	1.441	0.363	3.052	0.542
6	0.740	1.707	28.683	11.406	2.513	3.231	1.443	0.361	3.040	0.544
7	0.742	1.706	28.631	11.406	2.501	3.227	1.440	0.358	3.046	0.539
8	0.734	1.695	28.572	11.384	2.497	3.213	1.432	0.355	3.031	0.536
9	0.738	1.689	28.577	11.383	2.500	3.212	1.439	0.351	3.036	0.539
10	0.714	1.640	28.332	11.211	2.410	3.111	1.383	0.339	2.913	0.525
11	0.671	1.564	27.950	10.924	2.285	2.909	1.271	0.323	2.610	0.485
12	0.701	1.647	28.435	11.213	2.421	3.112	1.374	0.339	2.859	0.524
13	0.711	1.664	28.526	11.276	2.446	3.115	1.390	0.340	2.908	0.532
14	0.717	1.678	28.550	11.297	2.463	3.138	1.402	0.346	2.944	0.538
15	0.710	1.668	28.533	11.260	2.445	3.149	1.395	0.349	2.900	0.536
16	0.715	1.677	28.573	11.325	2.463	3.198	1.408	0.345	3.099	0.538
17	0.719	1.683	28.587	11.331	2.469	3.191	1.418	0.347	3.249	0.541
18	0.724	1.692	28.647	11.335	2.485	3.193	1.440	0.351	3.273	0.546
19	0.737	1.704	29.257	11.395	2.508	3.202	1.450	0.354	3.292	0.551
20	0.735	1.687	29.547	11.374	2.489	3.186	1.448	0.345	3.297	0.544
21	0.738	1.690	29.528	11.353	2.499	3.198	1.438	0.349	3.306	0.546
22	0.744	1.703	29.624	11.412	2.510	3.169	1.454	0.353	3.308	0.552
23	0.746	1.706	29.623	11.413	2.509	3.190	1.462	0.354	3.316	0.551
24	0.749	1.711	29.613	11.398	2.512	3.218	1.475	0.363	3.318	0.552
25	0.736	1.700	29.600	11.359	2.486	3.156	1.454	0.368	3.262	0.549
26	0.703	1.643	29.313	11.174	2.406	3.078	1.383	0.350	3.090	0.520
27	0.696	1.630	29.259	11.138	2.397	3.055	1.371	0.339	3.061	0.513
28	0.708	1.658	29.417	11.256	2.434	3.112	1.396	0.342	3.130	0.525
29	0.717	1.672	29.495	11.305	2.458	3.150	1.416	0.346	3.187	0.535
30	0.700	1.644	29.384	11.188	2.419	3.078	1.382	0.343	3.077	0.520
31										
1ヶ月値	0.722	1.674	28.928	11.301	2.461	3.157	1.413	0.348	3.091	0.534
最大値	0.798	1.813	30.166	11.737	2.657	3.363	1.549	0.408	3.443	0.609
最大値日時	04/23 15:20	04/05 22:00	04/22 14:00	04/23 11:10	04/06 14:20	04/09 12:20	04/25 10:20	04/25 06:00	04/20 15:00	04/21 14:40
最小値	0.602	1.362	26.625	10.291	2.016	2.395	1.069	0.282	2.232	0.413
最小値日時	04/11 06:10	04/11 05:40	04/11 04:20	04/11 05:50	04/11 05:00	04/25 10:20	04/11 04:40	04/11 07:30	04/11 04:20	04/11 05:40

測定月報

測定日：2019/04

(8/11)

日	モニタ									
	B071	B072	B073	B074	B075	B076	B077	B078	B079	B080
	土捨場東側資材置場	瓦礫保管Aテント周辺	覆土式瓦礫保管エリアL北側	覆土式瓦礫保管エリアL南側	一時保管エリアG2周辺	一時保管エリアG1周辺	5、6号機迂回道路付近	一時保管エリアM周辺	旧研修棟正面玄関前	3、4号機西側法面上
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.700	21.306	3.499	0.551	0.332	0.859	4.041	1.464	29.614	9.640
2	1.681	21.375	3.502	0.551	0.331	0.863	4.056	1.467	29.524	9.517
3	1.702	21.367	3.529	0.557	0.334	0.865	4.074	1.469	29.578	9.534
4	1.723	21.493	3.557	0.564	0.338	0.876	4.140	1.493	29.898	9.874
5	1.746	21.673	3.583	0.578	0.345	0.893	4.193	1.515	30.447	10.312
6	1.746	21.742	3.602	0.574	0.343	0.894	4.217	1.522	29.983	10.172
7	1.745	21.716	3.585	0.574	0.342	0.893	4.221	1.524	29.670	10.084
8	1.728	21.694	3.585	0.565	0.340	0.890	4.197	1.516	29.329	9.846
9	1.736	21.721	3.587	0.564	0.339	0.891	4.202	1.526	28.636	9.859
10	1.694	20.998	3.445	0.544	0.328	0.854	4.036	1.460	27.288	9.467
11	1.620	19.568	3.043	0.512	0.309	0.778	3.731	1.325	26.352	9.351
12	1.685	21.060	3.372	0.541	0.327	0.847	3.983	1.433	26.405	9.718
13	1.706	21.244	3.470	0.549	0.330	0.857	4.042	1.452	26.161	9.773
14	1.716	21.366	3.499	0.555	0.337	0.868	4.083	1.469	26.382	9.979
15	1.708	21.116	3.470	0.559	0.335	0.856	4.017	1.446	26.374	10.101
16	1.719	21.396	3.516	0.557	0.336	0.865	4.068	1.466	26.751	9.908
17	1.735	21.530	3.532	0.564	0.339	0.873	4.089	1.483	27.198	10.017
18	1.742	21.490	3.563	0.572	0.342	0.880	4.123	1.494	26.911	10.163
19	1.751	21.595	3.591	0.578	0.347	0.887	4.154	1.506	26.968	10.305
20	1.745	21.742	3.585	0.561	0.340	0.883	4.147	1.498	26.395	9.889
21	1.744	21.743	3.586	0.566	0.344	0.888	4.168	1.504	26.472	9.991
22	1.760	21.817	3.606	0.574	0.347	0.894	4.192	1.519	26.396	10.209
23	1.756	21.714	3.609	0.573	0.344	0.892	4.194	1.516	26.079	10.096
24	1.761	22.416	3.612	0.579	0.346	0.892	4.203	1.532	26.176	10.328
25	1.751	23.510	3.565	0.586	0.346	0.879	4.122	1.505	25.907	10.395
26	1.696	22.817	3.323	0.556	0.331	0.845	3.936	1.422	24.929	9.680
27	1.683	22.731	3.276	0.544	0.327	0.839	3.920	1.402	24.912	9.598
28	1.703	23.087	3.439	0.554	0.332	0.853	3.978	1.439	25.291	9.717
29	1.722	23.337	3.514	0.565	0.337	0.867	4.053	1.464	25.646	9.932
30	1.701	22.803	3.368	0.556	0.331	0.846	3.939	1.417	25.147	9.896
31										
1ヶ月値	1.720	21.772	3.501	0.561	0.337	0.869	4.084	1.475	27.227	9.912
最大値	1.903	23.964	3.759	0.647	0.383	0.955	4.412	1.602	31.088	10.929
最大値日時	04/26 09:20	04/25 01:30	04/22 16:20	04/10 08:50	04/20 07:40	04/21 11:30	04/09 09:00	04/06 14:30	04/05 16:40	04/05 17:00
最小値	1.491	16.560	2.617	0.445	0.271	0.631	3.243	1.128	24.118	8.562
最小値日時	04/11 05:50	04/11 04:30	04/11 04:30	04/11 04:10	04/11 03:10	04/11 06:00	04/11 05:20	04/11 04:30	04/27 04:30	04/11 04:30

測定月報

測定日: 2019/04

(9/11)

日	モニタ									
	B081 事務本館南	B082 大型メンテナンス建屋周辺	B083 2、3号機間道路西側(10m盤)	B084 3、4号機海側	B085 中央交差点	B086 No4倉庫周辺	B087 1、2号機排気筒西側	B088 1、2号機海側(4m盤)	B089 線量表示器89	B090 線量表示器90
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	9.475	1.125	74.402	10.337	0.368	11.739	*(
2	9.373	1.120	73.668	10.265	0.370	11.739				
3	9.425	1.126	72.053	10.299	0.371	11.769				
4	9.756	1.154	72.529	10.517	0.378	11.897				
5	10.187	1.193	73.634	10.741	0.384	12.034				
6	10.046	1.175	73.683	10.722	0.383	12.067				
7	9.933	1.176	73.738	10.635	0.384	12.062				
8	9.703	1.157	71.665	10.502	0.380	12.016				
9	9.716	1.155	70.765	10.551	0.379	12.030				
10	9.310	1.117	70.224	10.083	0.367	11.460				
11	9.153	1.086	69.940	9.560	0.344	10.598				
12	9.496	1.130	71.424	10.217	0.368	11.640				
13	9.553	1.140	72.234	10.299	0.371	11.787				
14	9.732	1.157	72.744	10.414	0.376	11.880				
15	9.912	1.170	72.421	10.537	0.374	11.712				
16	9.783	1.159	72.633	10.582	0.377	11.861				
17	9.888	1.171	72.375	10.628	0.377	11.896				
18	9.998	1.181	72.923	10.711	0.380	11.918				
19	10.168	1.191	75.174	10.833	0.384	11.986				
20	9.717	1.157	75.025	10.614	0.380	12.001				
21	9.821	1.168	75.167	10.640	0.380	12.004				
22	10.021	1.185	75.551	10.812	0.385	12.082				
23	9.912	1.177	74.228	10.759	0.384	12.083				
24	10.091	1.192	75.449	10.794	0.386	12.101				
25	10.165	1.194	75.651	10.686	0.386	11.893				
26	9.489	1.124	73.416	10.216	0.372	11.448				
27	9.391	1.112	73.147	10.161	0.366	11.428				
28	9.493	1.127	73.937	10.362	0.371	11.656				
29	9.712	1.152	74.709	10.552	0.376	11.827				
30	9.701	1.143	74.071	10.338	0.369	11.469				
31										
1ヶ月値	9.737	1.154	73.286	10.479	0.376	11.803				
最大値	10.766	1.279	77.403	11.261	0.423	12.351				
最大値日時	04/19 11:20	04/05 17:10	04/19 14:50	04/19 12:50	04/25 02:50	04/06 15:20				
最小値	8.422	0.977	46.614	8.212	0.288	8.808				
最小値日時	04/11 02:40	04/11 07:10	04/08 13:20	04/11 04:40	04/11 05:40	04/11 03:40				

*1:線量表示器の故障に伴う欠測

測定月報

測定日：2019/04

(10/11)

日	モニタ									
	B091	B092	B093	B094	B095	B096	B097	B098	B099	B100
	2号機西側連夕カバ内 線量率 (μ Sv/h)	携行利用型線量表示器92 線量率 (μ Sv/h)	携行利用型線量表示器93 線量率 (μ Sv/h)	携行利用型線量表示器94 線量率 (μ Sv/h)	携行利用型線量表示器95 線量率 (μ Sv/h)	3号機海側連夕小屋内 線量率 (μ Sv/h)	1、2号機海側 線量率 (μ Sv/h)	携行利用型線量表示器98 線量率 (μ Sv/h)	携行利用型線量表示器99 線量率 (μ Sv/h)	携行利用型線量表示器100 線量率 (μ Sv/h)
1	52.141					11.650	11.516			
2	51.849					11.594	11.354			
3	51.799					11.639	11.403			
4	52.577					11.920	11.805			
5	53.224					12.228	12.171			
6	51.767					12.256	12.153			
7	51.725					12.162	12.040			
8	51.174					11.968	11.813			
9	51.013					11.929	11.829			
10	54.798					11.484	11.330			
11	59.423					10.994	11.035			
12	62.772					11.601	11.490			
13	63.364					11.715	11.595			
14	63.654					11.868	11.763			
15	63.620					11.909	11.948			
16	63.762					11.850	11.802			
17	63.710					11.927	11.860			
18	64.814					12.042	12.044			
19	67.645					12.162	12.181			
20	67.893					11.921	11.819			
21	67.806					11.966	11.914			
22	68.342					12.131	12.162			
23	67.847					12.066	12.031			
24	66.760					12.146	12.184			
25	65.380					12.071	12.140			
26	63.745					11.494	11.496			
27	63.423					11.426	11.378			
28	64.209					11.652	11.554			
29	64.873					11.844	11.766			
30	64.096					11.654	11.629			
31										
1ヶ月値	60.703					11.842	11.774			
最大値	69.501					12.814	12.760			
最大値日時	04/22 16:10					04/05 17:10	04/19 12:10			
最小値	48.047					9.774	10.092			
最小値日時	04/06 03:20					04/11 04:30	04/11 04:20			