

測定月報

測定日：2019/05

(1/11)

日	モニタ									
	B001	B002	B003	B004	B005	B006	B007	B008	B009	B010
	入退域管理棟周辺	正門警備所周辺	環境管理棟周辺	車両スクリーニング場周辺	厚生棟休憩所周辺	登録センター休憩所周辺	5、6号機サービス建屋休憩所周辺	シールド中央制御室周辺	免震重要棟周辺	5、6号機防護本部周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	0.207	0.476	1.675	0.454	0.564	1.381	* (2.232	5.767	1.371
2	0.208	0.491	1.680	0.456	0.572	1.387		2.251	5.799	1.391
3	0.206	0.483	1.693	0.461	0.575	1.390		2.259	5.794	1.405
4	0.206	0.493	1.694	0.460	0.575	1.392		2.260	5.792	1.413
5	0.207	0.498	1.696	0.463	0.580	1.396		2.267	5.806	1.424
6	0.207	0.492	1.681	0.463	0.574	1.393		2.266	5.787	1.389
7	0.203	0.489	1.671	0.452	0.563	1.379		2.226	5.728	1.368
8	0.205	0.483	1.691	0.463	0.573	1.388		2.268	5.791	1.407
9	0.210	0.498	1.697	0.468	0.579	1.395		2.292	5.836	1.423
10	0.209	0.509	1.697	0.468	0.577	1.402		2.296	5.839	1.438
11	0.209	0.501	1.691	0.464	0.571	1.403		2.273	5.787	1.431
12	0.206	0.500	1.686	0.459	0.570	1.396		2.260	5.742	1.415
13	0.204	0.497	1.685	0.459	0.573	1.408		2.257	5.733	1.417
14	0.208	0.501	1.688	0.468	0.578	1.402		2.276	5.770	1.432
15	0.207	0.497	1.649	0.455	0.569	1.390		2.255	5.732	1.376
16	0.204	0.498	1.671	0.456	0.565	1.394		2.247	5.752	1.383
17	0.206	0.478	1.687	0.456	0.567	1.397		2.270	5.775	1.400
18	0.209	0.481	1.685	0.460	0.575	1.400		2.286	5.786	1.412
19	0.209	0.484	1.681	0.463	0.574	1.394		2.292	5.794	1.423
20	0.207	0.498	1.665	0.461	0.575	1.394		2.302	5.806	1.450
21	0.202	0.492	1.619	0.450	0.561	1.376		2.228	5.732	1.286
22	0.203	0.493	1.647	0.455	0.564	1.383		2.255	5.760	1.379
23	0.204	0.486	1.658	0.459	0.568	1.383		2.269	5.806	1.406
24	0.208	0.491	1.663	0.465	0.572	1.390		2.276	5.846	1.426
25	0.212	0.488	1.656	0.463	0.575	1.395		2.299	5.865	1.441
26	0.214	0.499	1.663	0.465	0.578	1.399		2.304	5.870	1.449
27	0.214	0.501	1.665	0.469	0.583	1.398		2.302	5.892	1.457
28	0.212	0.498	1.666	0.470	0.580	1.403		2.315	5.897	1.460
29	0.210	0.488	1.639	0.461	0.567	1.393		2.266	5.800	1.400
30	0.208	0.485	1.649	0.461	0.569	1.387		2.266	5.824	1.407
31	0.210	0.500	1.646	0.464	0.570	1.391		2.277	5.842	1.418
1ヶ月値	0.208	0.493	1.672	0.461	0.572	1.393		2.271	5.798	1.409
最大値	0.247	0.560	1.784	0.509	0.629	1.490		3.298	6.040	1.543
最大値日時	05/25 20:50	05/16 06:50	05/17 16:30	05/09 08:20	05/09 15:30	05/18 08:30		05/22 10:20	05/27 23:00	05/27 08:20
最小値	0.169	0.422	1.537	0.402	0.456	1.303		2.088	5.547	0.917
最小値日時	05/13 16:20	05/30 05:20	05/21 11:00	05/21 13:30	05/20 13:00	05/16 06:10		05/21 14:20	05/21 11:30	05/21 14:40

*：線量表示器の故障に伴う欠測

測定月報

測定日: 2019/05

(2/11)

日	モニタ									
	B011	B012	B013	B014	B015	B016	B017	B018	B019	B020
	1号機北側法面上周辺	1、2号機西側法面上周辺	3、4号機西側法面上周辺	4号機南側法面上周辺	一般焼却炉周辺	車両整備場周辺	多核種除去施設周辺	キャスク仮保管施設周辺	野鳥の森五差路周辺	5、6号機西側周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	43.489	39.209	10.009	1.105	17.180	0.866	0.610	0.271	2.361	1.720
2	44.058	39.575	10.105	1.118	17.347	0.870	0.618	0.274	2.378	1.741
3	44.155	39.528	10.005	1.104	17.557	0.880	0.627	0.272	2.343	1.764
4	44.169	39.337	9.946	1.099	17.637	0.882	0.628	0.272	2.311	1.768
5	44.344	39.546	9.988	1.105	17.739	0.888	0.629	0.272	2.335	1.785
6	44.136	39.563	10.029	1.100	17.535	0.885	0.626	0.276	2.361	1.776
7	43.542	39.008	9.806	1.072	17.212	0.868	0.610	0.269	2.281	1.719
8	44.170	39.567	10.014	1.103	17.520	0.781	0.630	0.272	2.345	1.762
9	44.443	39.944	10.163	1.117	17.594	0.741	0.644	0.277	2.413	1.792
10	44.779	40.183	10.229	1.121	17.730	0.744	0.639	0.278	2.428	1.803
11	44.293	39.497	9.950	1.093	17.806	0.739	0.636	0.272	2.316	1.786
12	43.705	38.985	9.783	1.074	17.813	0.735	0.630	0.264	2.243	1.779
13	43.664	38.972	9.753	1.066	17.763	0.735	0.650	0.265	2.246	1.782
14	44.120	39.472	10.005	1.078	17.819	0.723	0.658	0.273	2.342	1.792
15	43.358	39.084	9.918	1.048	17.262	0.721	0.619	0.271	2.323	1.705
16	43.500	39.116	9.895	1.065	17.343	0.726	0.621	0.269	2.303	1.708
17	43.883	39.381	9.958	1.075	17.466	0.732	0.649	0.270	2.329	1.726
18	44.158	39.632	10.045	1.083	17.677	0.730	0.668	0.272	2.354	1.749
19	44.286	39.764	10.090	1.084	17.781	0.734	0.673	0.271	2.379	1.766
20	44.330	39.805	10.134	1.084	17.752	0.733	0.654	0.276	2.400	1.776
21	43.110	39.094	9.989	1.034	16.838	0.716	0.631	0.272	2.368	1.679
22	43.581	39.271	9.997	1.046	17.222	0.716	0.660	0.272	2.358	1.693
23	44.296	39.724	10.097	1.058	17.385	0.739	0.671	0.276	2.390	1.729
24	44.761	40.272	10.327	1.079	17.548	0.741	0.678	0.277	2.462	1.750
25	44.804	40.281	10.346	1.080	17.762	0.731	0.685	0.280	2.454	1.767
26	44.823	40.268	10.371	1.077	17.871	0.739	0.691	0.280	2.468	1.778
27	45.156	40.585	10.515	1.087	17.795	0.745	0.694	0.286	2.532	1.802
28	45.093	40.648	10.536	1.087	17.861	0.747	0.698	0.287	2.573	1.795
29	44.037	39.768	10.205	1.043	17.323	0.724	0.671	0.279	2.455	1.727
30	44.246	39.880	10.204	1.047	17.448	0.726	0.672	0.278	2.453	1.736
31	44.567	40.143	10.276	1.055	17.573	0.733	0.653	0.280	2.489	1.762
1ヶ月値	44.163	39.648	10.087	1.080	17.554	0.767	0.649	0.274	2.380	1.755
最大値	46.068	41.376	10.947	1.226	18.228	0.941	0.876	0.355	2.764	1.892
最大値日時	05/27 08:50	05/28 14:40	05/27 09:00	05/10 09:50	05/14 14:10	05/03 17:40	05/22 10:30	05/24 10:20	05/22 10:20	05/04 18:20
最小値	42.245	37.590	8.439	0.942	15.130	0.514	0.569	0.228	2.129	1.533
最小値日時	05/21 15:30	05/21 11:30	05/23 10:50	05/29 22:50	05/21 13:50	05/14 12:40	05/01 02:50	05/17 23:50	05/13 02:30	05/21 13:40

測定月報

測定日：2019/05

(3/11)

日	モニタ									
	B021 西門周辺	B022 さくら通り正門側	B023 増設多核種除去設備西側周辺	B024 リフタエリア周辺(遊技場・モニタ小屋側)	B025 1、2号機海側(4m壁)	B026 3、4号機海側(4m壁)	B027 固体廃棄物貯蔵庫管理棟周辺	B028 高性能多核種除去設備周辺	B029 サブドレン浄化設備周辺	B030 給油所周辺
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.261	0.861	0.417	4.781	*1	*1	1194.870	64.586	0.279	0.369
2	1.257	0.868	0.418	4.817			1203.798	66.670	0.281	0.372
3	1.268	0.878	0.415	4.858			1209.246	66.729	0.278	0.372
4	1.269	0.877	0.410	4.868			1209.413	66.812	0.277	0.375
5	1.277	0.880	0.416	4.890			1210.555	67.188	0.280	0.380
6	1.277	0.879	0.418	4.874			1207.864	67.085	0.281	0.379
7	1.255	0.853	0.409	4.780			*2 509.913	*3 28.470	0.278	0.368
8	1.275	0.868	0.416	4.848			8.002	1.106	0.281	0.374
9	1.281	0.895	0.423	4.891			8.118	1.120	0.277	0.385
10	1.285	0.903	0.423	4.920			8.158	1.129	0.275	0.383
11	1.279	0.895	0.412	4.916			8.113	1.112	0.273	0.377
12	1.275	0.894	0.405	4.897			8.080	1.103	0.269	0.374
13	1.269	0.890	0.405	4.910			8.066	1.108	0.272	0.377
14	1.282	0.893	0.413	4.925			8.115	1.114	0.279	0.380
15	1.259	0.868	0.415	4.797			7.849	1.110	0.275	0.371
16	1.260	0.870	0.414	4.805			7.868	1.105	0.274	0.375
17	1.271	0.876	0.416	4.841			10.511	1.108	0.272	0.378
18	1.279	0.878	0.415	4.878			12.214	1.123	0.272	0.381
19	1.280	0.880	0.419	4.906			12.259	1.127	0.273	0.382
20	1.279	0.890	0.420	4.920			11.969	1.123	0.273	0.385
21	1.245	0.863	0.422	4.753			11.339	1.101	0.273	0.371
22	1.246	0.869	0.419	4.770			11.345	1.108	0.272	0.373
23	1.259	0.876	0.423	4.822			11.726	1.119	0.270	0.375
24	1.277	0.885	0.429	4.877			12.022	1.125	0.276	0.382
25	1.279	0.892	0.427	4.911			12.084	1.129	0.277	0.382
26	1.286	0.895	0.433	4.937			12.117	1.132	0.279	0.386
27	1.293	0.901	0.437	4.963			12.177	1.138	0.280	0.392
28	1.301	0.904	0.437	4.962			12.168	1.140	0.287	0.392
29	1.266	0.884	0.428	4.827			11.871	1.121	0.282	0.381
30	1.271	0.890	0.423	4.857			11.961	1.123	0.272	0.380
31	1.281	0.898	0.428	4.883			12.006	1.127	0.267	0.385
1ヶ月値	1.272	0.882	0.420	4.867			257.816	14.652	0.276	0.378
最大値	1.355	0.976	0.515	5.084			1220.517	68.479	0.353	0.867
最大値日時	05/11 01:10	05/09 15:00	05/27 09:50	05/27 10:30			05/05 10:50	05/03 10:20	05/28 10:20	05/22 10:30
最小値	1.160	0.799	0.367	4.530			7.609	1.034	0.219	0.329
最小値日時	05/21 15:40	05/21 11:00	05/14 05:20	05/21 13:50			05/15 08:40	05/09 00:50	05/13 11:30	05/19 23:20

*1: 線量表示器の故障に伴う欠測

*3: 2019年5月7日から B028をB039に入替へ

*2: 2019年5月7日から B027をB038に入替へ

測定月報

測定日：2019/05

(4/11)

日	モニタ									
	B031	B032	B033	B034	B035	B036	B037	B038	B039	B040
	HIC保管エリア周辺 線量率 (μ Sv/h)	H8タンクエリア周辺 線量率 (μ Sv/h)	H4タンクエリア周辺 線量率 (μ Sv/h)	H5タンクエリア周辺 線量率 (μ Sv/h)	J2タンクエリア周辺 線量率 (μ Sv/h)	1、2号機S/B周辺 線量率 (μ Sv/h)	タンク周辺 線量率 (μ Sv/h)	2号機R/B西側 線量率 (μ Sv/h)	1号機R/B西側 線量率 (μ Sv/h)	1号機R/B北側 線量率 (μ Sv/h)
1	*1	*1	*1	*1	*1	*1	*1	*1	*1	*2
2										
3										
4										
5										
6										
7	*3 16.315	*4 33.542						*9 1130.622	*10 63.247	
8	16.448	33.847						1142.608	63.674	
9	16.675	34.087						1147.565	64.274	
10	16.758	34.351						1151.856	64.247	
11	16.464	34.200						1149.969	64.321	
12	16.232	34.014						1147.998	63.854	
13	16.317	34.085						1148.267	63.849	
14	16.580	34.350	*5 111.491	*6 33.095	*7 69.668	*8 33.533		1150.256	64.053	
15	16.407	33.698	109.917	32.431	69.102	32.890		1140.091	63.791	
16	16.440	33.786	110.265	32.533	68.487	32.939		1142.575	63.571	
17	16.410	33.969	111.130	32.827	68.571	33.269		1146.807	63.774	
18	16.553	34.245	111.932	33.052	69.312	33.696		1151.108	64.429	
19	16.642	34.454	112.388	32.897	70.187	33.815		1152.562	65.065	
20	16.609	34.372	112.117	33.051	69.666	33.913		1151.987	64.477	
21	16.218	33.208	109.965	32.108	68.551	32.940		1137.230	63.331	
22	16.335	33.525	110.606	32.325	68.262	33.085		1141.719	63.089	
23	16.632	34.070	111.148	32.690	68.966	33.523		1148.003	63.773	
24	16.804	34.397	112.806	33.237	69.622	34.107		1150.942	64.331	
25	16.872	34.645	113.485	33.265	70.088	34.163		1152.634	64.657	
26	16.932	34.822	113.691	33.347	70.132	34.312		1153.223	64.573	
27	17.064	34.967	114.063	33.540	70.268	34.563		1154.992	64.626	
28	17.099	34.974	113.826	33.612	70.249	34.613		1151.441	64.671	
29	16.672	34.145	111.719	32.748	69.253	33.705		1143.347	63.781	
30	16.829	34.360	112.428	32.785	70.211	33.833		1144.612	64.515	
31	16.942	34.448	112.846	33.120	70.038	34.140		1146.289	64.331	
1ヶ月値	16.615	34.194	112.002	32.922	69.475	33.729		1147.428	64.106	
最大値	19.784	35.759	115.548	34.243	81.414	35.560		1163.938	72.834	
最大値日時	05/16 18:30	05/28 15:50	05/28 15:50	05/28 14:30	05/30 09:00	05/27 09:30		05/27 12:10	05/30 09:00	
最小値	13.470	30.558	80.085	19.723	54.707	18.831		328.403	40.621	
最小値日時	05/07 10:40	05/07 10:50	05/14 10:10	05/14 09:50	05/14 10:00	05/14 09:50		05/07 10:10	05/07 10:10	

*1: 線量表示器の点検・校正に伴う欠測

*2: 線量表示器の故障に伴う欠測

*3: 2019年5月7日からB031をB040の代替機として配備

*4: 2019年5月7日からB032をB035の代替機として配備

*5: 2019年5月14日からB033をB051の代替機として配備

*6: 2019年5月14日からB034をB052の代替機として配備

*7: 2019年5月14日からB035をB053の代替機として配備

*8: 2019年5月14日からB036をB054の代替機として配備

*9: 2019年5月7日からB038をB027に入れ替え

*10: 2019年5月7日からB039をB028に入れ替え

測定月報

測定日: 2019/05

(5/11)

日	モニタ									
	B041 MP7	B042 大型メンテナンス建屋・東側	B043 大熊通り中央付近	B044 1～4号機PPゲート前	B045 1、2号機S/B周辺	B046 3、4号機S/B周辺	B047 集中RW東側	B048 集中RW南側(PSFモニタ近傍)	B049 共用プール西側	B050 4号機R/B西側
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	*1	*1	2.898	18.046	35.110	60.331	6.223	9.086	27.805	8.396
2			2.921	18.294	35.615	60.854	6.323	9.246	28.222	8.481
3			2.944	18.254	35.801	61.645	6.447	9.455	28.682	8.507
4			2.956	18.245	35.919	62.046	6.383	9.479	28.833	8.512
5			2.973	18.353	36.103	62.560	6.564	9.512	28.942	8.553
6			2.965	18.322	35.916	61.987	6.361	9.318	28.452	8.519
7			2.846	17.807	34.753	57.336	6.408	9.053	27.741	8.345
8			*1	*1	*1	*1	6.346	9.196	28.577	8.487
9							6.598	9.355	28.853	8.576
10							6.498	9.493	28.966	8.633
11							6.429	9.479	28.896	8.531
12							6.472	9.448	28.831	8.465
13							6.322	9.415	28.812	8.437
14	3.028	3.798					6.312	9.198	28.806	8.429
15	2.971	3.777					*1	*1	*1	*1
16	2.968	3.765								
17	3.002	3.775								
18	3.021	3.798								
19	3.049	3.805								
20	3.072	3.833								
21	2.989	3.825								
22	3.020	3.861						*2	0.356	
23	3.065	3.977								
24	3.123	4.060								
25	3.127	4.050								
26	3.147	4.064								
27	3.186	4.095								
28	3.195	4.108								
29	3.089	4.026								
30	3.108	4.016								
31	3.137	4.058								
1ヶ月値	3.073	3.931	2.936	18.222	35.677	61.278	6.410	9.339	28.593	8.493
最大値	3.363	4.871	3.096	18.974	36.903	63.652	7.063	9.719	29.531	8.879
最大値日時	05/28 15:20	05/31 11:10	05/05 16:50	05/03 10:20	05/03 10:20	05/05 14:30	05/06 01:30	05/09 16:30	05/06 11:20	05/10 15:50
最小値	2.201	3.335	2.760	17.429	34.256	56.820	5.990	0.356	25.003	8.058
最小値日時	05/14 10:30	05/14 10:40	05/06 22:30	05/06 23:40	05/07 00:00	05/07 00:10	05/01 06:00	05/22 12:20	05/06 23:40	05/06 22:50

*1: 線量表示器の点検・校正に伴う欠測

*2: 線量表示器の点検・校正に伴う測定値

測定月報

測定日: 2019/05

(6/11)

日	モニタ									
	B051 3号機R/B西側	B052 2号機R/B西側	B053 1号機R/B西側	B054 1号機R/B北側	B055 物揚場周辺	B056 固体庫1, 2棟周辺	B057 旧事務本館北側	B058 固体庫第9棟建設地周辺	B059 MP3	B060 MP4
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	106.908	36.086	65.211	37.310	5.012	4.310	9.473	0.413	1.771	1.867
2	107.930	36.473	67.117	37.681	5.096	4.349	9.552	0.413	1.787	1.896
3	108.368	36.590	67.099	37.777	5.083	4.377	9.529	0.419	1.823	1.987
4	108.389	36.646	67.087	37.854	5.064	4.382	9.506	0.421	1.838	2.011
5	108.640	36.849	67.464	38.050	5.113	4.413	9.563	0.423	1.848	2.035
6	108.204	36.637	67.357	37.877	5.100	4.394	9.523	0.423	1.839	1.985
7	106.849	35.890	66.731	37.065	4.956	4.268	9.340	0.408	1.773	1.893
8	107.575	36.469	67.019	37.670	5.085	4.356	9.509	0.417	1.818	1.994
9	106.911	36.888	67.499	38.070	5.147	4.430	9.618	0.424	1.845	2.025
10	109.041	37.183	67.240	38.400	5.099	4.468	9.702	0.425	1.855	2.056
11	108.518	36.594	67.178	37.785	4.929	4.402	9.497	0.423	1.851	2.049
12	108.031	36.216	66.576	37.382	4.828	4.358	9.344	0.422	1.847	2.055
13	107.893	36.205	66.467	37.083	4.826	4.364	9.329	0.423	1.855	2.062
14	109.130	36.308	65.833	37.112	4.998	4.420	9.465	0.428	1.871	2.073
15	*1	*1	*1	*1	4.952	4.273	9.242	0.417	1.794	1.903
16					4.955	4.264	9.147	0.417	1.798	1.961
17					5.003	4.317	9.182	0.421	1.819	1.992
18					5.049	4.357	9.285	0.423	1.844	2.017
19					5.087	4.385	9.323	0.425	1.858	2.035
20					5.101	4.408	9.324	0.425	1.867	2.055
21					5.051	4.363	9.259	0.421	1.834	1.952
22					*2 0.288	*1	*1	*2 0.237	*1	*1
23					*1			*1		
24										
25										
26										
27										
28										
29										
30										
31										
1ヶ月値	107.980	36.511	66.894	37.675	5.023	4.365	9.419	0.420	1.830	1.997
最大値	113.788	38.100	69.143	39.444	5.348	4.629	9.993	0.474	1.946	2.143
最大値日時	05/14 09:40	05/10 09:50	05/09 12:10	05/10 10:00	05/03 09:40	05/09 14:40	05/08 17:30	05/18 15:10	05/19 13:30	05/13 16:00
最小値	85.524	34.076	57.452	35.723	0.288	4.082	8.357	0.237	1.667	1.580
最小値日時	05/09 07:20	05/06 20:50	05/01 13:00	05/06 20:50	05/22 12:20	05/06 22:40	05/16 14:20	05/22 12:20	05/07 00:40	05/06 20:50

*1: 線量表示器の点検・校正に伴う欠測

*2: 線量表示器の点検・校正に伴う測定値

測定月報

測定日：2019/05

(7/11)

日	モニタ									
	B061 MP5	B062 焼却設備建屋周辺	B063 Fタンクエリア周辺	B064 ビヤード P1東側周辺	B065 焼却設備建屋前道路カーブミラー脇	B066 資材置場	B067 一時保管エリアC周辺	B068 ALPS連夕周辺	B069 一時保管エリアH1周辺	B070 土捨場資材置場
	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)	線量率 ($\mu\text{Sv/h}$)
1	0.701	1.657	29.429	11.215	2.427	3.099	1.390	0.354	3.075	0.525
2	0.714	1.673	29.480	11.261	2.446	3.130	1.408	0.352	3.127	0.532
3	0.722	1.683	29.512	11.302	2.466	3.151	1.421	0.349	3.183	0.537
4	0.727	1.688	29.548	11.321	2.480	3.162	1.429	0.351	3.218	0.540
5	0.733	1.694	29.553	11.354	2.487	3.179	1.437	0.351	3.252	0.543
6	0.726	1.686	29.540	11.329	2.471	3.155	1.432	0.353	3.219	0.541
7	0.705	1.652	29.426	11.221	2.425	3.033	1.388	0.348	3.082	0.521
8	0.713	1.678	29.506	11.286	2.462	3.070	1.421	0.354	3.141	0.535
9	0.722	1.693	29.514	11.315	2.480	3.085	1.449	0.359	3.166	0.541
10	0.734	1.707	29.598	11.369	2.501	3.123	1.484	0.360	3.214	0.547
11	0.731	1.697	29.540	11.351	2.491	3.121	1.498	0.349	3.215	0.543
12	0.728	1.686	29.462	11.340	2.486	3.113	1.493	0.344	3.216	0.540
13	0.730	1.687	29.485	11.349	2.488	3.113	1.497	0.348	3.218	0.541
14	0.736	1.692	29.485	11.340	2.503	3.133	1.513	0.354	3.226	0.549
15	0.706	1.664	29.449	11.245	2.427	3.078	1.469	0.352	3.082	0.532
16	0.709	1.664	29.434	11.255	2.441	3.090	1.457	0.350	3.072	0.530
17	0.713	1.673	29.495	11.291	2.456	3.099	1.473	0.350	3.022	0.537
18	0.724	1.685	29.519	11.336	2.474	3.134	1.495	0.350	3.005	0.543
19	0.731	1.693	29.563	11.357	2.483	3.154	1.517	0.352	3.042	0.547
20	0.736	1.698	29.509	11.356	2.493	3.160	1.522	0.355	3.049	0.550
21	0.727	1.672	29.384	11.239	2.404	3.037	1.466	0.345	2.831	0.533
22	*1	*1	*1	*1	2.428	3.088	1.656	0.347	2.844	0.530
23					2.469	3.046	1.635	0.352	2.912	0.537
24					2.474	3.015	1.492	0.360	2.966	0.533
25					2.488	3.039	*2	0.359	3.012	0.539
26					2.505	3.064	1.536	0.360	3.038	0.543
27					2.514	3.064	1.546	0.364	3.050	0.546
28					2.521	3.097	1.547	0.366	3.046	0.547
29					2.450	3.044	1.490	0.360	2.909	0.526
30					2.453	3.023	1.486	0.354	2.949	0.527
31					2.462	2.247	1.489	0.356	2.994	0.531
1ヶ月値	0.722	1.682	29.500	11.308	2.470	3.069	1.484	0.353	3.077	0.538
最大値	0.794	1.799	30.038	11.679	2.763	34.438	1.882	0.403	3.364	0.598
最大値日時	05/05 14:10	05/10 12:40	05/11 12:40	05/10 10:20	05/23 15:10	05/30 10:20	05/22 18:00	05/08 15:00	05/14 18:50	05/23 13:20
最小値	0.652	1.568	28.019	10.955	2.292	2.163	1.311	0.310	2.571	0.476
最小値日時	05/02 01:30	05/17 01:50	05/07 10:00	05/07 05:40	05/21 12:30	05/29 10:10	05/07 01:50	05/11 14:40	05/21 14:00	05/21 16:10

*1:線量表示器の点検・校正に伴う欠測

*2:通信エラーに伴う欠測

測定月報

測定日：2019/05

(8/11)

日	モニタ									
	B071 土捨場東側資材置場	B072 瓦礫保管Aテント周辺	B073 MP1	B074 覆土式瓦礫保管エリアL南側	B075 MP2	B076 MP8	B077 MP6	B078 一時保管エリアM周辺	B079 旧研修棟正面玄関前	B080 3、4号機西側法面上
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	1.711	22.797	3.389	0.569	0.337	0.850	3.952	1.421	25.494	10.295
2	1.722	23.055	3.464	0.572	0.340	0.862	3.992	1.431	25.765	10.414
3	1.734	23.334	3.526	0.571	0.339	0.869	4.058	1.456	25.873	10.295
4	1.743	23.473	3.552	0.574	0.343	0.874	4.088	1.474	25.894	10.195
5	1.745	23.586	3.577	0.579	0.343	0.881	4.124	1.491	25.973	10.233
6	1.739	23.338	3.520	0.577	0.343	0.874	4.103	1.478	25.805	10.258
7	1.708	22.104	3.345	0.560	0.333	0.849	3.988	1.418	25.349	10.021
8	1.737	21.257	3.567	0.574	0.342	0.870	4.076	1.457	25.620	10.224
9	1.756	21.334	3.633	0.585	0.347	0.885	4.127	1.477	25.792	10.404
10	1.764	21.480	3.672	0.593	0.351	0.891	4.174	1.491	26.069	10.489
11	1.768	21.502	3.677	0.587	0.347	0.888	4.174	1.492	25.527	10.186
12	1.761	21.476	3.677	0.578	0.344	0.889	4.175	1.490	25.198	9.948
13	1.759	21.486	3.686	0.580	0.345	0.892	4.174	1.498	25.181	9.948
14	1.774	21.645	3.706	0.593	0.350	0.897	4.207	1.509	25.400	10.295
15	1.734	20.875	3.589	0.584	0.342	0.862	4.021	1.443	24.505	10.212
16	1.738	21.043	3.598	0.576	0.342	0.860	4.012	1.453	24.454	10.149
17	1.739	21.352	3.641	0.584	0.344	0.870	4.061	1.465	24.562	10.239
18	1.759	21.613	3.697	0.593	0.349	0.884	4.120	1.477	24.787	10.329
19	1.769	21.916	3.764	0.611	0.354	0.898	4.165	1.499	24.965	10.386
20	1.776	21.944	3.792	0.616	0.358	0.904	4.177	1.504	25.002	10.438
21	1.734	21.138	3.485	0.606	0.350	0.609	3.972	1.410	23.891	10.273
22	1.747	21.241	3.549	0.604	0.353	0.818	3.971	1.403	24.703	10.295
23	1.767	21.545	3.717	0.615	0.358	0.885	4.037	1.436	25.022	10.444
24	1.771	21.770	3.760	0.621	0.364	0.898	4.108	1.461	25.279	10.658
25	1.786	21.934	3.791	0.626	0.366	0.909	4.160	1.476	25.230	10.644
26	1.795	22.014	3.827	0.630	0.369	0.918	4.194	1.490	25.269	10.673
27	1.800	22.027	3.835	0.639	0.369	0.922	4.226	1.508	25.456	10.853
28	1.799	22.023	*	0.636	*	*	2.593	1.519	25.490	10.864
29	1.759	21.407		0.617	1.049	6.104	0.834	1.455	24.795	10.475
30	1.750	21.582		0.613	1.054	6.175	0.837	1.455	25.068	10.485
31	1.752	21.663		0.616	1.070	6.192	0.841	1.475	25.205	10.586
1ヶ月値	1.754	21.902	3.628	0.596	0.426	1.368	3.738	1.468	25.246	10.361
最大値	1.893	29.226	3.955	0.695	1.158	6.349	4.381	1.599	26.634	11.240
最大値日時	05/26 14:40	05/14 19:00	05/26 14:30	05/28 00:10	05/28 18:10	05/30 17:40	05/27 17:40	05/28 18:50	05/10 11:30	05/28 14:50
最小値	1.605	19.858	3.070	0.511	0.294	0.251	0.784	1.294	21.683	9.580
最小値日時	05/06 20:10	05/22 16:30	05/07 00:10	05/07 04:10	05/07 05:50	05/21 16:20	05/30 04:40	05/21 14:50	05/21 14:40	05/13 03:00

*1：2019年5月28日から各モニタリングポスト付近へ移設したことによる欠測や誤り定値変動

測定月報

測定日: 2019/05

(9/11)

日	モニタ									
	B081 事務本館南	B082 大型メンテナンス建屋周辺	B083 2、3号機間道路西側(10m盤)	B084 3、4号機海側	B085 中央交差点	B086 No.4倉庫周辺	B087 1、2号機排気筒西側	B088 1、2号機海側(4m盤)	B089 線量表示器89	B090 線量表示器90
	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)	線量率 (μ Sv/h)
1	10.015	1.170	74.925	10.477	0.375	11.503	*1			
2	10.072	1.180	75.679	10.686	0.379	11.658				
3	9.958	1.174	75.585	10.719	0.379	11.821				
4	9.900	1.167	75.366	10.731	0.380	11.886				
5	9.989	1.174	75.601	10.794	0.382	11.968				
6	10.048	1.178	75.515	10.729	0.383	11.868				
7	9.823	1.148	74.599	10.517	0.372	11.598				
8	10.020	1.172	74.118	10.712	0.381	11.803				
9	10.180	1.194	74.877	10.801	0.382	11.927				
10	10.284	1.199	74.203	10.936	0.384	11.994				
11	9.910	1.178	74.928	10.814	0.380	11.993				
12	9.624	1.162	74.765	10.666	0.379	11.975				
13	9.638	1.158	74.306	10.669	0.379	11.994				
14	9.901	1.179	75.276	10.778	0.383	11.981				
15	9.800	1.156	74.930	10.560	0.378	11.602				
16	9.732	1.159	75.114	10.559	0.376	11.624	*2 0.440			
17	9.822	1.167	75.480	10.648	0.379	11.816				
18	9.931	1.175	76.353	10.771	0.381	11.934				
19	9.957	1.180	76.543	10.780	0.383	12.006				
20	10.020	1.190	75.161	10.797	0.385	12.041				
21	9.893	1.160	75.206	10.376	0.375	11.429				
22	9.855	1.160	74.971	10.547	0.376	11.533				
23	9.980	1.176	75.133	10.723	0.378	11.735				
24	10.216	1.198	76.678	10.760	0.383	11.837				
25	10.175	1.200	77.249	10.818	0.386	11.962				
26	10.186	1.204	77.455	10.868	0.390	12.036				
27	10.334	1.213	77.447	10.955	0.392	12.079				
28	10.348	1.217	76.433	10.952	0.393	12.110				
29	9.989	1.174	76.359	10.632	0.385	11.685				
30	10.001	1.179	76.204	10.684	0.382	11.804				
31	10.134	1.190	76.644	10.691	0.386	11.875				
1ヶ月値	9.992	1.178	75.584	10.715	0.381	11.841	0.440			
最大値	10.783	1.291	78.798	11.279	0.641	12.421	0.440			
最大値日時	05/27 08:10	05/30 17:20	05/27 08:20	05/10 09:30	05/22 10:30	05/27 13:50	05/16 10:50			
最小値	9.305	1.083	57.872	9.949	0.325	10.866	0.440			
最小値日時	05/13 02:50	05/07 06:40	05/08 14:00	05/21 14:00	05/22 01:20	05/21 15:30	05/16 10:50			

*1:線量表示器の点検・校正に伴う欠測

*2:線量表示器の点検・校正に伴う限り定値

測定月報

測定日: 2019/05

(10/11)

日	モニタ									
	B091	B092	B093	B094	B095	B096	B097	B098	B099	B100
	2号機西側連ダカバー内 線量率 (μ Sv/h)	携行利用型線量表示器92 線量率 (μ Sv/h)	携行利用型線量表示器93 線量率 (μ Sv/h)	携行利用型線量表示器94 線量率 (μ Sv/h)	携行利用型線量表示器95 線量率 (μ Sv/h)	3号機海側連ダ小屋内 線量率 (μ Sv/h)	1、2号機海側 線量率 (μ Sv/h)	携行利用型線量表示器98 線量率 (μ Sv/h)	携行利用型線量表示器99 線量率 (μ Sv/h)	携行利用型線量表示器100 線量率 (μ Sv/h)
1	64.441					11.852	11.917			
2	65.067					12.066	12.132			
3	65.379					12.057	12.028			
4	65.376					12.076	12.014			
5	65.602					12.146	12.075			
6	65.377					12.088	12.050			
7	64.701					11.827	11.829			
8	65.289					11.988	11.978			
9	65.599					12.134	12.106			
10	65.870					12.248	12.230			
11	65.548					12.080	11.977			
12	65.203					11.920	11.775			
13	65.193					11.915	11.729			
14	65.713					12.062	11.983			
15	65.091					11.799	11.762			
16	65.036					11.835	11.759			
17	65.361					11.909	11.844			
18	65.713					12.008	11.925			
19	65.911					12.034	11.950			
20	65.931					12.055	11.968			
21	64.398					11.652	11.692			
22	64.865					11.818	11.784			
23	65.455					12.010	11.987			
24	66.048					12.177	12.171			
25	66.459					12.209	12.209			
26	66.589					12.262	12.256			
27	66.604					12.343	12.423			
28	68.144					12.401	12.441			
29	68.837					12.070	12.054			
30	69.129					12.062	12.044			
31	69.249					12.104	12.080			
1ヶ月値	65.909					12.039	12.006			
最大値	70.138					12.680	12.807			
最大値日時	05/28 15:00					05/28 15:10	05/28 15:50			
最小値	62.941					11.212	11.337			
最小値日時	05/21 13:40					05/21 15:10	05/13 03:20			