

承認	審査	作成

J1東タンクエリア点検マンホール等における放射線測定
J1東タンクエリア線量測定結果 (mSv/h)

BG 0.002mSV/h

測定日 2020.3.4 9:16~10:50

測定器番号 F1-ICWBL-165

測定器番号 F1-ICWBL-139

対象なし

タンク名	点検用マンホール	管台(配管取り出し)				連絡弁1			連絡弁2			連絡弁3			連絡弁4			引出し&予備			その他
		①	②	③	④	フランジ1	フランジ2	グラウンド	フランジ1	フランジ2	グラウンド	フランジ1	フランジ2	グラウンド	フランジ1	フランジ2	グラウンド	フランジ1	フランジ2	グラウンド	
J1-A1	0.007	A-1	A-16	A-101																	
		0.004	0.005	0.004		0.004	0.004	0.004	0.005	0.005	0.005							0.004	0.003	0.003	
J1-A2	0.003	A-2	A-3																		
		0.003	0.003			0.003	0.003	0.004	0.003	0.003	0.004										
J1-A3	0.004	A-4	A-5	A-7																	
		0.003	0.003	0.003		0.003	0.004	0.004	0.003	0.003	0.003	0.003	0.003	0.003							
J1-A4	0.005	A-6																			
		0.005				0.005	0.005	0.003													
J1-A5	0.002	A-8	A-9	AB-1																	
		0.003	0.005	0.004		0.003	0.003	0.003	0.005	0.005	0.005				0.004	0.004	0.004				
J1-A6	0.003	A-10	A-11																		
		0.003	0.003	0.004		0.003	0.003	0.003	0.004	0.004	0.004										
J1-A7	0.004	A-12	A-13	A-15																	
		0.003	0.004	0.005		0.003	0.003	0.003	0.004	0.003	0.003	0.005	0.005	0.005							
J1-A8	0.004	A-14	AB-3																		
		0.004	0.004			0.004	0.004	0.004							0.004	0.004	0.004				
J1-B1	0.015	B-1	BC-1	B-101																	
		0.007	0.005	0.008		0.007	0.007	0.007							0.005	0.004	0.003	0.008	0.003	0.005	
J1-B2	0.230	B-2	B-3	AB-4																	
		0.007	0.007	0.004		0.007	0.007	0.007	0.007	0.010	0.027				0.004	0.004	0.004				
J1-B3	0.200	B-4	B-5	B-16																	
		0.005	0.005	0.006		0.005	0.005	0.015	0.005	0.005	0.005	0.006	0.006	0.007							
J1-B4	0.050	B-6	B-7	BC-3																	
		0.007	0.006	0.008		0.007	0.007	0.008	0.006	0.008	0.040				0.008	0.003	0.004				
J1-B5	0.020	B-8	B-9																		
		0.006	0.006			0.006	0.007	0.050	0.006	0.015	0.200										
J1-B6	0.300	B-10	B-11	BC-5																	
		0.015	0.006	0.004		0.015	0.025	1.700	0.006	0.008	0.120				0.004	0.004	0.004				
J1-B7	0.065	B-12	B-13	AB-2																	
		0.008	0.008	0.005		0.008	0.007	0.250	0.008	0.008	0.260				0.005	0.005	0.005				
J1-B8	0.400	B-14	B-15																		
		0.007	0.008			0.007	0.007	0.130	0.008	0.007	0.010										
J1-C1	0.004	C-1	C-18	BC-2	C-101																
		0.007	0.003	0.004	0.004	0.007	0.007	0.007	0.003	0.004	0.003				0.004	0.004	0.003	0.004	0.005	0.003	
J1-C2	0.002	C-2	C-3																		
		0.004	0.003			0.003	0.003	0.003							0.004	0.003	0.004				
J1-C3	0.002	C-4	C-5																		
		0.004	0.003			0.004	0.003	0.003	0.003	0.003	0.002										
J1-C4	0.003	C-6	C-7	C-13	C-予備1																
		0.004	0.003	0.004	0.006	0.004	0.003	0.004	0.003	0.003	0.005	0.004	0.002	0.003				0.006	0.010	0.006	
J1-C5	0.003	C-8	C-9	BC-4	C-予備2																
		0.003	0.003	0.003	0.004	0.003	0.003	0.003	0.003	0.003	0.004				0.004	0.004	0.004	0.003	0.003	0.002	
J1-C6	0.002	C-10	C-11																		
		0.003	0.003			0.003	0.003	0.003	0.003	0.003	0.003										
J1-C7	0.002	C-12	BC-6																		
		0.003	0.003			0.003	0.003	0.003							0.003	0.003	0.003				
J1-C8	0.003	C-14	C-15																		
		0.003	0.003			0.003	0.003	0.003	0.003	0.003	0.003										
J1-C9	0.003	C-16	C-17																		
		0.003	0.003			0.003	0.003	0.003	0.003	0.002	0.003										
J1-N1	0.001	N-1	N-6																		
		0.001	0.001			0.001	0.001	0.001	0.001	0.001	0.001										
J1-N2	0.001	N-2	N-3																		
		0.001	0.001			0.001	0.001	0.001	0.001	0.001	0.001										
J1-N3	0.002	N-4	N-5	CN-1																	
		0.001	0.001	0.002		0.001	0.001	0.001	0.001	0.001	0.001				0.002	0.001	0.002				

