

運用部 運用支援G

承認	審査	作成
2020.6.5	2020.6.5	2020.6.5

各建屋滞留水移送ライン近傍線量率データ(月報)

2020年 5月分

各建屋滞留水移送ライン近傍線量率データ(2020年5月分)

月日	2号T/B出口 ($\mu\text{Sv/h}$)	3号T/B入口 ($\mu\text{Sv/h}$)	4号T/B出口 ($\mu\text{Sv/h}$)	HTI建屋入口 ($\mu\text{Sv/h}$)	プロセス主建屋入口 ($\mu\text{Sv/h}$)	焼却工作建屋出口 ($\mu\text{Sv/h}$)	備考
5/1	1.47E+02	7.40E+02	3.35E+01	5.15E+01	2.03E+01	2.92E+01	
5/2	1.51E+02	7.88E+02	3.34E+01	5.14E+01	2.01E+01	2.92E+01	
5/3	1.52E+02	8.04E+02	3.29E+01	5.14E+01	1.97E+01	2.93E+01	
5/4	1.50E+02	7.83E+02	3.28E+01	5.13E+01	1.98E+01	2.92E+01	
5/5	1.51E+02	7.74E+02	3.27E+01	5.16E+01	2.00E+01	2.92E+01	
5/6	1.49E+02	7.75E+02	3.24E+01	5.15E+01	1.99E+01	2.91E+01	
5/7	1.35E+02	5.69E+02	2.89E+01	5.14E+01	1.72E+01	2.92E+01	
5/8	1.41E+02	6.62E+02	3.00E+01	5.18E+01	1.82E+01	2.90E+01	
5/9	1.44E+02	7.20E+02	3.24E+01	5.13E+01	1.99E+01	2.92E+01	
5/10	1.41E+02	7.28E+02	3.23E+01	5.03E+01	1.96E+01	2.88E+01	
5/11	1.42E+02	6.44E+02	3.02E+01	5.14E+01	1.82E+01	2.93E+01	
5/12	1.44E+02	6.70E+02	3.04E+01	5.12E+01	1.85E+01	2.91E+01	
5/13	1.44E+02	6.80E+02	2.81E+01	5.12E+01	1.69E+01	2.88E+01	
5/14	1.39E+02	6.81E+02	2.86E+01	5.12E+01	1.68E+01	2.89E+01	
5/15	1.38E+02	6.89E+02	2.93E+01	5.15E+01	1.76E+01	2.88E+01	
5/16	1.37E+02	6.80E+02	3.08E+01	5.13E+01	1.90E+01	2.87E+01	
5/17	1.37E+02	6.84E+02	3.14E+01	5.13E+01	1.90E+01	2.88E+01	
5/18	1.45E+02	8.61E+02	2.97E+01	5.22E+01	1.86E+01	2.83E+01	
5/19	1.30E+02	8.33E+02	2.54E+01	4.90E+01	1.65E+01	2.69E+01	
5/20	1.00E+02	5.69E+02	2.45E+01	5.04E+01	1.66E+01	2.65E+01	
5/21	7.73E+01	7.97E+02	2.53E+01	5.12E+01	1.66E+01	2.64E+01	
5/22	6.65E+01	5.97E+02	2.19E+01	5.31E+01	1.41E+01	2.60E+01	
5/23	7.13E+01	7.47E+02	2.43E+01	5.13E+01	1.60E+01	2.61E+01	
5/24	6.94E+01	6.52E+02	2.56E+01	5.27E+01	1.70E+01	2.65E+01	
5/25	7.19E+01	4.99E+02	2.24E+01	5.37E+01	1.47E+01	2.65E+01	
5/26	7.42E+01	5.64E+02	2.53E+01	5.38E+01	1.73E+01	2.63E+01	
5/27	5.77E+01	6.93E+02	2.61E+01	5.45E+01	1.73E+01	2.65E+01	
5/28	5.27E+01	5.80E+02	2.44E+01	5.46E+01	1.63E+01	2.65E+01	
5/29	5.24E+01	6.08E+02	2.58E+01	5.49E+01	1.74E+01	2.65E+01	
5/30	5.76E+01	8.00E+02	2.72E+01	5.50E+01	1.77E+01	2.65E+01	
5/31	5.84E+01	8.37E+02	2.82E+01	5.50E+01	1.82E+01	2.65E+01	