

構内連続ダストモニタ測定記録(2020 年 6 月)

※表中、最大値・最小値に関しては、BG 測定による影響があるため値は参考値扱いとする。

測定月報

測定日：2020/06

(1/8)

日	モニタ											
	A001 正門警備所			A002 正門警備所			A003 免震重要棟			A004 免震重要棟		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.39E-06	1.3	100	1.50E-06	0.9	100	1.33E-06	7.8	100	1.39E-06	7.9	100
2	1.26E-06	1.3	100	1.35E-06	0.9	100	1.11E-06	7.8	100	1.14E-06	7.9	100
3	*1 3.89E-06	1.3	100	4.22E-06	0.9	100	3.76E-06	7.8	100	3.88E-06	7.9	100
4	3.58E-06	1.3	100	*1 3.87E-06	0.9	100	3.16E-06	7.8	100	3.25E-06	7.9	100
5	7.04E-06	1.3	100	7.61E-06	0.9	100	6.00E-06	7.8	100	6.24E-06	7.9	100
6	3.70E-06	1.3	100	3.99E-06	0.9	100	3.40E-06	7.8	100	3.54E-06	7.9	100
7	3.80E-06	1.3	100	4.13E-06	0.9	100	3.67E-06	7.8	100	3.73E-06	7.9	100
8	3.00E-06	1.3	100	3.31E-06	0.9	100	2.66E-06	7.8	100	2.80E-06	7.9	100
9	6.52E-06	1.3	100	7.02E-06	0.9	100	5.65E-06	7.8	100	*1 5.94E-06	7.9	100
10	4.74E-06	1.3	100	5.06E-06	0.9	100	*1 3.93E-06	7.7	100	3.98E-06	7.9	100
11	1.33E-06	1.3	100	1.47E-06	0.9	100	1.18E-06	7.6	100	1.09E-06	7.9	100
12	4.70E-06	1.3	100	5.17E-06	0.9	100	3.75E-06	7.6	100	3.83E-06	7.9	100
13	6.70E-06	1.3	100	7.24E-06	0.9	100	5.55E-06	7.6	100	5.70E-06	7.9	100
14	5.13E-06	1.3	100	5.66E-06	0.9	100	4.53E-06	7.6	100	4.60E-06	7.9	100
15	5.06E-06	1.3	100	5.56E-06	0.9	100	4.67E-06	7.6	100	4.79E-06	7.9	100
16	5.82E-06	1.3	100	6.42E-06	0.9	100	5.32E-06	7.6	100	5.56E-06	7.9	100
17	2.37E-06	1.3	100	2.59E-06	0.9	100	2.30E-06	7.6	100	2.33E-06	7.9	100
18	4.69E-06	1.3	100	5.07E-06	0.9	100	4.33E-06	7.6	100	4.50E-06	7.9	100
19	6.00E-06	1.3	100	6.50E-06	0.9	100	5.32E-06	7.6	100	5.50E-06	7.9	100
20	4.31E-06	1.3	100	4.71E-06	0.9	100	3.96E-06	7.6	100	4.03E-06	7.9	100
21	2.97E-06	1.3	100	3.21E-06	0.9	100	2.50E-06	7.6	100	2.54E-06	7.9	100
22	4.47E-06	1.3	100	4.91E-06	0.9	100	3.78E-06	7.6	100	3.84E-06	7.9	100
23	1.38E-06	1.3	100	1.51E-06	0.9	100	1.28E-06	7.6	100	1.24E-06	7.9	100
24	6.30E-07	1.3	100	6.98E-07	0.9	100	5.41E-07	7.6	100	5.08E-07	7.9	100
25	4.53E-07	1.3	100	5.28E-07	0.9	100	3.68E-07	7.6	100	3.07E-07	7.9	100
26	8.89E-07	1.3	100	1.02E-06	0.9	100	7.36E-07	7.6	100	6.86E-07	7.9	100
27	3.36E-06	1.3	100	3.67E-06	0.9	100	2.94E-06	7.6	100	3.04E-06	7.9	100
28	7.66E-06	1.3	100	8.37E-06	0.9	100	6.97E-06	7.6	100	7.13E-06	7.9	100
29	*1 3.85E-06	1.3	100	4.19E-06	0.9	100	3.24E-06	7.6	100	3.30E-06	7.9	100
30	5.52E-06	1.3	100	6.03E-06	0.9	100	4.84E-06	7.6	100	4.97E-06	7.9	100
31												
1ヶ月値	3.88E-06	1.3	100	4.22E-06	0.9	100	3.43E-06	7.7	100	3.51E-06	7.9	100
最大値	2.16E-05	1.3	102	2.30E-05	0.9	102	1.92E-05	7.8	102	1.91E-05	7.9	105
最大値日時	06/30 04:25	06/01 00:01	06/01 22:07	06/30 04:29	06/01 00:01	06/03 15:28	06/30 04:27	06/01 00:01	06/04 19:15	06/30 04:09	06/01 00:01	06/09 09:18
最小値	0.00E+00	1.3	98	0.00E+00	0.9	98	0.00E+00	7.6	98	0.00E+00	7.9	98
最小値日時	06/01 16:57	06/01 00:01	06/03 00:44	06/01 16:55	06/01 00:01	06/01 13:38	06/01 16:40	06/10 09:25	06/11 04:34	06/01 16:37	06/01 00:01	06/01 21:26

*1:ろ紙交換

測定月報

測定日：2020/06

(2/8)

日	モニタ											
	A005 5/6号警備所前			A006 5/6号警備所前			A007 1号北側法面上(旧厚生棟)			A008 1号北側法面上(旧厚生棟)		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.70E-06	3.1	100	1.56E-06	1.5	100	1.51E-06	9.3	100	1.50E-06	6.8	100
2	1.24E-06	3.1	100	1.13E-06	1.5	100	1.13E-06	9.3	100	1.10E-06	6.8	100
3	4.17E-06	3.1	100	3.82E-06	1.5	100	3.69E-06	9.3	100	3.97E-06	6.8	100
4	3.45E-06	3.1	100	3.14E-06	1.5	100	3.06E-06	9.3	100	3.31E-06	6.8	100
5	5.57E-06	3.1	100	5.10E-06	1.5	100	5.14E-06	9.3	100	5.59E-06	6.8	100
6	3.74E-06	3.1	100	3.41E-06	1.5	100	3.23E-06	9.3	100	3.50E-06	6.8	100
7	4.17E-06	3.1	100	3.78E-06	1.5	100	3.52E-06	9.3	100	3.78E-06	6.8	100
8	2.91E-06	3.1	100	2.66E-06	1.5	100	2.53E-06	9.3	100	2.70E-06	6.8	100
9	6.36E-06	3.1	100	5.82E-06	1.5	100	*1 5.56E-06	9.2	100	5.99E-06	6.8	100
10	3.88E-06	3.1	100	*1 3.52E-06	1.6	100	3.54E-06	9.2	100	3.84E-06	6.8	100
11	1.15E-06	3.1	100	9.53E-07	1.6	100	1.11E-06	9.2	100	1.06E-06	6.8	100
12	3.55E-06	3.1	100	3.17E-06	1.6	100	3.23E-06	9.2	100	3.50E-06	6.8	100
13	5.94E-06	3.1	100	5.29E-06	1.6	100	5.17E-06	9.2	100	5.71E-06	6.8	100
14	5.90E-06	3.1	100	5.32E-06	1.6	100	4.96E-06	9.2	100	5.42E-06	6.8	100
15	5.10E-06	3.1	100	4.69E-06	1.6	100	4.38E-06	9.2	100	4.76E-06	6.8	100
16	6.27E-06	3.1	100	5.71E-06	1.6	100	5.42E-06	9.2	100	5.71E-06	6.8	100
17	*1 2.74E-06	3.0	100	2.39E-06	1.6	100	2.29E-06	9.2	100	*1 2.45E-06	6.6	100
18	4.85E-06	3.0	100	4.45E-06	1.6	100	4.29E-06	9.2	100	4.81E-06	6.5	100
19	5.78E-06	3.0	100	5.23E-06	1.6	100	5.08E-06	9.2	100	5.60E-06	6.5	100
20	4.30E-06	3.0	100	3.88E-06	1.6	100	3.84E-06	9.2	100	4.24E-06	6.5	100
21	2.77E-06	3.0	100	2.46E-06	1.6	100	2.48E-06	9.2	100	2.65E-06	6.5	100
22	4.33E-06	3.0	100	3.94E-06	1.6	100	3.69E-06	9.2	100	4.07E-06	6.5	100
23	1.47E-06	3.0	100	1.25E-06	1.6	100	1.31E-06	9.2	100	1.40E-06	6.5	100
24	6.57E-07	3.0	100	5.19E-07	1.6	100	6.13E-07	9.2	100	6.30E-07	6.5	100
25	4.82E-07	3.0	100	3.58E-07	1.6	100	4.62E-07	9.2	100	4.78E-07	6.5	100
26	8.46E-07	3.0	100	6.89E-07	1.6	100	7.79E-07	9.2	100	8.47E-07	6.5	100
27	2.96E-06	3.0	100	2.63E-06	1.6	100	2.69E-06	9.2	100	2.97E-06	6.5	100
28	7.79E-06	3.0	100	6.98E-06	1.6	100	6.80E-06	9.2	100	7.73E-06	6.5	100
29	3.59E-06	3.0	100	3.25E-06	1.6	100	3.18E-06	9.2	100	3.58E-06	6.5	100
30	5.63E-06	3.0	100	5.05E-06	1.6	100	4.72E-06	9.2	100	5.29E-06	6.5	100
31												
1ヶ月値	3.78E-06	3.1	100	3.41E-06	1.6	100	3.31E-06	9.2	100	3.61E-06	6.7	100
最大値	2.05E-05	3.1	102	1.80E-05	1.6	102	1.71E-05	9.3	102	1.88E-05	6.8	101
最大値日時	06/30 04:22	06/01 00:01	06/05 00:40	06/30 04:21	06/10 10:47	06/01 02:49	06/30 04:10	06/01 00:01	06/01 04:01	06/30 04:06	06/01 00:01	06/01 00:11
最小値	0.00E+00	3.0	98	0.00E+00	1.5	97	0.00E+00	9.2	97	0.00E+00	6.5	99
最小値日時	06/01 16:16	06/17 11:16	06/01 01:04	06/01 16:12	06/01 00:01	06/21 04:33	06/01 15:58	06/09 11:20	06/09 04:23	06/01 15:56	06/17 10:50	06/01 00:27

*1: ろ紙交換

測定月報

測定日：2020/06

(3/8)

日	モニタ											
	A009			A010			A011			A012		
	1/2号西側法面上			1/2号西側法面上			3/4号西側法面上			3/4号西側法面上		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.44E-06	5.4	100	1.61E-06	7.5	100	1.54E-06	4.3	100	1.65E-06	3.8	100
2	1.12E-06	5.4	100	1.35E-06	7.5	100	1.27E-06	4.3	100	1.38E-06	3.8	100
3	4.04E-06	5.4	100	4.26E-06	7.5	100	4.12E-06	4.3	100	4.34E-06	3.8	100
4	*1 3.33E-06	5.3	100	3.51E-06	7.5	100	3.39E-06	4.3	100	3.62E-06	3.8	100
5	6.22E-06	5.3	100	6.27E-06	7.5	100	6.14E-06	4.3	100	6.49E-06	3.8	100
6	3.68E-06	5.3	100	3.83E-06	7.5	100	3.71E-06	4.3	100	3.89E-06	3.8	100
7	3.92E-06	5.3	100	4.02E-06	7.5	100	3.88E-06	4.3	100	4.15E-06	3.8	100
8	2.87E-06	5.3	100	2.98E-06	7.5	100	2.90E-06	4.3	100	3.14E-06	3.8	100
9	6.24E-06	5.3	100	6.27E-06	7.5	100	6.25E-06	4.3	100	6.61E-06	3.8	100
10	4.18E-06	5.3	100	4.23E-06	7.5	100	*1 4.23E-06	4.2	100	4.31E-06	3.8	100
11	1.22E-06	5.3	100	1.31E-06	7.5	100	1.42E-06	4.1	100	1.42E-06	3.8	100
12	3.93E-06	5.3	100	*8 4.03E-06	6.8	100	4.36E-06	4.1	100	4.33E-06	3.8	100
13	6.02E-06	5.3	100	5.57E-06	5.9	100	6.31E-06	4.1	100	6.33E-06	3.8	100
14	5.14E-06	5.3	100	4.80E-06	5.9	100	5.26E-06	4.1	100	5.32E-06	3.8	100
15	5.10E-06	5.3	100	4.73E-06	5.9	100	5.34E-06	4.1	100	5.39E-06	3.8	100
16	6.00E-06	5.3	100	5.61E-06	5.9	100	6.16E-06	4.1	100	6.23E-06	3.8	100
17	2.46E-06	5.3	100	2.36E-06	5.9	100	2.67E-06	4.1	100	2.65E-06	3.8	100
18	4.85E-06	5.3	100	4.57E-06	5.9	100	5.06E-06	4.1	100	5.16E-06	3.8	100
19	5.77E-06	5.3	100	5.41E-06	5.9	100	5.99E-06	4.1	100	5.98E-06	3.8	100
20	4.27E-06	5.3	100	4.02E-06	5.9	100	4.52E-06	4.1	100	4.60E-06	3.8	100
21	2.69E-06	5.3	100	2.54E-06	5.9	100	2.95E-06	4.1	100	3.01E-06	3.8	100
22	3.98E-06	5.3	100	3.82E-06	5.9	100	4.28E-06	4.1	100	4.37E-06	3.8	100
23	1.34E-06	5.3	100	1.32E-06	5.9	100	1.49E-06	4.1	100	*1 1.49E-06	3.9	100
24	5.64E-07	5.3	100	6.02E-07	5.9	100	7.17E-07	4.1	100	6.60E-07	3.9	100
25	4.10E-07	5.3	100	4.42E-07	5.9	100	5.81E-07	4.1	100	4.97E-07	3.9	100
26	7.86E-07	5.3	100	7.95E-07	5.9	100	9.50E-07	4.1	100	8.87E-07	3.9	100
27	3.11E-06	5.3	100	2.92E-06	5.9	100	3.29E-06	4.1	100	3.32E-06	3.9	100
28	7.50E-06	5.3	100	7.08E-06	5.9	100	7.96E-06	4.1	100	8.16E-06	3.9	100
29	3.55E-06	5.3	100	3.33E-06	5.9	100	3.74E-06	4.1	100	3.79E-06	3.9	100
30	5.32E-06	5.3	100	4.93E-06	5.9	100	5.38E-06	4.1	100	5.42E-06	3.9	100
31												
1ヶ月値	3.70E-06	5.3	100	3.62E-06	6.5	100	3.86E-06	4.2	100	3.95E-06	3.8	100
最大値	1.93E-05	5.4	101	1.86E-05	7.5	102	1.95E-05	4.3	102	2.01E-05	3.9	102
最大値日時	06/30 04:12	06/01 00:01	06/01 01:16	06/05 05:26	06/01 00:01	06/13 21:24	06/22 05:02	06/01 00:01	06/04 00:37	06/22 05:11	06/23 10:03	06/09 22:28
最小値	0.00E+00	5.3	99	0.00E+00	5.9	98	0.00E+00	4.1	98	0.00E+00	3.8	98
最小値日時	06/01 15:02	06/04 08:48	06/01 00:04	06/01 14:57	06/12 13:33	06/12 13:34	06/01 16:23	06/10 10:18	06/02 00:00	06/01 16:20	06/01 00:01	06/01 02:49

*1: ろ紙交換 *8: 機器異常

測定月報

測定日：2020/06

(4/8)

日	モニタ											
	A013 4号南側法面上[3号南側]			A014 4号南側法面上[3号南側]			A015 登録C休憩所			A016 登録C休憩所		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.33E-06	6.6	100	1.57E-06	1.3	100	1.42E-06	2.2	100	1.53E-06	2.0	100
2	1.06E-06	6.6	100	1.25E-06	1.3	100	1.31E-06	2.2	100	1.39E-06	2.0	100
3	3.81E-06	6.6	100	4.43E-06	1.3	100	3.96E-06	2.2	100	4.12E-06	2.0	100
4	3.16E-06	6.6	100	3.66E-06	1.3	100	3.60E-06	2.2	100	3.76E-06	2.0	100
5	5.52E-06	6.6	100	6.43E-06	1.3	100	7.14E-06	2.2	100	7.38E-06	2.0	100
6	3.35E-06	6.6	100	3.90E-06	1.3	100	3.77E-06	2.2	100	3.98E-06	2.0	100
7	3.55E-06	6.6	100	4.15E-06	1.3	100	3.92E-06	2.2	100	4.13E-06	2.0	100
8	2.70E-06	6.6	100	3.14E-06	1.3	100	3.16E-06	2.2	100	3.32E-06	2.0	100
9	5.87E-06	6.6	100	6.72E-06	1.3	100	*1 6.72E-06	2.1	100	6.81E-06	2.0	100
10	3.80E-06	6.6	100	*1 4.49E-06	1.2	100	4.89E-06	2.1	100	5.09E-06	2.0	100
11	1.07E-06	6.6	100	1.33E-06	1.2	100	1.42E-06	2.1	100	1.46E-06	2.0	100
12	3.69E-06	6.6	100	4.30E-06	1.2	100	4.70E-06	2.1	100	4.87E-06	2.0	100
13	5.61E-06	6.6	100	6.51E-06	1.2	100	6.80E-06	2.1	100	7.01E-06	2.0	100
14	4.72E-06	6.6	100	5.60E-06	1.2	100	5.28E-06	2.1	100	5.44E-06	2.0	100
15	4.57E-06	6.6	100	5.46E-06	1.2	100	5.23E-06	2.1	100	5.38E-06	2.0	100
16	5.46E-06	6.6	100	6.44E-06	1.2	100	5.98E-06	2.1	100	6.15E-06	2.0	100
17	2.22E-06	6.6	100	2.68E-06	1.2	100	2.50E-06	2.1	100	*1 2.58E-06	2.1	100
18	4.52E-06	6.6	100	5.43E-06	1.2	100	4.71E-06	2.1	100	4.87E-06	2.1	100
19	5.24E-06	6.6	100	6.21E-06	1.2	100	6.17E-06	2.1	100	6.33E-06	2.1	100
20	3.91E-06	6.6	100	4.64E-06	1.2	100	4.54E-06	2.1	100	4.64E-06	2.1	100
21	2.43E-06	6.6	100	2.97E-06	1.2	100	3.11E-06	2.1	100	3.15E-06	2.1	100
22	3.71E-06	6.6	100	4.37E-06	1.2	100	4.80E-06	2.1	100	4.99E-06	2.1	100
23	*1 1.26E-06	6.5	100	1.53E-06	1.2	100	1.49E-06	2.1	100	1.48E-06	2.1	100
24	6.40E-07	6.4	100	7.60E-07	1.2	100	6.63E-07	2.1	100	6.35E-07	2.1	100
25	4.45E-07	6.4	100	5.45E-07	1.2	100	5.41E-07	2.1	100	4.94E-07	2.1	100
26	7.83E-07	6.4	100	9.43E-07	1.2	100	1.00E-06	2.1	100	9.86E-07	2.1	100
27	2.81E-06	6.4	100	3.29E-06	1.2	100	3.49E-06	2.1	100	3.59E-06	2.1	100
28	7.39E-06	6.4	100	8.47E-06	1.2	100	7.79E-06	2.1	100	8.04E-06	2.1	100
29	3.35E-06	6.4	100	3.87E-06	1.2	100	3.82E-06	2.1	100	3.95E-06	2.1	100
30	4.80E-06	6.4	100	5.59E-06	1.2	100	5.65E-06	2.1	100	5.75E-06	2.1	100
31												
1ヶ月値	3.43E-06	6.5	100	4.02E-06	1.2	100	3.96E-06	2.1	100	4.11E-06	2.0	100
最大値	1.84E-05	6.6	102	2.06E-05	1.3	101	2.11E-05	2.2	102	2.22E-05	2.1	101
最大値日時	06/22 05:07	06/01 00:01	06/01 00:28	06/30 04:41	06/01 00:01	06/01 00:02	06/30 04:14	06/01 00:01	06/04 06:29	06/22 04:51	06/17 09:37	06/01 00:07
最小値	0.00E+00	6.4	97	0.00E+00	1.2	98	0.00E+00	2.1	98	0.00E+00	2.0	98
最小値日時	06/01 15:55	06/23 10:26	06/19 09:25	06/01 15:52	06/10 10:06	06/01 22:15	06/01 16:39	06/09 09:50	06/06 18:21	06/01 16:36	06/01 00:01	06/01 17:53

*1:ろ紙交換

測定月報

測定日：2020/06

(5/8)

日	モニタ											
	A017 旧情報棟			A018 旧情報棟			A019 シールド中央制御室			A020 シールド中央制御室		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.43E-06	5.7	100	1.52E-06	5.3	100	1.33E-06	2.9	100	1.21E-06	2.8	100
2	1.12E-06	5.7	100	1.21E-06	5.3	100	1.12E-06	2.9	100	1.01E-06	2.8	100
3	3.60E-06	5.7	100	3.90E-06	5.3	100	3.85E-06	2.9	100	3.67E-06	2.8	100
4	3.02E-06	5.7	100	3.30E-06	5.3	100	3.22E-06	2.9	100	3.01E-06	2.8	100
5	5.32E-06	5.7	100	5.72E-06	5.3	100	5.78E-06	2.9	100	5.51E-06	2.8	100
6	3.20E-06	5.7	100	3.46E-06	5.3	100	3.38E-06	2.9	100	3.26E-06	2.8	100
7	3.47E-06	5.7	100	3.71E-06	5.3	100	3.59E-06	2.9	100	3.43E-06	2.8	100
8	2.52E-06	5.7	100	2.72E-06	5.3	100	2.74E-06	2.9	100	2.61E-06	2.8	100
9	5.62E-06	5.7	100	*1 6.08E-06	5.2	100	5.93E-06	2.9	100	5.66E-06	2.8	100
10	3.73E-06	5.7	100	4.00E-06	5.2	100	3.96E-06	2.9	100	*1 3.84E-06	2.7	100
11	1.18E-06	5.7	100	1.29E-06	5.2	100	1.11E-06	2.9	100	1.10E-06	2.6	100
12	3.12E-06	5.7	100	3.40E-06	5.2	100	3.79E-06	2.9	100	3.72E-06	2.6	100
13	5.23E-06	5.7	100	5.61E-06	5.2	100	5.70E-06	2.9	100	5.44E-06	2.6	100
14	4.74E-06	5.7	100	5.05E-06	5.2	100	4.76E-06	2.9	100	4.54E-06	2.6	100
15	4.61E-06	5.7	100	5.01E-06	5.2	100	4.58E-06	2.9	100	4.46E-06	2.6	100
16	5.29E-06	5.7	100	5.76E-06	5.2	100	5.42E-06	2.9	100	5.30E-06	2.6	100
17	*1 2.31E-06	5.7	100	2.50E-06	5.2	100	*1 2.23E-06	2.8	100	2.19E-06	2.6	100
18	4.22E-06	5.7	100	4.61E-06	5.2	100	4.45E-06	2.8	100	4.37E-06	2.6	100
19	4.83E-06	5.7	100	5.39E-06	5.2	100	5.28E-06	2.8	100	5.18E-06	2.6	100
20	3.78E-06	5.7	100	4.11E-06	5.2	100	4.02E-06	2.8	100	3.92E-06	2.6	100
21	2.44E-06	5.7	100	2.69E-06	5.2	100	2.59E-06	2.8	100	2.52E-06	2.6	100
22	3.50E-06	5.7	100	3.86E-06	5.2	100	3.83E-06	2.8	100	3.70E-06	2.6	100
23	1.24E-06	5.7	100	1.42E-06	5.2	100	1.30E-06	2.8	100	1.24E-06	2.6	100
24	5.04E-07	5.7	100	6.10E-07	5.2	100	5.85E-07	2.8	100	5.72E-07	2.6	100
25	3.56E-07	5.7	100	4.53E-07	5.2	100	4.58E-07	2.8	100	4.39E-07	2.6	100
26	6.62E-07	5.7	100	7.75E-07	5.2	100	7.91E-07	2.8	100	7.61E-07	2.6	100
27	2.88E-06	5.7	100	3.14E-06	5.2	100	2.79E-06	2.8	100	2.77E-06	2.6	100
28	7.00E-06	5.7	100	7.57E-06	5.2	100	7.22E-06	2.8	100	7.04E-06	2.6	100
29	3.15E-06	5.7	100	3.41E-06	5.2	100	3.35E-06	2.8	100	3.32E-06	2.6	100
30	4.69E-06	5.7	100	5.01E-06	5.2	100	4.87E-06	2.8	100	4.78E-06	2.6	100
31												
1ヶ月値	3.29E-06	5.7	100	3.58E-06	5.2	100	3.47E-06	2.9	100	3.35E-06	2.7	100
最大値	1.78E-05	5.7	102	2.83E-05	5.3	101	1.88E-05	2.9	101	1.82E-05	2.8	124
最大値日時	06/30 04:32	06/01 00:01	06/13 09:34	06/09 10:27	06/01 00:01	06/01 00:29	06/30 04:38	06/01 00:01	06/01 00:10	06/30 04:37	06/01 00:01	06/01 16:00
最小値	0.00E+00	5.7	98	0.00E+00	5.2	99	0.00E+00	2.8	99	0.00E+00	2.6	98
最小値日時	06/01 15:34	06/01 00:01	06/05 17:27	06/01 15:39	06/09 10:27	06/01 00:05	06/01 16:04	06/17 10:36	06/01 00:32	06/01 16:01	06/10 10:00	06/10 01:22

*1:ろ紙交換

測定月報

測定日：2020/06

(6/8)

日	モニタ											
	A021 Hタンクエリア			A022 Hタンクエリア			A023 2u西側			A024 2u西側		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.45E-06	2.5	100	1.39E-06	2.1	100	1.76E-06	17.4	100	1.57E-06	13.9	100
2	1.24E-06	2.5	100	1.19E-06	2.1	100	1.22E-06	17.4	100	1.23E-06	13.9	100
3	4.03E-06	2.5	100	3.78E-06	2.1	100	*1 3.96E-06	17.4	100	3.70E-06	13.9	100
4	*1 3.43E-06	2.5	100	3.30E-06	2.1	100	3.18E-06	17.4	100	3.08E-06	13.9	100
5	6.60E-06	2.5	100	6.26E-06	2.1	100	5.81E-06	17.4	100	5.50E-06	13.9	100
6	3.76E-06	2.5	100	3.51E-06	2.1	100	3.58E-06	17.4	100	3.46E-06	13.9	100
7	3.84E-06	2.5	100	3.67E-06	2.1	100	3.79E-06	17.4	100	3.67E-06	13.9	100
8	3.03E-06	2.5	100	2.83E-06	2.1	100	2.67E-06	17.4	100	2.66E-06	13.9	100
9	6.48E-06	2.5	100	6.07E-06	2.1	100	6.07E-06	17.4	100	5.80E-06	13.9	100
10	4.33E-06	2.5	100	4.05E-06	2.1	100	3.93E-06	17.4	100	*1 3.96E-06	14.0	100
11	1.29E-06	2.5	100	1.24E-06	2.1	100	1.17E-06	17.4	100	1.21E-06	14.0	100
12	4.37E-06	2.5	100	4.16E-06	2.1	100	3.60E-06	17.4	100	3.46E-06	14.0	100
13	6.52E-06	2.5	100	6.11E-06	2.1	100	5.75E-06	17.4	100	5.33E-06	14.0	100
14	5.15E-06	2.5	100	4.91E-06	2.1	100	5.17E-06	17.4	100	4.79E-06	14.0	100
15	5.12E-06	2.5	100	4.84E-06	2.1	100	4.80E-06	17.4	100	4.62E-06	14.0	100
16	5.98E-06	2.5	100	5.64E-06	2.1	100	5.79E-06	17.4	100	5.49E-06	14.0	100
17	2.47E-06	2.5	100	*1 2.29E-06	2.2	100	2.35E-06	17.4	100	2.34E-06	14.0	100
18	4.95E-06	2.5	100	4.48E-06	2.2	100	4.73E-06	17.4	100	4.40E-06	14.0	100
19	5.82E-06	2.5	100	5.39E-06	2.2	100	5.46E-06	17.4	100	5.09E-06	14.0	100
20	4.44E-06	2.5	100	4.09E-06	2.2	100	4.01E-06	17.4	100	3.83E-06	14.0	100
21	2.92E-06	2.5	100	2.69E-06	2.2	100	2.51E-06	17.4	100	2.44E-06	14.0	100
22	4.30E-06	2.5	100	4.01E-06	2.2	100	3.88E-06	17.4	100	3.68E-06	14.0	100
23	1.38E-06	2.5	100	1.24E-06	2.2	100	1.11E-06	17.4	100	1.02E-06	14.0	100
24	5.73E-07	2.5	100	4.98E-07	2.2	100	4.04E-07	17.4	100	4.44E-07	14.0	100
25	4.16E-07	2.5	100	3.64E-07	2.2	100	2.64E-07	17.4	100	3.02E-07	14.0	100
26	8.05E-07	2.5	100	7.33E-07	2.2	100	5.94E-07	17.4	100	5.80E-07	14.0	100
27	3.23E-06	2.5	100	3.02E-06	2.2	100	2.78E-06	17.4	100	2.63E-06	14.0	100
28	7.66E-06	2.5	100	7.21E-06	2.2	100	7.31E-06	17.4	100	6.88E-06	14.0	100
29	3.71E-06	2.5	100	3.44E-06	2.2	100	*1 3.62E-06	16.7	100	3.25E-06	14.0	100
30	5.34E-06	2.5	100	4.99E-06	2.2	100	5.36E-06	16.2	100	4.65E-06	14.0	100
31												
1ヶ月値	3.82E-06	2.5	100	3.58E-06	2.1	100	3.55E-06	17.3	100	3.37E-06	14.0	100
最大値	2.10E-05	2.5	102	1.98E-05	2.2	102	2.07E-05	17.4	101	1.19E-04	14.0	102
最大値日時	06/30 04:06	06/01 00:01	06/01 00:50	06/30 04:15	06/17 10:30	06/02 14:28	06/03 09:56	06/01 00:01	06/01 00:05	06/10 10:25	06/10 10:25	06/01 04:52
最小値	0.00E+00	2.5	98	0.00E+00	2.1	98	0.00E+00	16.2	99	0.00E+00	13.9	98
最小値日時	06/01 16:48	06/01 00:01	06/01 13:11	06/01 16:45	06/01 00:01	06/14 17:49	06/01 11:46	06/29 09:29	06/01 00:19	06/01 15:58	06/01 00:01	06/01 00:01

*1:ろ紙交換

測定月報

測定日：2020/06

(7/8)

日	モニタ											
	A027 1号機海側2、5m盤			A028 1号機海側2、5m盤			A029 3号機海側2、5m盤			A030 3号機海側2、5m盤		
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.61E-06	5.7	100	1.56E-06	3.9	100	1.29E-06	3.3	100	1.65E-06	5.1	100
2	1.10E-06	5.7	100	1.11E-06	3.9	100	8.70E-07	3.3	100	1.14E-06	5.1	100
3	4.11E-06	5.7	100	3.76E-06	3.9	100	3.27E-06	3.3	100	*1 4.17E-06	5.0	100
4	3.28E-06	5.7	100	3.01E-06	3.9	100	2.62E-06	3.3	100	3.34E-06	4.9	100
5	5.33E-06	5.7	100	4.82E-06	3.9	100	4.33E-06	3.3	100	5.35E-06	4.9	100
6	3.58E-06	5.7	100	3.29E-06	3.9	100	2.87E-06	3.3	100	3.65E-06	4.9	100
7	3.98E-06	5.7	100	3.59E-06	3.9	100	3.23E-06	3.3	100	4.02E-06	4.9	100
8	2.75E-06	5.7	100	2.54E-06	3.9	100	2.22E-06	3.3	100	2.85E-06	4.9	100
9	*1 6.52E-06	5.6	100	5.73E-06	3.9	100	*1 5.31E-06	3.1	100	6.37E-06	4.9	100
10	3.82E-06	5.5	100	3.48E-06	3.9	100	3.11E-06	3.0	100	3.80E-06	4.9	100
11	1.08E-06	5.5	100	9.93E-07	3.9	100	9.18E-07	3.0	100	1.12E-06	4.9	100
12	3.21E-06	5.5	100	2.94E-06	3.9	100	2.63E-06	3.0	100	3.23E-06	4.9	100
13	5.65E-06	5.5	100	5.07E-06	3.9	100	4.62E-06	3.0	100	5.65E-06	4.9	100
14	6.17E-06	5.5	100	5.55E-06	3.9	100	5.16E-06	3.0	100	6.25E-06	4.9	100
15	5.05E-06	5.5	100	4.47E-06	3.9	100	4.01E-06	3.0	100	4.97E-06	4.9	100
16	6.26E-06	5.5	100	5.57E-06	3.9	100	5.07E-06	3.0	100	6.22E-06	4.9	100
17	2.64E-06	5.5	100	2.38E-06	3.9	100	2.17E-06	3.0	100	2.68E-06	4.9	100
18	4.91E-06	5.5	100	4.37E-06	3.9	100	3.97E-06	3.0	100	4.79E-06	4.9	100
19	5.51E-06	5.5	100	4.98E-06	3.9	100	4.60E-06	3.0	100	5.46E-06	4.9	100
20	4.25E-06	5.5	100	3.77E-06	3.9	100	3.51E-06	3.0	100	4.27E-06	4.9	100
21	2.63E-06	5.5	100	2.42E-06	3.9	100	2.28E-06	3.0	100	2.79E-06	4.9	100
22	4.18E-06	5.5	100	3.82E-06	3.9	100	3.51E-06	3.0	100	4.27E-06	4.9	100
23	1.42E-06	5.5	100	*1 1.34E-06	3.8	100	1.21E-06	3.0	100	1.46E-06	4.9	100
24	6.45E-07	5.5	100	6.17E-07	3.8	100	5.27E-07	3.0	100	6.81E-07	4.9	100
25	4.67E-07	5.5	100	4.73E-07	3.8	100	3.96E-07	3.0	100	5.19E-07	4.9	100
26	8.12E-07	5.5	100	7.71E-07	3.8	100	6.88E-07	3.0	100	8.45E-07	4.9	100
27	2.79E-06	5.5	100	2.54E-06	3.8	100	2.28E-06	3.0	100	2.78E-06	4.9	100
28	7.88E-06	5.5	100	7.04E-06	3.8	100	6.25E-06	3.0	100	7.51E-06	4.9	100
29	3.61E-06	5.5	100	3.29E-06	3.8	100	3.01E-06	3.0	100	*1 3.66E-06	5.0	100
30	5.35E-06	5.5	100	4.82E-06	3.8	100	4.43E-06	3.0	100	5.45E-06	5.0	100
31												
1ヶ月値	3.69E-06	5.6	100	3.34E-06	3.9	100	3.01E-06	3.1	100	3.70E-06	4.9	100
最大値	1.83E-05	5.7	102	1.64E-05	3.9	102	1.52E-05	3.3	102	2.10E-05	5.1	101
最大値日時	06/30 05:01	06/01 00:01	06/10 10:08	06/30 04:56	06/01 00:01	06/01 12:15	06/22 05:24	06/01 00:01	06/01 03:51	06/29 09:20	06/01 00:01	06/01 00:05
最小値	0.00E+00	5.5	98	0.00E+00	3.8	98	0.00E+00	3.0	97	0.00E+00	4.9	98
最小値日時	06/01 15:26	06/09 10:51	06/01 01:41	06/01 15:21	06/23 11:02	06/01 00:31	06/01 15:35	06/09 10:51	06/14 06:30	06/01 15:31	06/03 10:44	06/06 02:20

*1:ろ紙交換

測定月報

測定日：2020/06

(8/8)

日	モニタ											
	A031 HTI南側			A032 HTI南側								
	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)	濃度 (Bq/cm ³)	計数率 (cps)	流量 (L/min)
1	1.51E-06	10.3	100	1.77E-06	7.1	100						
2	1.17E-06	10.3	100	1.38E-06	7.1	100						
3	3.76E-06	10.3	100	*1 4.50E-06	7.0	100						
4	3.18E-06	10.3	100	3.84E-06	6.9	100						
5	5.56E-06	10.3	100	6.52E-06	6.9	100						
6	3.41E-06	10.3	100	4.16E-06	6.9	100						
7	3.63E-06	10.3	100	4.36E-06	6.9	100						
8	2.74E-06	10.3	100	3.29E-06	6.9	100						
9	5.87E-06	10.3	100	6.96E-06	6.9	100						
10	*1 3.99E-06	10.4	100	4.77E-06	6.9	100						
11	1.02E-06	10.4	100	1.43E-06	6.9	100						
12	3.33E-06	10.4	100	4.12E-06	6.9	100						
13	5.36E-06	10.4	100	6.36E-06	6.9	100						
14	4.96E-06	10.4	100	5.88E-06	6.9	100						
15	4.43E-06	10.4	100	5.44E-06	6.9	100						
16	5.42E-06	10.4	100	6.54E-06	6.9	100						
17	2.20E-06	10.4	100	2.83E-06	6.9	100						
18	4.51E-06	10.4	100	5.49E-06	6.9	100						
19	5.04E-06	10.4	100	5.96E-06	6.9	100						
20	3.93E-06	10.4	100	4.80E-06	6.9	100						
21	2.57E-06	10.4	100	3.16E-06	6.9	100						
22	3.81E-06	10.4	100	4.45E-06	6.9	100						
23	1.14E-06	10.4	100	1.53E-06	6.9	100						
24	5.42E-07	10.4	100	8.10E-07	6.9	100						
25	3.68E-07	10.4	100	6.53E-07	6.9	100						
26	6.63E-07	10.4	100	9.39E-07	6.9	100						
27	2.68E-06	10.4	100	3.35E-06	6.9	100						
28	7.06E-06	10.4	100	8.42E-06	6.9	100						
29	3.40E-06	10.4	100	*1 4.13E-06	7.0	100						
30	4.71E-06	10.4	100	5.51E-06	7.0	100						
31												
1ヶ月値	3.40E-06	10.4	100	4.11E-06	6.9	100						
最大値	1.90E-05	10.4	103	2.05E-05	7.1	102						
最大値日時	06/30 04:20	06/10 10:37	06/05 07:18	06/22 05:21	06/01 00:01	06/03 17:20						
最小値	0.00E+00	10.3	97	0.00E+00	6.9	98						
最小値日時	06/01 14:59	06/01 00:01	06/08 21:30	06/01 15:45	06/03 10:51	06/01 00:28						

*1: ろ紙交換