


件名	2号機シールドプラグ調査 測定データ		
測定日	2021/10/7	使用機器	Kobra, Packbot
計測器	PDR 303		



単位：msv/h

No.	測定値
1	44.8
2	107
3	175
4	136
5	152
6	104,144 <sup>※1</sup>
7	294
8	117
9	134
10	76.2
11	14.4
12	37.5
13	58.8
14	50.0
15	62.6

No.	測定値
16	82.0
17	103
18	92.1
19	40.0
20	72.4
21	70.3
22	71.0
23	270
24	126
25	521 <sup>※2</sup>
26	23.0
27	17.0
28	96.5
29	73.0
30	78.0

No.	測定値
31	105
32	23.0
33	51.5
34	36.0
35	36.3
36	73.5
37	59.6
38	12.9
39	340
40	560
41	391
42	266
43	241
44	343
45	524

No.	測定値
46	93.2
47	59.3
48	143
49	105
50	105
51	139
52	157
53	138
54	259
55	390
56	123
57	228
58	420,385※3
59	113
60	61.5

[illegible]

※1：2回測定を実施

※2:近傍に残材あり。残材を避けた箇所で約70mSv/ ※3:2回測定を実施

※3：2回測定を実施