

GM	メンバー

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
TB-190 ✓	2023/10/2 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.004 ✓	-
2019 FU-00323 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.051 ✓	-
ZK-01100 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
KM-00327 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
TB-075 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	-
TB-146 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 ZK-02705 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.013 ✓	-
2019 FU-00352 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.006 ✓	-
KM-00193 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
KM-00246 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 NS-00026 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.006 ✓	-
ZK-00038 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.48 ✓	-
2019 ZK-02885 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	-
ZK-00444 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.011 ✓	-
2018 ZK-01972 ✓	2023/10/2	6	F1-ICWBL-96	0.003	0.003	0.067 ✓	-
ZK-01319 ✓	2023/10/3 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.028 ✓	-
KM-00255 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.009 ✓	-
KM-00199 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 FU-00158 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
HP-00002 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	-
2019 FU-00195 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00974 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.043 ✓	-
ZK-01352 ✓	2023/10/3	6	F1-ICWBL-96	0.003	0.003	0.14 ✓	-
2019 ZK-02646 ✓	2023/10/3 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	-	0.38 ✓	-
2018 FU-00107 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.22 ✓	-
2019 ZK-02676 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.59 ✓	-
2018 FU-00106 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.13 ✓	-
2019 FU-00276 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.19 ✓	-
2018 FU-00130 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.15 ✓	-
2018 FU-00105 ✓	2023/10/3	6	F1-ICW-239	0.003	-	0.17 ✓	-
2019 ZK-02756 ✓	2023/10/5 ✓	6 ✓	F1-ICW-239 ✓	0.005 ✓	-	0.025 ✓	-
2019 ZK-02679 ✓	2023/10/5	6	F1-ICW-239	0.005	-	0.73 ✓	-
2019 SS-00105 ✓	2023/10/5	6	F1-ICW-239	0.005	-	0.14 ✓	-
2019 ZK-02703 ✓	2023/10/5	6	F1-ICW-239	0.005	-	0.56 ✓	-
2019 SS-00104 ✓	2023/10/5	6	F1-ICW-239	0.005	-	0.85 ✓	-
2019 SS-00121 ✓	2023/10/5	6	F1-ICW-239	0.005	-	0.35 ✓	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta+\gamma$	γ	$\beta+\gamma$
2019 ZK-02984 ✓	2023/10/5 ✓	6 ✓	F1-ICW-239 ✓	0.005 ✓	—	0.90 ✓	—
2019 ZK-02912 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.098 ✓	—
2019 SS-00132 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.010 ✓	—
2019 ZK-02636 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.006 ✓	—
2019 SS-00311 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.005 ✓	—
2019 SS-00191 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.008 ✓	—
2019 ZK-02844 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.005 ✓	—
2019 ZK-02861 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.006 ✓	—
2019 ZK-02872 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.006 ✓	—
2019 ZK-02929 ✓	2023/10/5	6	F1-ICW-239	0.005	—	0.012 ✓	—
2019 SS-00474 ✓	2023/10/6 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	—	0.005 ✓	—
2019 SS-00484 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.007 ✓	—
2019 SS-00135 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.006 ✓	—
2018 FU-00053 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.22 ✓	—
2019 SS-00488 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.047 ✓	—
2019 SS-00485 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.007 ✓	—
2019 SS-00312 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.013 ✓	—
2018 FU-00048 ✓	2023/10/6	6	F1-ICW-239	0.003	—	0.32 ✓	—
2019 FU-00268G ✓	2023/10/6 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	—
KM-00075 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.008 ✓	—
TB-100 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 ZK-02640 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.007 ✓	—
ZK-00125 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
TB-179 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
ZK-00394 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
ZK-00090 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	—
ZK-00633 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
KM-00247 ✓	2023/10/6	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	—
2019 FU-00185G ✓	2023/10/7 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	—	0.15 ✓	—
2019 FU-00075 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.059 ✓	—
2019 SS-00289 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.17 ✓	—
2019 FU-00073 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.085 ✓	—
2019 FU-00131 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.063 ✓	—
2019 FU-00020 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.039 ✓	—
2018 FU-00046 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.17 ✓	—
2018 FU-00132 ✓	2023/10/7	6	F1-ICW-239	0.003	—	0.29 ✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
KM-00202 ✓	2023/10/7 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	-
ZK-00691 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00518 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
KM-00173 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 ZK-02686 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 FU-00134 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.10 ✓	-
2019 FU-00032 ✓	2023/10/7	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-01390 ✓	2023/10/10 ✓	6 ✓	F1-ICWBL-96 ✓	0.004 ✓	0.004 ✓	0.21 ✓	-
2019 FU-00101 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.15 ✓	-
2019 ZK-02488 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.006 ✓	-
ZK-00966 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
ZK-01243 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2018 ZK-01486 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.26 ✓	-
2019 NS-00093 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 ZK-02386 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 NS-00081 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 SS-00536 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.26 ✓	-
2019 SS-00125 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.12 ✓	-
2019 FU-00143 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 NS-00126 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 SS-00190 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.012 ✓	-
TB-236 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 NS-00006 ✓	2023/10/10	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 SS-00258 ✓	2023/10/11 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	-	0.066 ✓	-
2019 FU-00193G ✓	2023/10/11	6	F1-ICW-239	0.003	-	0.068 ✓	-
2019 SS-00267 ✓	2023/10/11	6	F1-ICW-239	0.003	-	0.29 ✓	-
2019 SS-00078 ✓	2023/10/11	6	F1-ICW-239	0.003	-	0.21 ✓	-
2019 SS-00351 ✓	2023/10/11	6	F1-ICW-239	0.003	-	0.17 ✓	-
2019 FU-00194G ✓	2023/10/11	6	F1-ICW-239	0.003	-	0.061 ✓	-
ZK-00389 ✓	2023/10/11 ✓	6 ✓	F1-ICWBL-96 ✓	0.004 ✓	0.004 ✓	0.004 ✓	-
KM-00076 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
KM-00341 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
2019 NS-00013 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
ZK-00972 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
ZK-00516 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-
KM-00203 ✓	2023/10/11	6	F1-ICWBL-96	0.004	0.004	0.004 ✓	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
KM-00186 ✓	2023/10/11 ✓	6 ✓	F1-ICWBL-96 ✓	0.004 ✓	0.004 ✓	0.004 ✓	-
2019 SS-00574 ✓	2023/10/12 ✓	6 ✓	F1-ICWBL-63 ✓	0.005 ✓	0.005 ✓	0.69 ✓	-
2019 SS-00292 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.069 ✓	-
2019 SS-00349 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.13 ✓	-
2019 SS-00299 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.15 ✓	-
2019 SS-00076 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.073 ✓	-
2019 ZK-02594 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.46 ✓	-
2019 SS-00263 ✓	2023/10/12	6	F1-ICWBL-63	0.005	0.005	0.34 ✓	-
KM-00078 ✓	2023/10/12 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	-
KM-00181 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 SS-00186 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00371 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00511 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.026 ✓	-
KM-00180 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
KM-00039 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
KM-00030 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00666 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00951 ✓	2023/10/12	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	-
2019 FU-00255 ✓	2023/10/13 ✓	6 ✓	F1-ICW-239 ✓	0.004 ✓	-	0.28 ✓	-
2019 FU-00173 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.006 ✓	-
2018 FU-00008 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.028 ✓	-
2019 FU-00179 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.035 ✓	-
2019 FU-00184 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.017 ✓	-
2019 FU-00252 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.006 ✓	-
2019 FU-00176 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.057 ✓	-
2019 FU-00174 ✓	2023/10/13	6	F1-ICW-239	0.004	-	0.006 ✓	-
HP-00001 ✓	2023/10/13 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	-
KM-00328 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
TB-066 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
ZK-00893 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	-
ZK-00609 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.006 ✓	-
ZK-00040 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.18 ✓	-
KM-00183 ✓	2023/10/13	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	-
2019 SS-00336 ✓	2023/10/14 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	-	0.045 ✓	-
2019 FU-00278 ✓	2023/10/14	6	F1-ICW-239	0.003	-	0.70 ✓	-
2019 FU-00217G ✓	2023/10/14	6	F1-ICW-239	0.003	-	0.23 ✓	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00280 ✓	2023/10/14 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	—	0.41 ✓	—
2019 FU-00264G ✓	2023/10/14	6	F1-ICW-239	0.003	—	0.13 ✓	—
2019 FU-00259 ✓	2023/10/14	6	F1-ICW-239	0.003	—	0.66 ✓	—
2019 FU-00274 ✓	2023/10/14	6	F1-ICW-239	0.003	—	0.36 ✓	—
2019 FU-00235G ✓	2023/10/14	6	F1-ICW-239	0.003	—	0.78 ✓	—
ZK-01106 ✓	2023/10/14 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.063 ✓	—
2019 FU-00065 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-00036 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.084 ✓	—
KM-00172 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
TB-137 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
KM-00204 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
KM-00336 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
KM-00330 ✓	2023/10/14	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 SS-00328 ✓	2023/10/16 ✓	6 ✓	F1-ICW-239 ✓	0.004 ✓	—	0.12 ✓	—
2019 FU-00222G ✓	2023/10/16	6	F1-ICW-239	0.004	—	0.41 ✓	—
2019 FU-00207G ✓	2023/10/16	6	F1-ICW-239	0.004	—	0.46 ✓	—
2019 FU-00153G ✓	2023/10/16	6	F1-ICW-239	0.004	—	0.28 ✓	—
ZK-01002 ✓	2023/10/16 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.007 ✓	—
ZK-00941 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
KM-00004 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 ZK-02712 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 ZK-02498 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.006 ✓	—
ZK-01226 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-01237 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.032 ✓	—
2019 SS-00357 ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.006 ✓	—
2019 FU-00157G ✓	2023/10/16	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
S062 ✓	2023/10/17 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	—	0.29 ✓	—
2019 SS-00445 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.15 ✓	—
2020 SS-00043 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.26 ✓	—
OK-0340 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.25 ✓	—
2018 ZK-01795 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.35 ✓	—
2018 ZK-01797 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.16 ✓	—
KM-00351 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.33 ✓	—
KM-10106 ✓	2023/10/17	6	F1-ICW-239	0.003	—	0.53 ✓	—
2019 ZK-02515 ✓	2023/10/17 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	—
2019 ZK-02346 ✓	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00228G	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.020	-
2019 ZK-02623	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.054	-
2019 ZK-02264	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.003	-
2019 FU-00099	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.042	-
2019 ZK-02695	2023/10/17	6	F1-ICWBL-96	0.003	0.003	0.011	-
2018 FU-00019	2023/10/18	6	F1-ICW-239	0.003	-	0.16	-
2018 FU-00021	2023/10/18	6	F1-ICW-239	0.003	-	0.022	-
2018 FU-00037	2023/10/18	6	F1-ICW-239	0.003	-	0.022	-
2019 FU-00164	2023/10/18	6	F1-ICW-239	0.003	-	0.035	-
2020 FU-00256	2023/10/18	6	F1-ICW-239	0.003	-	0.63	-
2021 SS-00143	2023/10/18	6	F1-ICW-239	0.003	-	0.84	-
2019 FU-00341	2023/10/18	6	F1-ICW-239	0.003	-	0.37	-
2019 FU-00046	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.006	-
2019 FU-00070	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.003	-
2018 ZK-01448	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.004	-
2019 NS-00117	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.003	-
2019 ZK-02856	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.054	-
2019 FU-00116	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.070	-
2019 FU-00164G	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.003	-
2018 FU-00147	2023/10/18	6	F1-ICWBL-96	0.003	0.003	0.007	-
2019 SS-00590	2023/10/19	6	F1-ICW-239	0.003	-	0.91	-
2018 ZK-01883	2023/10/19	6	F1-ICW-239	0.003	-	0.93	-
2018 FU-00020	2023/10/19	6	F1-ICW-239	0.003	-	0.26	-
2019 FU-00266G	2023/10/19	6	F1-ICW-239	0.003	-	0.54	-
2018 FU-00015	2023/10/19	6	F1-ICW-239	0.003	-	0.025	-
2019 SS-00469	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.19	-
ZK-01324	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.007	-
2018 FU-00061	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.003	-
2019 ZK-02699	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.004	-
ZK-01203	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.040	-
2019 NS-00290	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.003	-
ZK-01095	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.004	-
ZK-00257	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.003	-
KM-00011	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.003	-
ZK-00446	2023/10/19	6	F1-ICWBL-96	0.003	0.003	0.004	-
2018 FU-00010	2023/10/20	6	F1-ICW-239	0.004	-	0.019	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00196 ✓	2023/10/20 ✓	6 ✓	F1-ICW-239 ✓	0.004 ✓	—	0.049 ✓	—
2019 FU-00155 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.011 ✓	—
2019 FU-00263 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.018 ✓	—
2019 FU-00266 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.030 ✓	—
2019 FU-00258 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.016 ✓	—
2018 FU-00027 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.034 ✓	—
2019 SS-00024 ✓	2023/10/20	6	F1-ICW-239	0.004	—	0.16 ✓	—
KM-00179 ✓	2023/10/20 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	—
KM-00201 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-00267 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
KM-00342 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 ZK-02840 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.13 ✓	—
2018 ZK-01424 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-00525 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-01200 ✓	2023/10/20	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
2019 SS-00154 ✓	2023/10/21 ✓	6 ✓	F1-ICW-239 ✓	0.004 ✓	—	0.13 ✓	—
2019 FU-00274G ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.089 ✓	—
201 FU-00185 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.076 ✓	—
2019 ZK-02412 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.17 ✓	—
2019 FU-00254 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.15 ✓	—
2019 FU-00267 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.019 ✓	—
2019 FU-00170 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.26 ✓	—
2019 FU-00272 ✓	2023/10/21	6	F1-ICW-239	0.004	—	0.016 ✓	—
ZK-00363 ✓	2023/10/21 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.003 ✓	—
ZK-00975 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-00610 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	—
ZK-00940 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.004 ✓	—
ZK-00883 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
ZK-00973 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.051 ✓	—
ZK-00387 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.005 ✓	—
ZK-00464 ✓	2023/10/21	6	F1-ICWBL-96	0.003	0.003	0.003 ✓	—
2019 SS-00038 ✓	2023/10/23 ✓	6 ✓	F1-ICW-239 ✓	0.003 ✓	—	0.21 ✓	—
2019 SS-00448 ✓	2023/10/23	6	F1-ICW-239	0.003	—	0.38 ✓	—
2019 SS-00016 ✓	2023/10/23	6	F1-ICW-239	0.003	—	0.27 ✓	—
2019 SS-00441 ✓	2023/10/23	6	F1-ICW-239	0.003	—	0.33 ✓	—
ZK-00980 ✓	2023/10/23 ✓	6 ✓	F1-ICWBL-96 ✓	0.003 ✓	0.003 ✓	0.057 ✓	—

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
ZK-00946 /	2023/10/23 /	6 /	F1-ICWBL-96 /	0.003 /	0.003 /	0.003 /	-
ZK-00505 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.003 /	-
ZK-00848 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.003 /	-
ZK-00531 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.003 /	-
ZK-00577 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.034 /	-
ZK-00808 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.003 /	-
ZK-00985 /	2023/10/23	6	F1-ICWBL-96	0.003	0.003	0.074 /	-
2019 SS-00238 /	2023/10/24 /	6 /	F1-ICW-239 /	0.004 /	-	0.084 /	-
2019 SS-00156 /	2023/10/24	6	F1-ICW-239	0.004	-	0.35 /	-
2019 SS-00058 /	2023/10/24	6	F1-ICW-239	0.004	-	0.12 /	-
2019 SS-00027 /	2023/10/24	6	F1-ICW-239	0.004	-	0.27 /	-
2019 SS-00055 /	2023/10/24	6	F1-ICW-239	0.004	-	0.42 /	-
2019 FU-00024 /	2023/10/24	6	F1-ICW-239	0.004	-	0.051 /	-
2022 FU-00076 /	2023/10/24	6	F1-ICW-239	0.004	-	0.85 /	-
2019 SS-00423 /	2023/10/25 /	6 /	F1-ICW-268 /	0.004 /	-	0.039 /	-
2019 SS-00103 /	2023/10/25	6	F1-ICW-268	0.004	-	0.071 /	-
2019 SS-00221 /	2023/10/25	6	F1-ICW-268	0.004	-	0.027 /	-
2019 FU-00275G /	2023/10/25	6	F1-ICW-268	0.004	-	0.19 /	-
2019 ZK-02816 /	2023/10/25	6	F1-ICW-268	0.004	-	0.37 /	-
2019 SS-00106 /	2023/10/25	6	F1-ICW-268	0.004	-	0.31 /	-
2019 SS-00268 /	2023/10/25	6	F1-ICW-268	0.004	-	0.21 /	-
2022 SK-00720 /	2023/10/26 /	6 /	F1-ICW-239 /	0.004 /	-	0.35 /	-
2021 SS-40405 /	2023/10/26	6	F1-ICW-239	0.004	-	0.93 /	-
2022 FU-00189 /	2023/10/26	6	F1-ICW-239	0.004	-	0.94 /	-
2022 FU-00167 /	2023/10/26	6	F1-ICW-239	0.004	-	0.66 /	-
2022 SK-00786 /	2023/10/26	6	F1-ICW-239	0.004	-	0.70 /	-
2021 ZK-05259 /	2023/10/27 /	6 /	F1-ICW-239 /	0.004 /	-	0.92 /	-
2019 SS-00294 /	2023/10/27	6	F1-ICW-239	0.004	-	0.24 /	-
2021 ZK-05254 /	2023/10/27	6	F1-ICW-239	0.004	-	0.90 /	-
ZK-00039 /	2023/10/27 /	6 /	F1-ICWL-96 /	0.003 /	0.003 /	0.24 /	-
2019 SS-00013 /	2023/10/28 /	6 /	F1-ICW-239 /	0.004 /	-	0.13 /	-
2021 SS-30042 /	2023/10/28	6	F1-ICW-239	0.004	-	0.10 /	-
2021 ZK-04960 /	2023/10/28	6	F1-ICW-239	0.004	-	0.30 /	-
2019 SS-00098 /	2023/10/28	6	F1-ICW-239	0.004	-	0.15 /	-
2019 SS-00446 /	2023/10/28	6	F1-ICW-239	0.004	-	0.081 /	-
2019 ZK-02418 /	2023/10/30 /	6 /	F1-ICW-239 /	0.004 /	-	0.45 /	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2021 FU-00173 ✓	2023/10/30 ✓	6 ✓	F1-ICW-239 ✓	0.004 ✓	—	0.79 ✓	—
2021 FU-00127 ✓	2023/10/30	6	F1-ICW-239	0.004	—	0.60 ✓	—
2021 SS-40439 ✓	2023/10/31 ✓	6 ✓	F1-ICW-283 ✓	0.005 ✓	—	0.090 ✓	—
2021 NM-00046 ✓	2023/10/31	6	F1-ICW-283	0.005	—	0.35 ✓	—
2019 SS-00287 ✓	2023/10/31	6	F1-ICW-283	0.005	—	0.15 ✓	—
2021 NM-00052 ✓	2023/10/31	6	F1-ICW-283	0.005	—	0.37 ✓	—