

GM	メンバー

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 ZK-03197	2025/9/1	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 FU-00056	2025/9/1	6	F1-ICWBL-258	0.004	0.004	0.009	-
2019 ZK-02670	2025/9/1	6	F1-ICWBL-258	0.004	0.004	0.006	-
2019 ZK-03081	2025/9/2	6	F1-ICWBL-258	0.004	0.004	0.008	-
2019 ZK-02641	2025/9/2	6	F1-ICWBL-258	0.004	0.004	0.004	-
TB-276	2025/9/2	6	F1-ICWBL-258	0.004	0.004	0.038	-
2020 ZK-03530	2025/9/2	6	F1-ICWBL-258	0.004	0.004	0.068	-
2019 FU-00078	2025/9/2	6	F1-ICWBL-258	0.004	0.004	0.083	-
2019 ZK-02835	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.073	-
2019 ZK-02507	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.045	-
KM-00292	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.021	-
2019 ZK-02526	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 SS-00356	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.025	-
2019 ZK-02831	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.015	-
2022 CT-00144	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.055	-
2019 SS-00120	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.022	-
2020 SS-00413	2025/9/3	6	F1-ICWBL-258	0.004	0.004	0.036	-
ZK-01057	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.072	-
ZK-00631	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.005	-
ZK-00989	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.005	-
2019 ZK-03208	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.005	-
ZK-00651	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.019	-
ZK-00791	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.038	-
ZK-00872	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.004	-
2019 FU-00052	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.007	-
ZK-00739	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.019	-
ZK-00669	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.005	-
2019 FU-00160	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.006	-
2019 ZK-02780	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.008	-
2018 ZK-01872	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.006	-
ZK-00664	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.007	-
2019 SS-00034	2025/9/3	6	F1-ICWBL-79	0.004	0.004	0.006	-
2019 FU-00345	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.022	-
2019 ZK-02325	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 FU-00395	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.026	-
ZK-01017	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta+\gamma$	γ	$\beta+\gamma$
2019 ZK-02098	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.027	-
2019 FU-00271G	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-
ZK-01016	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 SS-00068	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.033	-
2019 ZK-02485	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.006	-
ZK-00978	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.037	-
ZK-00998	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 SS-00288	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.010	-
ZK-00800	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.073	-
2019 ZK-02041	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.010	-
2020 SS-00358	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.019	-
ZK-01236	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.006	-
ZK-00511	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.045	-
ZK-00610	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.013	-
2019 ZK-02476	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.008	-
2019 FU-00242G	2025/9/4	6	F1-ICWBL-240	0.003	0.003	0.005	-
2020 ZK-03313	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.055	-
2020 SS-00420	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.031	-
ZK-00591	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.087	-
2018 ZK-01437	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.23	-
ZK-00840	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.062	-
2020 FU-00234	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.10	-
2020 ZK-04555	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.32	-
2020 ZK-03572	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.095	-
2019 FU-00237G	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.020	-
2020 ZK-03460	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.49	-
2021 ZK-05068	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.30	-
ZK-01014	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.16	-
ZK-01054	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.21	-
2022 SK-00755	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.13	-
2021 ZK-05072	2025/9/4	6	F1-ICWBL-258	0.004	0.004	0.26	-
2019 FU-00129	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.051	-
2021 SS-40570	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.18	-
2021 ZK-05073	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.39	-
KM-00290	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.47	-
2021 ZK-05070	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.10	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta+\gamma$	γ	$\beta+\gamma$
2022 SK-00751	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.60	-
2022 CT-00083	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.45	-
2019 FU-00175	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.11	-
2019 FU-00148	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.38	-
2022 CT-00344	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.75	-
KM-00369	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.10	-
ZK-01041	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.33	-
ZK-01340	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.29	-
2019 FU-00195G	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.41	-
2019 SS-00081	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.81	-
2022 CT-00302	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.28	-
2022 CT-00318	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.54	-
2019 FU-00120	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.085	-
2022 CT-00365	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.12	-
2021 ZK-05069	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.21	-
2019 FU-00068	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.33	-
2022 FU-00219	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.80	-
2022 CT-00348	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.29	-
2020 ZK-03329	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.31	-
ZK-01037	2025/9/8	6	F1-ICWBL-258	0.004	0.004	0.12	-
2019 ZK-02226	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.011	-
2021 SS-30200	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.004	-
2019 NS-00065	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.004	-
2021 FU-00154	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.010	-
2018 ZK-01424	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.003	-
2019 SS-00514	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.021	-
2019 FU-00287	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 NS-00323	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.005	-
2021 NM-00046	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.58	-
2019 ZK-02272	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 ZK-02128	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.14	-
2021 SS-30176	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.005	-
2019 ZK-02528	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.020	-
2020 SS-00110	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.006	-
2020 ZK-03644	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.022	-
2020 ZK-03630	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.043	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 SS-00287	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.091	-
TB-115	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.009	-
ZK-00957	2025/9/8	6	F1-ICWBL-240	0.003	0.003	0.006	-
2019 FU-00168	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.21	-
2022 CT-00441	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.24	-
2019 SS-00246	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.80	-
ZK-01015	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.066	-
2019 FU-00180G	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.040	-
2019 ZK-02838	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.25	-
2022 CT-00442	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.067	-
2022 CT-00094	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.18	-
2021 SS-30171	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.060	-
2020 SS-00317	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.41	-
2020 SS-00411	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.45	-
2019 FU-00055	2025/9/9	6	F1-ICWBL-258	0.004	0.004	0.40	-
2019 ZK-03013	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.006	-
2019 ZK-02902	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.19	-
2019 ZK-02518	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.021	-
2019 ZK-03195	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03778	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.055	-
2019 ZK-02269	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 FU-00181G	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.011	-
2019 FU-00290	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.027	-
2019 FU-00285	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.005	-
TB-268	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.066	-
2019 ZK-02768	2025/9/12	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 FU-00155	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.005	-
2019 ZK-02602	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.013	-
2020 ZK-03741	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.13	-
2020 ZK-03787	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.031	-
2021 SK-00301	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.34	-
2019 ZK-03115	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.005	-
2019 ZK-03290	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.009	-
2021 SS-10026	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.13	-
2020 FU-00158	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.005	-
TB-098	2025/9/16	6	F1-ICWBL-240	0.004	0.004	0.008	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 FU-00244G	2025/9/16	6	F1-ICWBL-258	0.004	0.004	0.078	-
2019 FU-00210G	2025/9/16	6	F1-ICWBL-258	0.004	0.004	0.14	-
2020 SS-00068	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.49	-
2019 FU-00179G	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.042	-
2019 ZK-02814	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.020	-
2019 FU-00162G	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.040	-
2020 SS-00540	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.063	-
2019 FU-00071	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.19	-
2019 FU-00209G	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.17	-
2022 CT-00315	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.11	-
ZK-01094	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.18	-
2022 SK-01009	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.20	-
2021 SS-40414	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.40	-
2022 CT-00346	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.24	-
2019 ZK-02696	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02886	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03640	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.028	-
2019 NS-00042	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03366	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.022	-
TB-018	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.049	-
2022 FU-00164	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.15	-
2019 NS-00041	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.009	-
2019 ZK-02815	2025/9/17	6	F1-ICWBL-258	0.004	0.004	0.029	-
2019 ZK-03178	2025/9/18	6	F1-ICWBL-79	0.003	0.003	0.004	-
2020 FU-00153	2025/9/18	6	F1-ICWBL-79	0.003	0.003	0.003	-
2020 SS-00299	2025/9/18	6	F1-ICWBL-79	0.003	0.003	0.34	-
2019 ZK-03225	2025/9/18	6	F1-ICWBL-240	0.003	0.003	0.007	-
2022 FU-00089	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.17	-
2020 SS-00311	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.44	-
2019 SS-00432	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.099	-
2019 ZK-03069	2025/9/18	6	F1-ICWBL-259	0.004	0.004	0.004	-
2019 ZK-03167	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03173	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03369	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.050	-
2020 FU-00157	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 NS-00241	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.43	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2020 ZK-03774	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.031	-
2019 ZK-03073	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03216	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03536	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.061	-
2020 FU-00159	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03200	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03170	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-02994	2025/9/18	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 SS-00085	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.73	-
2020 ZK-03516	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.16	-
2020 ZK-03688	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.046	-
2022 SK-01034	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.44	-
2021 ZK-05036	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.53	-
2019 ZK-03133	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03342	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.14	-
2021 SS-00027	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.22	-
2019 ZK-03067	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.004	-
2020 ZK-03565	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.043	-
ZK-00468	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.10	-
2020 ZK-03560	2025/9/19	6	F1-ICWBL-258	0.004	0.004	0.14	-
2020 FU-00284	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.78	-
2019 ZK-03025	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.005	-
TB-231	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.005	-
2019 ZK-02919	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.048	-
2019 SS-00127	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.35	-
2019 ZK-03011	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.024	-
KM-00182	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.005	-
2021 SS-40394	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.32	-
2019 SS-00114	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.50	-
2021 ZK-04955	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.27	-
2019 SS-00067	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.60	-
2019 ZK-03014	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.009	-
2019 SS-00169	2025/9/22	6	F1-ICWBL-240	0.004	0.004	0.65	-
2019 ZK-03097	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.011	-
2019 ZK-03124	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.022	-
2021 SS-40456	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.39	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 SS-00185	2025/9/22	6	F1-ICWBL-258	0.004	0.004	1.18	-
TB-286	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.11	-
2019 SS-00057	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.37	-
2019 ZK-03085	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-01187	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03096	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
2019 ZK-03003	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.024	-
2019 ZK-02942	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.045	-
2019 SS-00178	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.60	-
2020 FU-00179	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.027	-
2020 ZK-03606	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.055	-
2019 ZK-03058	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.004	-
ZK-01136	2025/9/22	6	F1-ICWBL-258	0.004	0.004	0.015	-
2019 ZK-03089	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.012	-
2019 SS-00066	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.32	-
2019 ZK-02987	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.033	-
ZK-01114	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.038	-
2019 ZK-03140	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.031	-
2020 ZK-03584	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.025	-
2020 ZK-03570	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.15	-
2021 SS-30253	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.47	-
2021 SS-10037	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.15	-
2021 SK-00026	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.35	-
2021 FU-00051	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.93	-
2020 ZK-03347	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.11	-
2020 ZK-03356	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.013	-
2019 SS-00118	2025/9/24	6	F1-ICWBL-82	0.004	0.004	0.004	-
2019 FU-00224G	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.83	-
2019 ZK-02592	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.033	-
2020 ZK-03634	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.17	-
2020 ZK-03468	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.044	-
2019 ZK-03128	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.049	-
2021 SS-10315	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.086	-
2021 SS-40391	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.35	-
2021 SS-10033	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.93	-
2019 ZK-02809	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.012	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 ZK-03098	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.023	-
2020 SS-00227	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.073	-
2019 ZK-02979	2025/9/25	6	F1-ICWBL-82	0.004	0.004	0.014	-
2018 ZK-01685	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.007	-
2018 ZK-01417	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.007	-
2020 ZK-03355	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.034	-
2020 SS-00350	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.10	-
2019 ZK-02783	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.008	-
2021 SS-00144	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.92	-
2019 FU-00344	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.019	-
2019 FU-00362	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.055	-
2021 ZK-04946	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.68	-
2019 FU-00017	2025/9/25	6	F1-ICWBL-79	0.004	0.004	0.007	-
2019 ZK-02993	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.004	-
2019 ZK-03004	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.015	-
2019 ZK-02921	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.019	-
2020 ZK-03513	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.20	-
2019 ZK-02946	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.004	-
2020 SS-00349	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.061	-
2020 FU-00177	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.33	-
2018 ZK-01671	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.036	-
ZK-00965	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.004	-
ZK-00407	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.008	-
2019 ZK-02345	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.004	-
2019 ZK-02963	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.004	-
2020 ZK-03334	2025/9/26	6	F1-ICWBL-82	0.004	0.004	0.12	-
2019 FU-00128	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.010	-
2019 ZK-02657	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.019	-
ZK-00383	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.008	-
ZK-00654	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.016	-
ZK-00967	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.010	-
2019 SS-00029	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.031	-
ZK-00818	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.005	-
2020 ZK-03571	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.048	-
TB-280	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.098	-
2018 FU-00077	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.007	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
ZK-00583	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.006	-
ZK-00831	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.005	-
ZK-00587	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.007	-
2020 ZK-03577	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.098	-
ZK-00986	2025/9/29	6	F1-ICWBL-240	0.003	0.003	0.008	-
ZK-00526	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.018	-
2019 ZK-02504	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.011	-
TB-120	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.051	-
ZK-01218	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.063	-
ZK-01138	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.074	-
2019 ZK-02058	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.005	-
TB-172	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.033	-
ZK-00449	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.008	-
2019 SS-00083	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.015	-
2019 NS-00317	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.008	-
ZK-00404	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.005	-
2019 ZK-02490	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.013	-
2019 ZK-03294	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.005	-
2020 ZK-03309	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.10	-
2019 ZK-02307	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.008	-
ZK-00031	2025/9/29	6	F1-ICWBL-82	0.004	0.004	0.14	-
2020 ZK-03564	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.044	-
ZK-00778	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.005	-
2020 ZK-03379	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.028	-
2020 ZK-03581	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.022	-
2019 ZK-02378	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.008	-
2019 SS-00389	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.038	-
TB-128	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.091	-
2022 SK-00416	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.075	-
2019 ZK-02312	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.005	-
TB-240	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.005	-
TB-125	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.13	-
2018 ZK-01457	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.012	-
2020 ZK-03489	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.031	-
2020 ZK-03312	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.033	-
TB-284	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.034	-

瓦礫等収納容器点検結果(線量測定データ)

容器番号	確認年月日	コンテナサイズ (m ³)	測定器No	BG値 (mSv/h)		表面線量当量率 (mSv/h)	
				γ	$\beta + \gamma$	γ	$\beta + \gamma$
2019 NS-00280	2025/9/30	6	F1-ICWBL-82	0.004	0.004	0.006	-