## FY2023 Discharge Plan

 ALPS treated water will be discharged starting from which stored in the measurement/confirmation facility, the K4 area tank groups A-C.

• Especially, the water stored in the tank group B which was analyzed by International Atomic Energy Agency (IAEA) is discharged first.

Tritium concentrations
will be less than 1,500Bq/liter
by dilution more than 700 times
with seawater

| Discharge   | Tritium Concentration        | <b>Total Amount of Tritium</b> |
|---|------------------------------|--------------------------------|
| 1st Approx. 7,800m <sup>3</sup>   | <sup>3</sup> 140,000Bq/liter | 1.1 trillion Bq                |
| 2 <sup>nd</sup> C Approx. 7,800m <sup>3</sup>   | <sup>3</sup> 140,000Bq/liter | 1.1 trillion Bq                |
| 3rd Approx. 7,800m <sup>3</sup>   | <sup>3</sup> 130,000Bq/liter | 1.0 trillion Bq                |
| 4th  K4 area Group E K3 area Group A  Approx. 4,500m <sup>3</sup> Approx. 3,300m <sup>3</sup> | •                            | 1.4 trillion Bq*               |

that was empty after the 1st discharge was completed

Being transferred to K4 area tank group B

Total amount of tritium to be discharged

FY2023 : Approx. 5 trillion Bq

Annual limit : 22 trillion Bq

<sup>\*</sup> Average value of the tank group that was assessed taking into account the radioactive decay until July 1, 2023

## FY2023 Discharge History

• Discharge progress of ALPS treated water into the sea are as follows.


| Analysis date of measurement/confirmation facility | Tank group | Tritium<br>concentration    | Concentration of radioactive materials excluding tritium                            | Commencement<br>of<br>discharge | Completion<br>of<br>discharge | Dilution rate<br>during<br>discharge | Tritium<br>concentrations<br>after dilution*1 | Amount<br>of<br>discharge | Amount of<br>tritium<br>radioactivity |
|--|------------|-----------------------------|---|---------------------------------|-------------------------------|--------------------------------------|---|---------------------------|---------------------------------------|
| June 22, 2023                                      | Group B    | 14×10 <sup>4</sup> Bq/liter | The sum of ratios of legally required standards concentrations    0.28 < 1          | August 24, 2023                 | September 11,<br>2023         | Approx.<br>800 times                 | 160-200 Bq/liter                              | 7,788m³                   | Approx.<br>1.1 trillion Bq            |
| September 21,<br>2023                              | Group C    | 14×10 <sup>4</sup> Bq/liter | The sum of ratios of legally required concentrations Regulatory standards           | October 5, 2023                 | October 23,<br>2023           | Approx.<br>800 times                 | 150-170 Bq/liter                              | 7,810m³                   | Approx.<br>1.1 trillion Bq            |
| October 19,<br>2023                                | Group A    | 13×10 <sup>4</sup> Bq/liter | The sum of ratios of legally required concentrations Regulatory standards           | November 2,<br>2023             | November 20,<br>2023          | Approx.<br>800 times                 | 150-180 Bq/liter                              | 7,753m³                   | Approx.<br>1.0 trillion Bq            |
| February 26,<br>2024                               | Group B    | 17×10 <sup>4</sup> Bq/liter | The sum of ratios of legally required standards concentrations Regulatory standards | February 28,<br>2024            | March 17,<br>2023             | Approx.<br>800 times                 | 170-230 Bq/liter                              | 7,794m³                   | Approx.<br>1.3 trillion Bq            |

<sup>\*1</sup> Tritium concentrations of the water sampled at seawater pipe.

## Sea area monitoring results (concentrations of tritium in seawater)

|                     | Area   | Monitoring<br>locations | Results of quick tritium measurement            |  |  |  |  |
|---------------------|--|-------------------------|---|--|--|--|--|
| First<br>discharge  | Within a 3km of the power station                  | 10 locations            | Below the detection limit<br>- Max. 10 Bq/liter |  |  |  |  |
|                     | Within a 10km square in front of the power station | 4 locations             | Below the detection limit                       |  |  |  |  |
| Second<br>discharge | Within a 3km of the power station                  | 10 locations            | Below the detection limit<br>- Max. 22 Bq/liter |  |  |  |  |
|                     | Within a 10km square in front of the power station | 4 locations             | Below the detection limit                       |  |  |  |  |
| Third<br>discharge  | Within a 3km of the power station                  | 10 locations            | Below the detection limit<br>- Max. 11 Bq/liter |  |  |  |  |
|                     | Within a 10km square in front of the power station | 4 locations             | Below the detection limit                       |  |  |  |  |
| Fourth<br>discharge | Within a 3km of the power station                  | 10 locations            | Below the detection limit<br>- Max. 16 Bq/liter |  |  |  |  |
|                     | Within a 10km square in front of the power station | 4 locations             | Below the detection limit                       |  |  |  |  |
|                     |  |                         |   |  |  |  |  |

## [Reference] Comparison of concentration of tritium in seawater



<sup>\*1:</sup> This standard has been stipulated based on the calculation that if a person were to drink approximately 2L of the water coming out of the discharge outlet of a nuclear facility every day for one year, his/her exposure would be 1mSv. \*2: Source: Environmental Radioactivity and Radiation in Japan (Period: April 2019 to March 2022)