Sampling Results of Pump Wells of the Groundwater Bypass at Fukushima Daiichi Nuclear Power Station

<Reference> August 13, 2014 Tokyo Electric Power Company

Unit: Bq/L

	Pump wells of the groundwater bypass											
	No.1	No.2	No.3	No.4	No.5	No.6	No.7	No.8	No.9	No.10	No.11	No.12
Date of Sampling		Aug 11, 2014		Aug 11, 2014		Aug 11, 2014		Aug 11, 2014		Aug 11, 2014		Aug 11, 2014
Time of sampling		8:48 AM		8:53 AM		9:02 AM		9:07 AM		9:15 AM		9:24 AM
Gross β		ND(11)		ND(11)		ND(11)		ND(11)		ND(11)		ND(3.9)
H-3 (Approx. 12 years)		7.7		23		120		76		180		730

Linit: Da/

(Note) The detection limit is set as less than 5Bq/L for gross β obtained in pump well No.7 and No.12.

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<Reference> The Highest Dose Until the Previous Measurement

						Unit. Bq/L
	No.1	No.2	No.3	No.4	No.5	No.6
Gross β	ND	ND	ND	ND	ND	ND
H_2 (Approx 12 years)	40	84	72	120	48	230
H-3 (Approx. 12 years)	[11/26]	[12/31]	<5/8>	<3/25,5/12>	<3/25>	<4/8>

	No.7	No.8	No.9	No.10	No.11	No.12
Gross β	ND	ND	ND	ND	ND	ND
$H^{2}(\Lambda pprox, 12)$	690	100	110	330	530	2,300
H-3 (Approx. 12 years)	<4/8>	<4/22>	<5/1>	[9/1,9/2]	<6/12>	<6/30>

* The sampling date is provided in parentheses. []: 2013, < >: 2014

