Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]				
	Chemical Analysis Building *	Laboratory at Unit 5 and 6	Sampling place	Sampling date	Sampling time
Cs-134	ND(6.5E-01)	ND(5.9E-01)			
Cs-137	ND(6.3E-01)	ND(7.8E-01)	Treated water tank	Jul 22, 2014	4:00 PM
Gross β	ND (3.9E+00)	ND (4.3E+00)			
Tritium	3.9E+02	3.5E+02	Receiving tank	Jul 17, 2014	11:30 AM
Notification density rate*	0.15	0.17			

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

* Analysis of tritium is performed at Environment Management Building.