## Analysis Results of Rainwater Obtained Inside the Dike at the Tank Area After Treated by the Rainwater Treatment System

<Mobile RO membrane system>

	Measurement result [Bq/L]				
	Chemical Analysis Building *	Laboratory at Unit 5 and 6	Sampling place	Sampling date	Sampling time
Cs-134	ND ( 5.9E-01 )	ND ( 5.4E-01 )			
Cs-137	ND ( 4.6E-01 )	ND ( 6.6E-01 )	Treated water tank	Aug 5, 2014	3:40 PM
Gross β	ND ( 8.5E-01 )	ND ( 4.1E+00 )			
Tritium	1.8E+02	1.7E+02	Receiving tank	Aug 1, 2014	10:10 AM
Notification density rate*	0.046	0.156			

<sup>\* &</sup>quot;ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

<sup>\*</sup> Analysis of tritium is performed at Environment Management Building.