Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference> June 3, 2014 Tokyo Electric Power Company


				Unit: Bq/L
	Seawater of the south water outlet ^{Note 1} (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C ^{Note 2} (C- 0)	Point near Fureai Intersection in the drainage channel B ^{Note 2} (B-0-1)
Date of Sampling	Jun 2, 2014	Jun 2, 2014		
Time of sampling	7:50 AM	7:58 AM		
Cs-134(Approx. 2 years)	ND(1.4)	ND(18)		
Cs-137(Approx.30 years)	ND(1.5)	ND(22)		
Gross β	ND(18)	ND(14)		

	Unit: Bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Date of Sampling	Jun 2, 2014
Time of sampling	8:01 AM
Cs-134(Approx. 2 years)	ND(18)
Cs-137(Approx.30 years)	ND(24)
Gross β	53

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.



<reference> The Highest Dose Until the Previous Measurement Unit: Bo</reference>					
	Seawater of the south water outlet Note 1 (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C ^{Note 2} (C-0)		
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>		
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>		
Gross β	ND	2,500 [10/24]	120 <2/15>		

	Point near Fureai Intersection in the drainage channel B ^{Note 2} (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]
Gross β	380 [9/2]	15,000 [10/2]

* Sampling date is provided in parentheses. []: 2013, < >: 2014