Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

<Reference> June 9, 2014 Tokyo Electric Power Company

				Unit: Bq/L	_	
	Seawater of the south water outlet ^{Note 1} (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C ^{Note 2} (C- 0)	Point near Fureai Intersection in the drainage channel B ^{Note 2} (B-0-1)		
Date of Sampling	Jun 8, 2014	Jun 8, 2014				Date
Time of sampling	8:05 AM	7:55 AM				Time
Cs-134(Approx. 2 years)	ND(1.3)	ND(17)				Cs-134(
Cs-137(Approx.30 years)	ND(1.4)	ND(26)				Cs-137(/
Gross β	ND(15)	43				(

	Unit: Bq/L
	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Date of Sampling	Jun 8, 2014
Time of sampling	8:07 AM
Cs-134(Approx. 2 years)	17
Cs-137(Approx.30 years)	50
Gross β	79

.

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

	T-2 Seawater of the south water outlet (near the drainage channel exit)
	e channel C C-2 Drainage channel C O.P.35 exit
B south are Drainage channel B	A A A A A A A A A A A A A A A A A A A
H4 north area	* There is no outflow from the sampling point X-1 and X-2 to the drainage channel C, since they are completely isolated from the drainage channel C.
Tank area	
* The ducting is provided Point near Fureai Intersection in	C-0 Point near the main gate in the drainage channel C

<reference> The Highes</reference>	Unit: Bq/L		
	Seawater of the south water outlet ^{Note 1} (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C ^{Note 2} (C-0)
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>
Gross β	ND	2,500 [10/24]	120 <2/15>

	Point near Fureai Intersection in the drainage channel B ^{Note 2} (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]
Gross β	380 [9/2]	15,000 [10/2]

* Sampling date is provided in parentheses. []: 2013, < >: 2014