## Sampling Results Regarding the Water Leak at the Tanks in the H4 area in Fukushima Daiichi Nuclear Power Station (South Water Outlet, Drainage Channel)

## <Reference> June 14, 2014 Tokyo Electric Power Company

					Unit: Bq/L	
		Seawater of the south water outlet <sup>Note 1</sup> (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C <sup>Note 2</sup> (C- 0)	Point near Fureai Intersection in the drainage channel B <sup>Note 2</sup> (B-0-1)	
Ī	Date of Sampling	Jun 13, 2014	Jun 13, 2014			Date of Sampling
	Time of sampling	8:05 AM	7:56 AM			Time of sampling
	Cs-134(Approx. 2 years)	ND(0.79)	ND(16)			Cs-134(Approx. 2 year
Ī	Cs-137(Approx.30 years)	2.6	ND(23)			Cs-137(Approx.30 year
	Gross β	ND(18)	71			Gross β

in the dot line.

the drainage channel B

	Cs-134(Approx. 2 years)	ND(17)	
	Cs-137(Approx.30 years)	ND(26)	
	Gross β	72	
			T-2 Seawater of the south water outlet (near the drainage channel exit)
	Dra	C-2 Drainage channel C O.P.35 exit	
<b>Eu</b> Drai	B south nage channel B	X-1 Point immediately short of the junction with the drainage channel C	
	H4 north area		* There is no outflow from the sampling point X-1 and X-2 to th drainage channel C, since they a completely isolated from the drainage channel C.
	Tank area		
* The ducting is provid	led B-0-1 Point near Fureai Intersection	C-0 Point near the ma	ain gate in

the drainage channel C

Unit: Bq/L

Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1) Jun 13, 2014

8:15 AM

Note 1: Approx. 330m south from Unit 1-4 water outlet (T-2)

Note 2: Water inflow location of drainage channel to the tank area

(Defense as The Links of Decentration Decentration Measurement)

\* "ND" indicates that the measurement result is below the detection limit, and the detection limit of each nuclide is provided in parentheses.

-Reference> The Highest Dose Until the Previous Measurement Unit: E					
	Seawater of the south water outlet <sup>Note 1</sup> (near the drainage channel exit) (T-2)	Drainage channel C OP.35 exit (C-2)	Point near the main gate in the drainage channel C <sup>Note 2</sup> (C-0)		
Cs-134(Approx. 2 years)	3.5 [11/9]	45 [9/26]	20 <2/15>		
Cs-137(Approx.30 years)	8.1 [9/15,11/9]	130 [9/26]	51 <2/15>		
Gross β	ND	2,500 [10/24]	120 <2/15>		

	Point near Fureai Intersection in the drainage channel B Note 2 (B-0-1)	Side ditch next to the tank (point immediately short of the junction with the drainage channel C) (X-1)	
Cs-134(Approx. 2 years)	110 <5/1>	450 [10/4]	
Cs-137(Approx.30 years)	280 <5/1>	990 [10/4]	
Gross β	380 [9/2]	15,000 [10/2]	

\* Sampling date is provided in parentheses. []: 2013, < >: 2014