Investigation Results inside the Unit 3's PCV at Fukushima Daiichi Nuclear Power Station (Prompt report as of October 22) Tokyo Electric Power Company

The evaluation and confirmation of corrosive environment inside the PCV will be conducted by sampling and analyzing the retained water inside the PCV. The information will be acquired to explore examination methods for future research.



Investigation Results by the Pan-tilt Camera of Sampling Device

- No damage of the structures inside the PCV (electricity wire pipe, support structures, X-6 penetration, CRD rail) and the PCV's inner wall was found within the investigation range.
- Sediments were found on the CRD rail and 1st floor grating.



1. Support structures for the inspection stand

2. X-6 penetration and CRD rail







800 ml of retained water was sampled at two sampling points in the vicinity of retained water surface (approx. 0.1m below) and at approx. 0.7m below the surface.

- No damage of the structures inside the PCV (electricity wire pipe, support structures, X-6 penetration, CRD rail) and the PCV's inner wall was found within the investigation range.
- Sediments were found on the CRD rail and 1st floor grating.
- No obstacles were found to install PCV's permanent monitoring instruments.



Schedule planned for Unit 3



