

## Results of Nuclide Analyses of Sub-drains

Reference
-----------

( Data summarized on July 23)

Place of sampling	Sub-drain of Unit1, Fukushima Daiichi	Sub-drain of Unit2, Fukushima Daiichi	Sub-drain of Unit3, Fukushima Daiichi	Sub-drain of Unit4, Fukushima Daiichi	Sub-drain of Unit5, Fukushima Daiichi	Sub-drain of Unit6, Fukushima Daiichi	Deep well, Fukushima Daiichi
Time and Date of Sample Collection	2011/07/22 11:35	2011/07/22 11:40	2011/07/22 11:45	2011/07/22 13:03	2011/07/22 11:30	2011/07/22 11:20	2011/07/22 10:15
Detected Nuclides (Half-life)	Radioactivity Density of Sample ( Bq/cm <sup>3</sup> )						
I-131 (about 8 days)	ND	ND	2.5E-02	ND	ND	ND	ND
Cs-134 (about 2 years)	2.0E+00	7.7E+00	2.8E-01	1.2E-01	ND	ND	ND
Cs-137 (about 30 years)	2.5E+00	9.6E+00	3.1E-01	1.3E-01	ND	ND	ND

. E± means . ×10<sup>±</sup> .

Data of other nuclides are under evaluation.

ND means that the detected amount is below the detection limit in this analysis (I-131: approx. 6E-2Bq/cm<sup>3</sup>, Cs-134: approx. 3E-2Bq/cm<sup>3</sup>, Cs-137: approx.4E-2Bq/cm<sup>3</sup>).

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.