

Nuclide Analysis Results of Radioactive Materials in the Air  
at the Sites of Fukushima Nuclear Power Stations

Reference
-----------

(Data Summarized on July 26)

Place of sampling	Northeast part of Ground, Fukushima Daiichi (Additional monitoring at the time of nitrogen injection)		West Gate of Fukushima Daiichi		MP-1 of Fukushima Daini (Reference)		Density limit by the announcement of Reactor Regulation (Bq/cm <sup>3</sup> ) (Density limit in the air to which radiation workers breathe in the section 4 of the appendix 2) 2
Date and time of sampling	2011/07/25 9:30 ~ 9:50		2011/07/25 11:30 ~ 11:50		2011/07/25 9:31 ~ 9:41		
Detected nuclide (half-life)	Radioactivity density 1 ( Bq/cm <sup>3</sup> )	Scaling factor ( / )	Radioactivity density 1 ( Bq/cm <sup>3</sup> )	Scaling factor ( / )	Radioactivity density 1 ( Bq/cm <sup>3</sup> )	Scaling factor ( / )	
I-131 (approx. 8 days)	ND	-	ND	-	ND	-	1E-03
Cs-134 (approx. 2 years)	ND	-	ND	-	ND	-	2E-03
Cs-137 (approx. 30 years)	ND	-	ND	-	ND	-	3E-03

1 The value of radioactivity density is the sum of the value of volatile nuclide's density and the value of particulate nuclide's density.

. E - means . x 10<sup>-</sup>

Data of other nuclides are under examination.

2 In the case of more than 2 nuclides, summation of scaling factor for each statutory density is compared to 1.

3 In this analysis, "ND" means that the results fall below the measurable threshold.

(Volatile: I-131: approx. 4E-6Bq/cm<sup>3</sup>, Cs-134: approx. 1E-5Bq/cm<sup>3</sup>, and Cs-137: approx. 1E-5Bq/cm<sup>3</sup>)

(Particulate: I-131: approx. 2E-6Bq/cm<sup>3</sup>, Cs-134: approx. 6E-6Bq/cm<sup>3</sup>, and Cs-137: approx. 6E-6Bq/cm<sup>3</sup>)

Please note that these nuclides are sometimes detected even when they are below the threshold, contingent on the detector or samples.