## Result of nuclide analysis of sub drain of Fukushima Daiichi NPS

Reference

(Data summarized on December 8)

Place of Sampling	Fukushima Daiichi NPS 1U sub-drain				Fukushima Daiichi NPS 5U sub-drain		
Time of Sampling	07-Dec-11 9:50 AM	07-Dec-11 10:05 AM	07-Dec-11 10:15 AM	07-Dec-11 9:48 AM	07-Dec-11 9:45 AM	07-Dec-11 9:40 AM	07-Dec-11 9:15 AM
Detected Nuclides (Half-life)	Density of sample (Bq/cm3)						
l-131 (about 8 days)	ND	ND	ND	ND	ND	ND	ND
Cs-134 (about 2 years)	6.8E-01	4.2E-01	2.8E-02	ND	ND	ND	ND
Cs-137 (about 30 years)	9.2E-01	5.5E-01	ND	ND	ND	ND	ND

\* 0.0E - 0 means 0.0 x 10-0

\* Data of other nuclides are under evaluation.

\* "ND" means the sampled data is below measurable limit.

I-131: approx. 3E-2Bq/cm3, Cs-134: approx. 2E-2Bq/cm3, Cs-137: approx. 3E-2Bq/cm3 )

Please note that these nuclides are sometimes detected even when they are below the limits, contingent on the detector or samples.