Situation of Storage and Treatment of Accumulated Water including Highly Concentrated Radioactive Materials at Fukushima Daiichi Nuclear Power Station (208th Release)

July 3, 2015 Tokyo Electric Power Company

1. Introduction

This document is to report the following matters in accordance with the instruction of "Installment of treatment facility and storing facility of water including highly concentrated radioactive materials at Fukushima Daiichi Nuclear Power Station of the Tokyo Electric Power Company (Instruction) "(NISA No. 6, June 8, 2011), dated on June 9, 2011.

<Instruction>

TEPCO should report to NISA the situation of storing and treatment of the contaminated water in the Power Station and the future forecast based upon the current situation has to be reported to NISA as soon as the treatment facility starts its operation. Also, subsequently, continued report has to be submitted to NISA once a week until the treatment of the accumulated water in the Central Radioactive Waste Treatment Facility is completed.

2. Situation of storing and treatment of accumulated water in the building (actual record)

Stored amounts in each unit building (Units 1 to 4 (including condensers and trenches)) and stored and treated amounts, and other related data in the Accumulated Water Storing Facility as of July 2 are shown in the Attachment -1.

3. Forecast of storing and treatment

(1) Short term forecast

Water transfer is planned so that the levels of the accumulated water in Units 1&2 and Units 3&4 building will be maintained around at the level of OP. 3,000, based on the stored amount in the Accumulated Water Storing Facilities and the operating situation of the radioactive material treatment equipment. Water is transferred to the Process Main Building and/or High Temperature Incinerator Building as Accumulated Water Storing Facilities.

Treatment is implemented considering the situation of storage and transfer of Accumulated Water Storing Facilities.

We assume stored amounts in each unit building (Units 1 to 4 (including condenser and trench)), and stored and treated amounts, and other related data in the Accumulated Water Storing Facilities as of July 9, as shown in Attachment -2.

(2) Middle term forecast

Regarding accumulated water in Unit 1&2 building and Unit 3&4 building, from the viewpoint of reducing the risks of discharging to the ocean and leaking into the groundwater, it is necessary to keep enough capacity for the accumulated water in the building until its level reaches OP. 4,000 and to keep the accumulated water level lower than the groundwater level. On the other hand, based on the view of limiting inflow of underwater to buildings and reducing the amount of emerged accumulated water, we are planning to transfer accumulated water keeping its level in the building around OP. 3,000 considering water tank capacity.

As for accumulated water of the Process Main Building and the High Temperature Incinerator Building, we are planning to treat the accumulated water considering the situation of construction of middle and low level waste water tanks, the operation factor of the radioactive material treatment instruments and duration for maintenance.


We forecast stored amounts in each unit building (Unit 1 to 4 (including condensers and trenches)), and storing and treatment situations in the Accumulated Water Storing Facilities for the next 3 months, as shown in Attachment -3.

Stored amounts in each building and the water storage equipment are forecasted to be unchanged in case transfer and treatment were implemented as scheduled without rain. However, it would be subject to change depending on the operation factor of the radioactive material treatment instruments and so on.

Also, the water treated at the radioactive material treatment equipment (fresh water and condensed salt water) can be stored in the middle and low level waste water tanks.

END

Storage and treatment of high level radioactive accumulated water (as of July 2, 2015)



| Storage volume | Change from last | Water level in T/B | Storage Facility | Storage volume | Change from last report | Water level | Treated volume (6/26 -7/2) | Cumulative treated volume | Waste produced | | Change from last report | Storage capacity |
|------------------------------|---------------------|-----------------------|---------------------------------------|------------------------------|----------------------------|-------------|-------------------------------|---------------------------------------|----------------|------------------------------|---------------------------------------|---|
| Approx. 13,100m ³ | -100m ³ | OP.2,615 | Process Main Building | Approx. 16,140m ³ | +100m ³ | OP.4,562 | Approx.5,190m ^{3*7} | Approx. 1,262,780m ³ "7 | Sludge | 597m ³ | No Change | 700m ^{3*3} |
| Approx. 16,300m ³ | +600m ³ | OP.2,893 | High Temperature Incinerator Building | Approx. 2,440m ³ | -20m ³ | OP.1,218 | Approx.5, 190m | | Used vessels | 2,616 ^{*8} | +13 | 6,055 |
| Approx. 17,400m ³ | -800m ³ | OP.2,873 | Total | Approx. 18,580m ³ | | | | | *1 The | figures of the data are trea | teri as a reference, hecause water le | wels during water transfer are not stal |

1 In Bigures of the data are releated as a reinterfered, becaule water levels during water transfer are hot stable. 27 The figures of the storage volume do not include those of the following volumes that have accumulated from the bottom of the tarries to the height of so-called "down scale (DS)," where water gauges show 0%. Freshwater receiving tank (approx.100m), Contentiated water liquid storage tank (approx.100m), Contentiated water liquid storage tank (approx.100m).

Frisshwater receiving lark (approx. 1.000m¹). Concentrated water liquid storage tark (approx. 100m¹).
Treated water storage tark (approx. 100m²). Storaum-treated water storage tark (approx. 100m²).
The floyers of the data show the operational limits.
4 The figures of Storage capacity (10 ont include those of the volumes that have accumulated from the bottom of the tanks to
the height of so-called "down scale (DS)." where water gauges show 0%. However, each tank has the capacity that accomode
more than the storage tark (approx. 100m²). Storage capacity (10 the height of TS).
5 The data shows here are those of the height of TS.
5 The data shows here are those of C-137.
7 Total treated amount of C-sulf. Cesium adsorption apparatus (S).
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those of C-137.
5 The data shows here are those

2nd cesium Cesium adsorption apparatus (140) Others: Storage container (1,619), Treated column (3) ,Used vessel (155), Filiters and so forth (65

Since June 23, the operation of the Cesium Adsorption Apparatus has been suspended.

The operation of the 2nd Cesium Adsorption Apparatus has been conducted; the availability factor has been 61.8% (previously assumed: 60%), On June 25 and 26, water transfer from the Condensate Storage Tanks at Unit 1 to the Radioactive Waste Treatment Facility at Unit 1 was conducted.

On June 28, water transfer from Unit 1 T/B to the Radioactive Waste Treatment Facility at Unit 1 was conducted.

Main operations that have been conducted during the period from June 25, 2015 (the previous announcement data) to July 2, 2015] • On June 27, water transfer from Unit 2 to the High Temperature Incinerator Building was suspended, and on June 28, the transfer resumed

On July 1, water transfer from Unit 1 Emergency Diesel Generators (B) to Unit 1 T/B was conducted.

OP.2.848

The storage capacity of the Treated Water Storage Tank increased by adding new tanks.

+100m³

Facility Unit 1 Unit 2 Unit 3

Unit 4


Total

Approx. 16,300m³

Approx. 63,100m³

On June 30, water transfer from Unit 2 to the High Temperature Incinerator Building was suspended, and on July 1, the transfer resumed. Since the resumption, the transfer has continued. On June 25, water transfer from Unit 3 to the High Temperature Incinerator Building resumed, and on June 27, the transfer was suspended. On June 28, water transfer from Unit 3 to the High Temperature Incinerator Building resumed, and on June 30, the transfer was suspended. On July 1, water transfer from Unit 3 to the High Temperature Incinerator Building resumed, and since the resumption, the transfer has continued.

Storage and treatment of high level radioactive accumulated water (as of July 9, 2015)



| Facility | | | Water level in T/B | Storage Facility | Storage volume | Change from last report | Water level | Treated volume (7/3 - 7/9) | Cumulative treated volume | Waste | produced | Change from last report | Storage capacity |
|----------|------------------------------|--------------------|-----------------------|---------------------------------------|------------------------------|----------------------------|-------------|-------------------------------|---------------------------------|--------------|-------------------------|------------------------------|-------------------------------|
| Unit 1 | Approx. 13,200m ³ | +100m ³ | OP.2,910 | Process Main Building | Approx. 16,260m ³ | +120m ³ | OP.4,597 | Approx.4,200m ^{3*5} | Approx. 1,266,980m ³ | Sludge | 597m ³ | No Change | 700m ^{3 *2} |
| Unit 2 | Approx. 16,200m ³ | -100m ³ | (Unit 2 T/B) | High Temperature Incinerator Building | Approx. 4,020m ³ | +1,580m ³ | OP.2,519 | Approx.4,200m | *5 | Used vessels | 2,640 ^{*6} | +24 | 6,055 |
| Unit 3 | Approx. 17,000m ³ | -400m ³ | OP.2,815 | Total | Approx. 20,280m ³ | | | | | | | | |
| Unit 4 | Approx. 16,100m ³ | -200m ³ | (Unit 3 T/B) | | | | | | | *1 | The figures of "Storage | volume" do not include those | of the volumes that have accu |

[Main operations that are planned to be conducted during the period from July 2, 2015 to July 9, 2015.]

- Water transfer from Unit 2 to the High Temperature Incinerator Building will be suspended. Water transfer from Unit 2 to the High Temperature Incinerator Building will resume
- Water transfer from Unit 3 to the High Temperature Incinerator Building will be suspended. Water transfer from Unit 3 to the High Temperature Incinerator Building will resume

The operation of Cesium Adsorption Apparatus will continue to be suspended.

Total

Approx. 62,500m3

The operation of 2nd Cesium Adsorption Apparatus is scheduled (assumed Availability Factor 50%).

- *1 The figures of "Storage volume" do not include those of the volumes that have accumulated from the bottom of the tanks to the height of so-called "down scale (DS)," where water gauges show 0%.
- *2 The figures of the data show the operational limits.
- *3 The figures of "Storage capacity" do not include those of the volumes that have accumulated from the bottom of the tanks to the height of so-called "down scale (DS)," where water gauges show 0%. However, each tank has the capacity that accomodates more than the storage volume that accumulates up to the height of "DS."
- *4 The figure of "Residual water" includes the one of the volumes that have accumulated from the bottom of the tanks to
- the height of so-called "down scale (DS)," where water gauges show 0%. *5 Total treated amount of Cesium adsorption apparatus and 2nd Cesium adsorption apparatus
- Breakdown of the treated amount: Cesium adsorption apparatus (0m³) 2nd Cesium adsorption apparatus (4,200m³)
 - Breakdown of the cumulative treated amount: Cesium adsorption apparatus (288,350m3)


*5 Breakdown of the used vessels:

Cesium adsorption apparatus (634)

2nd cesium Cesium adsorption apparatus (142), Others: Storage container (1,640), Treated column (3) Used vessels (156)

Filters and so forth (65

2nd Cesium adsorption apparatus (978,630m3)



- The amount of water treated by the 2nd Cesium Adsorption Apparatus is estimated to be 780m³/d (Subject to change depending on the factors such as the levels of water accumulated in T/Bs.)

- "Accumulated Water Levels in Unit 2 and 3 T/Bs" are simulated water levels in consideration of the change of the water levels caused by recent rainfall, inflow of groundwater, etc. in the surrounding areas of the Fukushima Daiichi Nuclear Power Station.

"Accumulated Water Levels in Unit 2 and 3 T/Bs Taking into Account the Rainfall" are simulated water levels which are calculated by adding to the accumulated water amounts which are assumed to increase at the rate of 5mm a day when the surrounding areas of the Fukushima Daiichi Nuclear Power Station have the rainfall equal to the average amount of rain which fell for three months from August to October in 2008 to 2010.